

AMM 03/10

Louisville Engineering, Construction & Management (LECM)  
Limited Energy Study - LECM  
Fort Campbell, Kentucky

Final Report  
Volume 1  
Sections 1-5

CONTRACT DAACA27-01-84-D-0034  
SYSTEMS CORP PROJECT #64013.01  
SEPTEMBER 23, 1994



19971016 257

**SYSTEMS**  
*corp*

SYSTEMS ENGINEERING AND MANAGEMENT CORPORATION

## TABLE OF CONTENTS

FY04 BEAP LIGHTING ENERGY STUDY, FT. CAMPBELL, KY

### VOLUME I

1.	EXECUTIVE SUMMARY .....	1-1
1.1	Synopsis .....	1-1
1.2	Introduction .....	1-1
1.2.1	Scope of Work .....	1-1
1.2.2	Organization of the Final Report .....	1-2
1.3	Present and Historical Electrical Energy Consumption .....	1-2
1.4	Energy Conservation Opportunities Investigated .....	1-2
1.4.1	ECOs Recommended .....	1-5
1.4.2	ECOs Rejected .....	1-5
1.4.3	ECIP Projects Developed .....	1-5
2.	METHODS AND APPROACH .....	2-1
2.1	Field Survey .....	2-1
2.1.1	Interior/Exterior Lighting .....	2-1
2.1.2	Lighting Controls .....	2-6
2.2	Calculations .....	2-6
2.2.1	Baseline Energy Consumption .....	2-6
2.2.1.1	Baseline Energy Consumption: ECO-1 .....	2-6
2.2.1.2	Baseline Energy Consumption: ECO-2 .....	2-10
2.2.2	ECO Energy Consumption .....	2-10
2.2.2.1	ECO Energy Consumption: ECO-1 .....	2-10
2.2.2.2	ECO Energy Consumption: ECO-2 .....	2-10
2.3	Energy Conservation Opportunities .....	2-12
2.3.1	ECO-1: High Efficiency Interior/Exterior Lighting .....	2-12
2.3.2	ECO-2: Lighting Controls .....	2-13
2.4	ECO Life Cycle Costs .....	2-18
2.4.1	Energy Costs - Electricity .....	2-18
2.4.2	Maintenance and Replacement Costs .....	2-18
3.	PROJECT I: INTERIOR/EXTERIOR LIGHTING AT AIRFIELD .....	3-1
4.	PROJECT II: LIGHTING CONTROLS AT AIRFIELD .....	4-1
5.	PROJECT III: INTERIOR LIGHTING AND CONTROLS AT BLANCHFIELD HOSPITAL .....	5-1

## **REPRODUCTION QUALITY NOTICE**

**This document is the best quality available. The copy furnished to DTIC contained pages that may have the following quality problems:**

- **Pages smaller or larger than normal.**
- **Pages with background color or light colored printing.**
- **Pages with small type or poor printing; and or**
- **Pages with continuous tone material or color photographs.**

**Due to various output media available these conditions may or may not cause poor legibility in the microfiche or hardcopy output you receive.**



**If this block is checked, the copy furnished to DTIC contained pages with color printing, that when reproduced in Black and White, may change detail of the original copy.**

## TABLE OF CONTENTS

FY04 BEAP LIGHTING ENERGY STUDY, Ft. Campbell, KY

## VOLUME II

6. PROJECT IV: INTERIOR LIGHTING AT KOREAN WAR BARRACKS . . . . . 6-1

## APPENDICES

- |    |   |     |
|----|---|-----|
| A. | SCOPE OF WORK . . . . .                         | A-1 |
| B. | INTERIM REVIEW COMMENTS AND RESPONSES . . . . . | B-1 |
| C. | INTERIM REVIEW PRESENTATION . . . . .           | C-1 |
| D. | MAINTENANCE COSTS CALCULATIONS . . . . .        | D-1 |

## TABLE OF CONTENTS

FY94 LEAP LIGHTING ENERGY STUDY, FT. CAMPBELL, KY

### TABLES, FIGURES, AND FORMS

Table 1.3.1	Fort Campbell Electric - FY93 . . . . .	1-3
Table 1.4.3	Fort Campbell Lighting Energy Study: ECIP Project Summary . . . . .	1-6
Table 2.1.1	Buildings Surveyed . . . . .	2-2
Table 2.2.1.1.1	Baseline Energy Consumption: ECO-1 . . . . .	2-7
Table 2.2.1.2.1	Baseline Energy Consumption: ECO-2 . . . . .	2-11
Table 2.4.1.1	Fort Campbell Electric - FY93 . . . . .	2-19
Table 2.4.2.1	Maintenance and Replacement Costs . . . . .	2-22
Table 3.1	Project Summary: Interior/Exterior Lighting at Airfield . . . . .	3-2
Table 4.1	Project Summary: Lighting Controls at Airfield . . . . .	4-2
Table 5.1	Project Summary: Hospital Interior Lighting Controls . . . . .	5-2
Table 6.1	Project Summary: Interior Lighting at Korean War Barracks . . . . .	6-2
Figure 1.3.1	Fort Campbell Electric - FY93 . . . . .	1-4
Figure 2.4.1.1	Fort Campbell Electric - FY93 . . . . .	2-20
Form 2.3.1.1	Simplified Lighting Design Calculation - T12, 34W . . . . .	2-14
Form 2.3.1.1	Simplified Lighting Design Calculation - T8, 32W . . . . .	2-16

## 1 EXECUTIVE SUMMARY

FY94 EEAP LIGHTING ENERGY STUDY, FT. CAMPBELL, KY

### 1.1 SYNOPSIS

Systems Corp surveyed and completed energy analyses for 95 representative buildings at Fort Campbell, categorized as Korean War Barracks, Airfield Buildings, and Blanchfield Hospital buildings B and C. The energy conservation opportunities (ECOs) evaluated were high efficiency interior and exterior lighting, and indoor lighting controls. Cost estimates were prepared using MeanaData for Windows Spreadsheets, Version 2.0a. Life cycle cost analyses were performed using the Life Cycle Cost in Design (LCCID) computer program. Project development brochures (PDBs) and DD1391 forms were prepared for four Energy Conservation Investment Program (ECIP) projects. The total of the four projects that were developed represent \$383,283 in annual savings with a simple payback of 6.37 years and a saving to investment ratio (SIR) of 1.89.

### 1.2 INTRODUCTION

Systems Engineering and Management Corporation (Systems Corp) was contracted by the Louisville District of the United States Army Corps of Engineers in June 1994 to perform a limited energy study for 95 buildings at Fort Campbell, Kentucky. The project includes a study of interior and exterior lighting, as well as controls.

#### 1.2.1 Scope of Work

1. Evaluate selected energy conservation opportunities (ECOs) to determine their energy savings potential and economic feasibility.
2. Conduct a limited site survey of selected buildings or areas to insure that any methods of energy conservation which are practical and have not been evaluated in any previous energy study have been considered and the results documented.
3. Determine efficiency of existing systems. Determines the replacement option with the highest SIR.
4. Provide complete programming or implementation documentation for all recommended ECOs.
5. Prepare a comprehensive report to document the work performed, the results, and the recommendations.

## 1 EXECUTIVE SUMMARY

FY94 EEAP LIGHTING ENERGY STUDY, FT. CAMPBELL, KY

### 1.2.2 Organization of the Final Report

The submitted material for this report consists of the following:

Volume I: Executive Summary, Methods and Approach, Project I: Interior/Exterior Lighting at Airfield, Project II: Lighting Controls at Airfield, Project III: Interior Lighting and Controls at Blanchfield Hospital, Project IV: Interior Lighting at Korean War Barracks

Volume II: Scope of Work, Interim Review Comments and Responses, and Interim Review Presentation

### 1.3 PRESENT AND HISTORICAL ELECTRICAL ENERGY CONSUMPTION

The baseline energy consumptions and the energy conservation opportunity energy consumption were determined using spreadsheets and manual calculating to model system energy consumption. These have been included in Section 2 of this report.

The electric energy consumptions, demand, and total costs for FY93 are shown in Table 1.3.1 Fort Campbell Electric. Figure 1.3.1 is a bar graph of the monthly consumption and cost for FY93. The electric costs used to calculate the electric cost savings for the project are as follows:

COST/kWh	= \$0.02114/kWh (No Demand)
COST/MBtu	= \$6.18/MBtu (No Demand)
COST/kW	= \$11.78/kW (Monthly Demand)

### 1.4 ENERGY CONSERVATION OPPORTUNITIES INVESTIGATED

Systems Corp analyzed two energy conservation opportunities (ECOs) at Fort Campbell, Kentucky. The analysis was performed utilizing energy models developed by Systems Corp and data collected during the field survey of the facilities at Fort Campbell. Each ECO was evaluated to determine the potential energy savings, dollar savings, implementation costs, simple payback, life cycle cost, and savings to investment ratio (SIR). The two ECOs that were evaluated are as follows:


ECO - 1 High Efficiency Interior/Exterior Lighting

ECO - 2 Lighting Controls

**Table 1.3.1**  
**Fort Campbell Electric**  
**FY93**

Month	Demand (kW)	Consumption (kWh)	Total Cost	Cost/kWh
Oct '92	31,072	6,077,800	\$739,316	\$0.046
Nov	34,020	7,257,200	\$800,866	\$0.046
Dec	33,907	10,320,400	\$821,704	\$0.045
Jan '93	35,351	10,307,400	\$880,657	\$0.046
Feb	36,140	17,644,200	\$857,977	\$0.049
Mar	33,944	17,894,100	\$811,111	\$0.048
Apr	34,883	15,861,200	\$780,282	\$0.048
May	43,697	16,429,600	\$828,917	\$0.050
Jun	47,212	23,372,800	\$1,061,098	\$0.045
Jul	50,069	25,800,600	\$1,160,394	\$0.045
Aug	49,588	25,229,400	\$1,141,714	\$0.045
Sep	43,281	17,486,800	\$802,283	\$0.042
<b>TOTAL</b>	<b>474,882</b>	<b>232,957,200</b>	<b>\$10,864,239</b>	<b>\$0.047</b>
Min	31,072	15,691,200	\$739,348	\$0.046
Max	50,069	25,800,600	\$1,160,394	\$0.045
Avg	39,574	19,413,100	\$805,353	\$0.047

*Figure 1.3.1*  
**Fort Campbell Electric  
FY93**



## 1 EXECUTIVE SUMMARY

FY94 EEAP LIGHTING ENERGY STUDY, Ft. CAMPBELL, KY

Systems Corp's energy analysis models were used to determine the savings achieved for implementing each ECO in the facilities that were evaluated. Means Data for Windows Spreadsheets, Version 2.0a cost estimating software was used to estimate the implementation cost of each ECO in each facility evaluated. The U.S. Army Corps of Engineers' Life Cycle Cost in Design, Version 1.0, Level 80, software was used to perform life cycle cost analyses and determine the SIR of each ECO for each facility evaluated.

### 1.4.1 ECOs Recommended

Systems Corp recommended that both of the ECOs evaluated be implemented, but not in every area surveyed. The following is a list of the ECOs recommended to be implemented by area surveyed. The criteria for recommendation is a favorable simple payback and savings to investment ratio (SIR).

ECO - 1: Airfield Buildings  
Blanchfield Hospital  
Korean War Barracks

ECO - 2: Airfield Buildings  
Blanchfield Hospital

### 1.4.2 ECOs Rejected

ECO-2, Lighting Controls, in the Korean War Barracks was rejected due to the large investment required for the proper controls set-up. The best opportunity for lighting controls was in the latrine areas. Due to multiple walls and sections, multiple overhead occupancy sensors would be required. Good energy savings were available, but the high investment costs gave the project a poor simple payback and SIR.

### 1.4.3 ECIP Projects Developed

Systems Corp developed four ECIP/FEMP projects. The projects included interior/exterior lighting in 28 buildings at the Airfield, lighting controls in 15 buildings at the Airfield, interior lighting and controls at Blanchfield Hospital, and interior lighting at 44 Korean War Barracks. The following table summarizes the savings and investments for each project.

**TABLE 1.4.3**  
**FORT CAMPBELL LIGHTING ENERGY STUDY**  
**ECIP PROJECT SUMMARY**

PROJECT NUMBER	DESCRIPTION	1ST YEAR SAVINGS	TOTAL INVESTMENT	SPI (YRS)	SIR
1	INTERIOR LIGHTING AT AIRFIELD (ECO 1)	\$130,855	\$709,900	5.43	2.21
2	LIGHTING CONTROLS AT AIRFIELD (ECO 2)	\$26,208	\$60,078	2.20	3.21
3	INTERIOR LIGHTING AND LIGHTING CONTROLS AT HOSPITAL (ECO 1 & 2)	\$78,518	\$424,003	5.33	2.27
4	INTERIOR LIGHTING AT KOREAN WAR BARRACKS (ECO 1)	\$148,900	\$1,280,718	8.47	1.43
<b>PROJECT TOTALS</b>		<b>\$385,283</b>	<b>\$2,454,696</b>	<b>6.37</b>	<b>1.89</b>

## 2 METHODS AND APPROACH

FY94 LEAP LIGHTING ENERGY STUDY, FT. CAMPBELL, KY

### 2.1 FIELD SURVEY

The field survey as performed by Systems Corp was designed to provide the necessary data required to complete the Scope of Work for this project. It was also designed to provide residual benefits to the installation by providing an organized and readily available source of information which can be used in future years. The information was transmitted in the form of field notes using standardized survey forms.

The survey forms were designed to allow notation of all data which could be utilized (not necessarily required) to calculate the energy savings gained by implementing a specific energy conservation opportunity. These forms contain data obtained from as-built drawings and confirmed in the field, as well as data obtained only in the field. Table 2.1 lists the buildings surveyed, sorted by type.

#### 2.1.1 Interior/Exterior Lighting

Thorough preparation for the building survey ensures that the data required to perform the technical analysis is obtained. The building surveys were performed in a manner which assured the best results. A simple listing of each step of the process best describes our approach to the surveys.

1. The list of ECOs included in the work scope were reviewed in detail.
2. Each ECO was given an identification number which is used consistently throughout the project.
3. An expanded description of each ECO was formulated to outline the possible methods for implementation of the ECO.
4. Survey forms were developed for each ECO to provide space to enter any data which might possibly be used in performing the engineering and economic analysis of the ECO.
5. A list of the types of as-built drawings required for the buildings was prepared based on the information required on the ECO survey forms.
6. The building surveys are then performed, confirming or revising data obtained from the drawings. Additional data is obtained as required.

Note: A Systems Corp representative assisted during the survey in gathering the necessary as-built drawings. Due to the age of drawings, most of the required information was gathered during the survey, while physically present at the buildings.

Systems Corp survey teams met with the post Energy Officer throughout the survey on an as-needed basis.

**TABLE 2.1.1**  
**BUILDINGS SURVEYED**

BUILDING TYPE	BUILDING NUMBER	BUILDING AREA (SQ FT)
HOSPITAL	650	227,735
	TOTAL AREA THIS TYPE	227,735
BARRACKS		
	3211	39,722
	3212	39,722
	3213	42,627
	3214	42,627
	3215	39,809
	3216	39,809
	3217	39,722
	3218	39,722
	6709	38,145
	6710	38,408
	6711	38,329
	6712	38,585
	6718	31,869
	6719	31,779
	6725	38,241
	6726	38,160
	6727	38,312
	6728	38,285
	6730	38,138
	6731	38,208
	6732	38,442
	6733	37,977
	6909	31,758
	6910	38,089
	6911	38,280
	6912	38,310
	6917	38,480
	6918	38,645
	6919	38,711
	6920	38,649
	6921	38,812
	6922	38,391
	6923	38,465
	6927	38,118
	6928	38,120

**TABLE 2.1.1**  
**BUILDINGS SURVEYED**

BUILDING TYPE	BUILDING NUMBER	BUILDING AREA (SQ. FT.)
BARRACKS (CONT)	6929	38,281
	6930	38,196
	6931	31,713
	6936	31,735
	6937	37,900
	6938	38,039
	6939	38,137
	6940	38,127
	6942	38,098
	6943	38,049
	6944	38,063
	6945	31,685
	7110	25,628
	7112	25,625
	7118	25,625
	7120	25,625
	TOTAL AREA THIS TYPE	1,877,991
AIRFIELD SUPPORT FACILITIES		
	7109	192
	7141	192
	7150	9237
	7155	4518
	7157	9648
	7158	100
	7159	4256
	7162	1256
	7164	3108
	7165	954
	7170	8400
	7176	3230
	7179	8300
	7187	1734
	7212	1849
	7287	29744
	TOTAL AREA THIS TYPE	83,719

**TABLE 2.1.1**  
**BUILDINGS SURVEYED**

BUILDING TYPE	BUILDING NUMBER	BUILDING AREA (SQ FT)
<b>HANGAR</b>		
	7152	20511
	7154	36677
	7158	34785
	7206	24178
	7208	41912
	7210	32611
	7214	41860
	7218	41800
	7243	41117
	7245	49139
	7249	49139
	7161	11218
	7262	59243
	7264	60000
	7268	60400
	7272	40548
	<b>TOTAL AREA THIS TYPE</b>	<b>683,198</b>
<b>DINING FACILITIES</b>		
	7114	7173
	<b>TOTAL AREA THIS TYPE</b>	<b>7,973</b>
<b>ADMINISTRATIVE</b>		
	7131	15404
	7133	15404
	7145	2381
	7163	11756
	<b>TOTAL AREA THIS TYPE</b>	<b>48,148</b>

**TABLE 2.1.1**  
**BUILDINGS SURVEYED**

BUILDING TYPE	BUILDING NUMBER	BUILDING AREA (SQ FT)
STORAGE		
	7134	17950
	7177	5512
	7281	12500
	TOTAL AREA THIS TYPE	36,862
MEDICAL CLINIC		
	7149	9248
	TOTAL AREA THIS TYPE	9,248
FIRE STATION		
	7160	12516
	TOTAL AREA THIS TYPE	12,516
	TOTAL AREA SURVEYED	2,954,887

## **2 METHODS AND APPROACH**

FY94 ERAP LIGHTING ENERGY STUDY, F. CAMPBELL, KY

### **2.1.2 Lighting Controls**

The lighting controls survey was performed in much the same way as the interior/exterior lighting survey. The same buildings were surveyed. The following is a listing of the additional steps required for the lighting controls survey.

1. The current method of control was identified through as-built drawings and field survey.
2. Systemis Corp representatives met with Blanchfield Hospital EMCS operators to discuss the current lighting control scheme at the hospital.
3. Building surveys were performed to identify opportunities for energy saving controls.
4. Systemis Corp met with the post Energy Officer throughout the survey on an as-needed basis.

### **2.2 CALCULATIONS**

Energy calculations were performed using computerized techniques. Due to the large volume of calculations to be performed, standardized procedures were developed for the computer models. This assured consistent results and uniformity of quality in all of the calculations performed.

#### **2.2.1 Baseline Energy Consumption**

The following sections will describe the method for calculating the baseline energy consumption for each of the two ECOs.

##### **2.2.1.1 Baseline Energy Consumption: ECO-1**

The baseline energy consumption for this ECO was calculated using a LOTUS123 spreadsheet. This spreadsheet modeled the energy consumption of the existing lighting systems by utilizing the following:

1. Existing fixture and lamp type (i.e., fluorescent, mercury vapor, etc.)
2. Lamp wattage
3. Ballast wattage
4. Hours of use

The above information was obtained during the field survey. Table 2.2.1.1 lists the baseline energy consumption for the buildings surveyed for ECO-1.

**TABLE 2.2.1.1.1**  
**BASELINE ENERGY CONSUMPTION**  
**ECO-1**

<b>ECO NUMBER</b>	<b>BUILDING NUMBER</b>	<b>BASELINE ENERGY CONSUMPTION (MJ)</b>
1	650	6,968,845
1	3211	481,732
1	3212	702,374
1	3213	489,861
1	3214	519,383
1	3215	1,021,811
1	3216	1,063,988
1	3217	503,772
1	3218	782,897
1	6709	525,223
1	6710	644,985
1	6711	321,630
1	6712	449,422
1	6718	267,404
1	6719	327,441
1	6725	297,891
1	6726	295,772
1	6727	373,547
1	6728	442,693
1	6730	438,582
1	6731	494,042
1	6732	483,058
1	6733	471,603
1	6909	418,778
1	6910	275,939
1	6911	525,156
1	6912	420,325
1	6917	599,011
1	6918	554,236
1	6919	634,674
1	6920	528,344
1	6921	448,785
1	6922	379,575
1	6923	555,798
1	6927	618,515

**TABLE 2.2.1.1.1**  
**BASELINE ENERGY CONSUMPTION**  
**ECO-1**

<b>ECO NUMBER</b>	<b>BUILDING NUMBER</b>	<b>BASELINE ENERGY CONSUMPTION (MJ)</b>
1	6928	551,605
1	6929	471,640
1	6930	659,472
1	6931	417,944
1	6936	381,338
1	6937	534,601
1	6938	600,981
1	6939	489,744
1	6940	549,808
1	6942	253,371
1	6943	537,138
1	6944	547,375
1	6945	450,202
1	7109	77,906
1	7110	23,173
1	7112	12,614
1	7116	35,606
1	7118	10,853
1	7120	9,280
1	7131	230,669
1	7133	189,379
1	7134	215,759
1	7141	30,989
1	7145	14,108
1	7149	148,962
1	7150	163,309
1	7152	77,248
1	7154	127,034
1	7155	42,221
1	7156	168,937
1	7157	76,288
1	7158	2,642
1	7159	59,065
1	7160	208,664
1	7163	174,858

**TABLE 2.2.1.1.1**  
**BASELINE ENERGY CONSUMPTION**  
**ECO-1**

<b>ECO NUMBER</b>	<b>BUILDING NUMBER</b>	<b>BASELINE ENERGY CONSUMPTION (MJ)</b>
1	7164	110,477
1	7165	34,532
1	7170	162,509
1	7178	112,867
1	7177	3,145
1	7179	95,486
1	7187	11,831
1	7208	617,305
1	7208	1,259,069
1	7210	881,474
1	7212	85,973
1	7214	1,080,339
1	7218	1,774,513
1	7243	1,810,377
1	7245	1,400,367
1	7249	1,400,367
1	7262	280,195
1	7264	169,048
1	7267	95,092
1	7268	234,593
1	7272	179,431
1	7281	195,374

## 2 METHODS AND APPROACH

APPENDIX E: ENERGY STUDY, FORT CAMPBELL, KY

### **2.2.1.2 Baseline Energy Consumption: ECO-2**

The baseline energy consumption for this ECO was also calculated using a LOTUS123 spreadsheet. The energy consumption was modeled using field measurements and local climatological data at Fort Campbell. The baseline was calculated after implementation of any proposed retrofits under ECO-1. The purpose of this was not to eliminate over estimating the savings. The information necessary to calculate the baseline include the following

1. Existing lighting systems-type and wattage (and corresponding information on replacement system, if applicable)
2. Hours of use

The above information was obtained during the field survey. Table 2.2.1.2.1 lists the baseline energy consumption for the buildings included in ECO-2.

### **2.2.2 ECO Energy Consumption**

The following sections describe how the energy consumption (or energy savings) for each of the two ECOS was calculated.

#### **2.2.2.1. ECO Energy Consumption: ECO-1**

The energy consumption for this ECO was calculated in the same manner as the baseline for ECO-1. New lamp wattages, number of lamps, and fixture wattages were substituted for the existing lighting systems. For a detailed description of replacement fixtures, please refer to Section 3.6.

#### **2.2.2.2 ECO Energy Consumption: ECO-2**

The energy consumption for this ECO was calculated in the same manner as the baseline for ECO-2. Two control options were evaluated under this ECO, occupancy sensors and daylight sensors. The daylight sensors utilize on/off photocells to limit the use of artificial lighting when daylighting is providing the necessary light levels. The required hours to operate the lighting systems to maintain the recommended light levels were determined from the local climatological data for the Fort Campbell area. This data includes hours of heavy fog, thunderstorms, and cloudy skies during daytime hours. Revised hours of operation were substituted for the existing hours used for the baseline.

**TABLE 2.2.1.2.1**  
**BASELINE ENERGY CONSUMPTION**  
**ECO-2**

<b>ECO NUMBER</b>	<b>BUILDING NUMBER</b>	<b>BASELINE ENERGY CONSUMPTION (MJ)</b>
2	650	401,562
2	7152	82,128
2	7154	82,128
2	7158	92,394
2	7160	18,450
2	7206	179,856
2	7208	413,338
2	7210	150,696
2	7214	578,673
2	7218	578,673
2	7243	361,670
2	7245	210,974
2	7249	210,974
2	7262	727,834
2	7264	667,181
2	7268	363,917
2	7272	272,938

## 2 METHODS AND APPROACH

1994 LEAP LIGHTING ENERGY STUDY, Ft. CAMPBELL, KY

### 2.3 ENERGY CONSERVATION OPPORTUNITIES

The energy consumption for each of the energy conservation opportunities was prepared after the successful run of the baseline calculations. Calculation of the ECOs requires preparing a conceptual design which would allow implementation of the ECO. It is important to note that an ECO may be implemented in several ways. The designer must carefully consider the options to ensure the chosen design is the most likely to result in a savings that can justify the investment. After completing the conceptual design, the energy results were calculated by computer spreadsheets. The calculations were then reviewed for accuracy and technical feasibility. When problems were discovered, the calculations were revised and corrected.

After completing the energy calculations for each ECO, the cost estimates and economic analysis were prepared. A standardized bill of materials was prepared for each building within each ECO. Material sizes, quantities, and prices were prepared to represent specific conditions of the ECO. Annual and non-annual recurring costs are an important part of the life cycle cost for a given project. Each ECO was evaluated individually to determine the correct difference in these costs between the current condition and the future condition.

The following is a description for each ECO of how the calculations were performed in terms of the energy-efficient replacement products used.

#### 2.3.1 ECO-1: High Efficiency Interior/Exterior Lighting

Many options were available which would fulfill this ECO. The goal was to increase the lighting efficiency of the interior and exterior lighting as much as possible while still being cost effective.

The following is a list and description of the options implemented. All options are not evaluated in all buildings due to applicability.

1. **Two Fixtures, Four Foot, Eight Foot Fluorescent Fixtures:** Replaced existing T12 lamps with T8 lamps and electronic ballasts. Reflectors were used in some fixtures to reduce the required number of lamps. Please refer to Sections 3 through 6 for a detailed description of reflector use. Reflectors were used only in four foot fixtures. There was a one-for-one fixture replacement.
2. **Incandescent Lighting:** Incandescents with wattages less than 200 watts were replaced with compact fluorescents. Incandescents in office areas with wattages greater than or equal to 200 watts were replaced with a two lamp, four foot, T8 fixture. There was not a one-for-one replacement for these high wattage lamps. Incandescents in shop bays, 200 watts or greater, were replaced with high pressure sodium fixtures.

## 2 METHODS AND APPROACH

FY94 EEAP LIGHTING ENERGY STUDY, F. CAMPBELL, KY

3. **Exit Signs:** Existing incandescent and fluorescent exit signs were replaced with LED exit signs, either through retrofit or complete sign replacement, except in the hospital where no retrofit was performed due to the type of the existing sign.
4. **Mercury Vapor Fixtures:** Existing mercury vapor fixtures were replaced with metal halide or high pressure sodium fixtures. Metal halide fixtures were used at all hangar facilities. Exterior mercury vapor fixtures were replaced with high pressure sodium fixtures. There was a one-for-one fixture and lumen replacement.

Please refer to Section 3 through 6 for a detailed description of replacements utilized in each facility.

In reference to option 1 above, the decision on whether or not to use reflectors and to delamp was based on light level readings taken during the field survey and on room cavity calculations. Most areas in the barracks were significantly underlit. In these areas, fixtures with an equal number of lamps were used as replacements. Most areas in Blanchfield Hospital and in administrative facilities at the Airfield had adequate or slightly high light levels. In these areas, reflectors were used and the number of lamps reduced. Form 2.3.1.1 shows example room cavity calculations to demonstrate existing foot candles and replacement foot candles.

In addition to savings calculated for lighting retrofits, air conditioning savings were calculated at Blanchfield Hospital. Since the hospital has year round cooling requirements, reducing the lighting load also reduces the air conditioning load. A Coefficient of Performance (COP) of 3.0 for the cooling equipment was assumed. This value was used along with the reduced lighting wattage to calculate the air conditioning savings.

### 2.3.2 ECO-2: Lighting Controls

Two types of controls were evaluated under this ECO: daylight sensors and occupancy sensors. For daylight sensors, the objective was to reduce the hours required for operating the lighting systems while maintaining required light levels. The use of these sensors was evaluated in hangar bays at the Airfield which receive significant daylighting through highbay doors for at least six months throughout the year. The daylight sensors work through on/off photocell control. Based on the light readings obtained during the field survey, a quantity of fixtures were identified that could be controlled by photocells. If a photocell indicates that the recommended light level is being achieved by the use of daylight, the light fixtures controlled by the photocell will turn off automatically. The sensor has a footcandle range of 50 to 300 footcandles, which is adjustable. The sensor will be set by the user at the desired footcandle reading. When the light level reaches the set footcandle level (due to daylight) and remains there for 15 minutes, the fixtures controlled by that sensor will turn off automatically. When the light level decreases to approximately 15% less than this setting and remains there for 15 minutes, the fixtures will be turned on. The time delay is built in to prevent


### FORM 2.3.1.1

<b>SIMPLIFIED LIGHTING DESIGN CALCULATION</b>									
<b>2 X 4 SPECIFIED FLUORESCENT FIXTURES : T-12, 34 W LAMP/MAGNETIC BALLAST</b>									
Lumens Output Per Luminaire		Input Voltage Per Luminaire		Mounting PC =  [read output from chart & CU = IFL = 1.0]		Light Loss Factor (LLF) = 0.75			
						Light Loss Factor (LLF) = 0.75 Condition based on lamp spec. NGR 1.0 From surface reflectance: 80 to 20			
Dimensions and Energy Consumption									
Fixture Spacing Centimeters or Lengths	APPL. Intensity SI	1-Lamp		2-Lamps		3-Lamps		4-Lamps	
		FC	Watts/W	FC	Watts/W	FC	Watts/W	FC	Watts/W
4x4	48	24	0.05	48	1.71	7.3	2.59	32	3.42
6x6	64	16	0.04	37	1.26	5.5	1.92	72	2.56
8x8	80	15	0.05	29	1.03	4.4	1.54	59	2.05
10x10	96	12	0.04	24	0.85	3.7	1.28	49	1.71
12x12	120	10	0.04	20	0.69	2.9	1.03	39	1.37
14x14	144	8	0.05	18	0.57	2.4	0.95	33	1.14
16x16	168	7	0.04	14	0.49	2.1	0.73	28	0.98
18x18	168	7	0.04	14	0.49	2.1	0.73	28	0.98
(Based on room geometry and fixture spacing indicated in chart)									
NGR 2 : 0.75 LLF, NGR 3 : 0.75 LLF, NGR 4 : 0.75 LLF, NGR 5 : 0.75 LLF, NGR 6 : 0.75 LLF, NGR 7 : 0.75 LLF, NGR 8 : 0.75 LLF, NGR 9 : 0.75 LLF, NGR 10 : 0.75 LLF									
NGR =	G = Total or Average • Watts		Watts/W = watts/lux • watts per fixture to work plane						
Mounting factor for fixtures = 1.2									
Average Standard Output = 1.2 multiplied by fixture output = 0.95 (based on fixture output)									
NGR = 0.75 x 0.95 = 0.715 = 0.75 (based on fixture output)									
Total Illuminance = 32 x 0.715 = 45 lux									
Lux Value (Plates lighting) = 45 lux									
Mounting Factor = 0.65 (for NGR 2 - 9.5)									
Average Standard Output = 72 lux									

Page 2-1

**FORM 2.3.1.1 SIMPLIFIED LIGHTING DESIGN DATA**

2x4 recessed, 1:12 slope, magnetic ballast



### **FORM 2.3.1.1**

SAMPLE LIGHTING DESIGN CALCULATION


卷之三

**FORM 2.3.1.1 SIMPLIFIED LIGHTING DESIGN DATA**

2x4 Acoustec 14 2W/Lamps, Double Rows

Based on Lamp Specs (PCB 19)  
Location Factor = 0.7, Room Surface Albedo = 0.55, 30

Average Horizontal Distance from Center of Lamp



## 2 METHODS AND APPROACH

FY94 EECAP Lighting Transition, Ft. Campbell, KY

the fixtures from turning off and on too frequently. Information on recommended buildings to utilize these sensors is found in Section 4, including a sketch of the building's bay floor plan indicating fixtures and proposed locations for photocell sensors.

For occupancy sensors, the ECO objective was to save energy by turning off lights when designated areas are unoccupied. These were evaluated for use in Blanchfield Hospital, Building C. Occupancy sensors will be installed to replace the wall switches to shut lights off automatically during day and evening hours in exam rooms and staff offices.

### 2.4 ECO LIFE CYCLE COSTS

The life cycle cost analyses for the ECOs are a combination of energy costs, investment costs, maintenance costs, and replacement costs. Each of these components may, or may not, be significant factors in determining the life cycle cost of the project. Each of these cost components has been evaluated for each ECO calculated in order to determine the contribution, if any, to the life cycle cost of the project.

The life cycle costs were calculated using the computer program Life Cycle Costing in Design (LCCD) as required in the Scope of Work.

#### 2.4.1 Energy Costs - Electricity

Energy costs for each type of fuel used in the facilities included in the Scope of Work were obtained from the installation and through the Defense Energy Information System (DEIS). The costs were obtained along with the amount of energy used for FY93. Average energy costs per unit of electricity were calculated. Electricity is the only source of energy related to the study.

The electric energy consumption, demand and costs for FY93 are shown in Table 2.4.1 ! Fort Campbell Electric. Figure 2.4.1.1 is a bar graph of the monthly consumption and cost. The electric cost to calculate the electric cost savings for this project are as follows:

$$\begin{aligned} \text{COST/kWh} &= \$0.02114/\text{kWh} && (\text{No demand}) \\ \text{COST/MWh} &= \$6.114/\text{MWh} && (\text{No demand}) \\ \text{COST/kW} &= \$11.78/\text{kW} && (\text{Monthly demand}) \end{aligned}$$

#### 2.4.2 Maintenance and Replacement Costs


The maintenance and operating cost savings for each ECO were calculated, where applicable. First considered was whether or not the annual recurring (maintenance and operations) non-energy costs

**Table 2.4.1.1**  
**Fort Campbell Electric**  
**FY93**

Month	Demand (kW)	Consumption (kWh)	Total Cost	Cost/kWh
Oct '92	31,072	16,077,600	\$739,346	\$0.046
Nov	34,020	17,287,200	\$800,806	\$0.046
Dec	33,807	16,320,400	\$821,704	\$0.045
Jan '93	35,361	19,307,400	\$880,867	\$0.046
Feb	36,140	17,644,200	\$857,977	\$0.049
Mar	34,844	17,804,000	\$811,111	\$0.046
Apr	34,863	15,691,200	\$780,282	\$0.048
May	43,897	19,429,600	\$926,917	\$0.050
Jun	47,212	23,872,800	\$1,081,048	\$0.045
Jul	50,000	25,800,800	\$1,180,394	\$0.045
Aug	49,556	25,228,400	\$1,141,714	\$0.045
Sep	43,281	17,488,800	\$802,283	\$0.052
<b>TOTAL</b>	<b>474,892</b>	<b>232,957,200</b>	<b>\$10,864,239</b>	<b>\$0.047</b>
Min	31,072	15,691,200	\$739,346	\$0.045
Max	50,000	25,800,800	\$1,160,394	\$0.052
Avg	39,574	19,413,100	\$905,353	\$0.047

*Figure 2.4.1.1*

## Fort Campbell Electric FY93



## 2 METHODS AND APPROACH

### 1994 EEAP LIGHTING ENERGY STUDY, Ft. CAMPBELL, KY

would significantly change as a result of each ECO. These values are sometimes unjustifiably manipulated to produce the desired results for the project economic analysis. Therefore, it was typically assumed maintenance and operational activities will continue at the same rate as before the project. However, readily identifiable differences, such as increased lamp life for fluorescent lamps as compared to incandescent lamps, have been included. The estimated costs were obtained from the Means Facilities Costs Data, 1994. Other sources included local service companies and Systems Corp developed data.

The replacement costs (non-energy non-annual recurring costs) for each ECO have been evaluated in the same manner as non-energy annual recurring costs. The same sources for cost data were used for estimating these costs also. Some examples of these types of cost items are as follows:

- = lamp replacements
- = replacing ballasts

It is the policy of Systems Corp to be conservative when estimating these more subjective cost components—which, if improperly evaluated, could result in inappropriate project qualification and funding decisions.

Table 2.4.2.1 shows the maintenance and replacements costs used in the analysis for the different fixture types. At the bottom of this table, the method used to calculate the maintenance savings/cost is illustrated. The calculations for all maintenance savings are included in Section 10 of this report. The maintenance savings are shown only for the buildings included in the final report, not for buildings which were eliminated from the projects due to poor economics. To be more conservative in this evaluation, no maintenance savings were calculated for ECO-2, Lighting Controls. Part of the calculations were performed manually, while part were performed using a computerized spreadsheet. The spreadsheet calculations are for the barracks, which had only two types of fixtures. The Airfield had multiple fixture types, so the spreadsheet calculations were not practical.

**TABLE 2.4.2.1**  
**MAINTENANCE AND REPLACEMENT COSTS**

PRODUCT DESCRIPTION	PRODUCT LIFE (HRS)	MATERIAL & LABOR COSTS
INCANDESCENT < 100 WATTS	750	\$3.50
INCANDESCENT 100-300 WATTS	750	\$5.25
INCANDESCENT > 300 WATTS	1,000	\$26.00
QUARTZ - 200 WATTS	2,000	\$32.50
4 FT FLUORESCENT TUBE	20,000	\$5.00
FLUORESCENT EXIT SIGN	20,000	\$6.00
COMPACT FLUORESCENT	20,000	\$18.00
MERCURY VAPOR - 250 WATTS	12,000	\$50.00
MERCURY VAPOR - 400 WATTS	18,000	\$50.00
MERCURY VAPOR - 1000 WATTS	24,000	\$70.00
METAL HALIDE - 250 WATTS	10,000	\$41.00
METAL HALIDE - 400 WATTS	20,000	\$47.00
HIGH PRESSURE SODIUM - 50 WATTS	24,000	\$28.00
HIGH PRESSURE SODIUM - 150 WATTS	24,000	\$38.00

SAMPLE CALCULATION

EXISTING MAINTENANCE COSTS  
 $\# \text{ OF LAMPS} \times \text{HRS OF OPERATION/YEAR} \times (1/\text{LAMP LIFE}) \times \text{MATERIAL & LAB COSTS}$

PROPOSED MAINTENANCE COSTS  
 $\# \text{ OF LAMPS} \times \text{HRS OF OPERATION/YEAR} \times (1/\text{LAMP LIFE}) \times \text{MATERIAL & LAB COSTS}$

MAINTENANCE SAVINGS = EXISTING MAINTENANCE COSTS - PROPOSED MAINTENANCE COSTS

FOR EACH OPTION (EXISTING OR PROPOSED) CALCULATE MAINTENANCE COST FOR EACH LAMP TYPE PRESENT WITHIN BUILDING. REPLACEMENT MAY HAVE SAME MAINTENANCE AS EXISTING (EXAMPLE: T12 FLUOR REplaced WITH T8 FLUOR WITH SAME NUMBER OF LAMPS).

### 3 PROJECT I: INTERIOR/EXTERIOR LIGHTING AT AIRFIELD

FY94 EEAP LIGHTING ENERGY STUDY, FT. CAMPBELL, KY

This section contains the Project Development Brochures and the DD 1391 Forms for Project I: Interior/Exterior Lighting at Airfield. Following the DD 1391 Forms is a project summary table, the life cycle cost analysis for the project, and the calculations and cost estimates for each building included in the report. Below is a detailed index of the information included in this section. Listed beside each building number are the high efficiency lighting replacements utilized in that building.

PIIBs .....	3-2
DD1391 Forms .....	3-18
Table 3.1: Project Summary - Interior/Exterior Lighting at Airfield .....	3-26
Project LCCA .....	3-27
<b>Bldg. Replacement Utilized</b>	<b>Page</b>
7103 T8 Fluor. HPS Exterior .....	3-28
7110 T8 Fluor. CF, LED Exit .....	3-36
7112 T8 Fluor. CF, LED Exit .....	3-44
7118 T8 Fluor. CF, LED Exit .....	3-52
7120 T8 Fluor. CF, LED Exit .....	3-60
7131 T8 Fluor. T8 Fluor with refl. CF .....	3-68
7133 T8 Fluor. T8 Fluor with refl. CF .....	3-75
7149 T8 Fluor. with Refl. CF. LED Exit .....	3-82
7154 T8 Fluor. (3-200W Incan to 1 2-lamp Fluor). CF .....	3-90
7155 T8 Fluor. with Refl. CF .....	3-98
7156 T8 Fluor. (3-200W Incan to 1 2-lamp Fluor). CF .....	3-105
7159 T8 Fluor. with refl. CF .....	3-113
7160 T8 Fluor. CF. HPS (200 W Incan to 50W HPS) .....	3-120
7164 T8 Fluor. with Refl. CF. LED Exit .....	3-129
7165 T8 Fluor. ....	3-137
7170 T8 Fluor. T8 Fluor with Refl. CF. LED Exit .....	3-143
7176 T8 Fluor. LED Exit. HPS .....	3-151
7179 T8 Fluor. with Refl. CF. LED Exit .....	3-159
7206 T8 Fluor. LED Exit. MH .....	3-167
7208 T8 Fluor. (405W Incan to 1 2-lamp Fluor). CF. MH .....	3-175
7210 T8 Fluor. CF. LED Exit. MH. HPS Exterior .....	3-183
7212 T8 Fluor. CF .....	3-194
7214 T8 Fluor. (405W Incan to 1 2-lamp Fluor). CF. LED Exit. MH .....	3-201
7218 T8 Fluor. (405W Incan to 1 2-lamp Fluor). CF. LED Exit. MH .....	3-211
7243 T8 Fluor. LED Exit. MH. HPS Exterior .....	3-221
7245 T8 Fluor. (750W Incan to 1 2-lamp Fluor). LED Exit. MH .....	3-230
7249 T8 Fluor. (750W Incan to 1 2-lamp Fluor). LED Exit. MH .....	3-239
7281 T8 Fluor. with Refl. LED Exit .....	3-248
Calculator Calc Sheets .....	3-255

**Note:**

T8 Fluor = T8 fluorescent fixture with electronic ballasts.

With Refl = above fixture with reflector used to reduce waste.

CF = Compact Florescent

LED Exit = exit sign replacement by abandonment of fluorescent exit sign

HPS = High Pressure Sodium fixture

MH = Metal halide

INC = Incandescence

For a more detailed description of existing fixtures and replacements, please refer to the calculation sheets for each building in this section.

# **facility**

INTERIOR LIGHTING REPLACEMENT AT ARMY AIRFIELD  
Fort Campbell, Kentucky

## **project coordinator for using service**

Arlin Wright

**functional requirements summary, PDB-1**

3-2

DA FORM 6020-1A, Feb 82

TM E-300-3 A-7

**OBJECTIVE:**


The objective of this project is to replace existing interior and exterior lighting with high efficiency fixtures and lamps at Campbell Army Airfield. The replacement of the existing lighting will reduce energy consumption and life cycle operating costs for the Airfield in accordance with the Army Energy Resources Management Plan (ERMP) and Executive Order 12759.

**functional requirements summary, PDB-1**

3-3

DA FORM 6020-2-R, Feb 82

TM 5-800-3 A-9



facilities requirements sketch, PDB- 1/2

3-4

DA FORM 5022-R, Feb 82

TM 5-800-3 A-21

TM 8-900-3

**APPENDIX C  
DOCUMENTATION CHECKLIST**

C-1  
J-5

### A. SPECIAL CONSIDERATIONS

ITEM											
A-1	Cost estimates for each primary and supporting facility										
A-2	Telecommunications system coordination with USACE and authorization for exceptions										
A-3	Coordination with state and local governments requirements during conduct, modified, facilities construction and operating permits, expropriation, etc.										
A-4	Assignment of commander										
A-5	Economic analysis of alternatives										
A-6	Approval for new states										
A-7	International defense of movements (ISDPI) coordination with U.S. Supreme command and NATO-commanded coalition and commandoes (include rate of exchange used in estimation)										
A-8	Impact of historic places on site survey. By authorized archaeologist and coordination with State Historic preservation officer and authority caused by historic preservation										
A-9	Exceptions to established criteria										
A-10	Coordination with various "SO" agencies (Project Manager, Contracting Officer, etc.)										
A-11	Identification of related or similar projects for review for incorporation										
A-12	Required completion date										
	Other Special Considerations (list one quarter items)										

1. See Appendix A

TYPE OF SPECIAL CONSIDERATION	R	C	T	D	U	Q	S	T	P	U	Q
	R	C	—	—	—	—	—	—	—	—	—
	NR										
	R	A									
	NR										
	R	D									
	NR										
	NR										
	NR										
	NR										
	NR										
	R										
	NR										
	R										
	R										
	R										
	R										

REQUIRED OR NOT REQUIRED - Not required or no information to determine. Enter "R" if item is relevant and is required for the project. Enter "NR" if item is irrelevant and is not required for the project.

TO BE DETERMINED - Information needed but not currently available. Enter code for information source.

DOCUMENT ATTACHED - Significant information summarized or detailed and attached.

DOCUMENT ATTACHED - Significant information is in another document which is referred to.

REGIONS IN WHICH AND MODE APPROXIMATELY

- A = DPAE
- B = Using Services
- C = Construction Services
- D = Damage
- E = Other (Local Commandos, Attorneys and Agents)

### documentation checklist

DA FORM 5C23-A-R, Feb 82

3-6

TM 3-800-3 C-8

## B. SITE DEVELOPMENT

ITEM		1	2	3	4
6-1	Communication with the District Office to determine and evaluate mine plan hazards				
6-2	Preparation, submission, and/or approval of mine plan				
6-2-1	General Site Plan				
6-2-2	Annotated General Site Plan				
6-2-3	Master Site Plan				
6-2-4	Facilities Requirements Section				
6-3	Preparation of:				
6-3-1	Site Survey				
6-3-2	Superal Information				
6-4	Approval by Department of Defense Economic Safety Board (DDESB) for Safety Site Plan				
	Other Site Development & Considerations (list one number item)				
	1. See Project Development Structure, PDS-1/2				

REQUIRED OR NOT REQUIRED - Not required or no information to determine. Enter "R" if item is relevant and is required for the project. Enter "NR" if item is relevant and is not required for the project.

TO BE DETERMINED - Information needed but not currently available. Enter code for information to be determined.

COMMENT ATTACHED - Significant information or summaries of evidence and findings.

DOCUMENT ATTACHED - Significant information or supporting data regarding a question.

CODE NUMBER (Check one column appropriate)

- A = Roads
- B = Utility Services
- C = Construction Services
- D = Design
- E = Other (Enter comments attached and original)

## documentation checklist

3-7

### C. ARCHITECTURAL & STRUCTURAL

ITEM		T E S T I C E R E Q U I R E	P R O J E C T I D E A C T I V E	C O N S U L T A T I V E	I N S P E C I F I C A T I V E
C-1	Registration with AFSC Housing Program and requirements	NR			1
C-2	Evaluation of existing facilities and degree of utilization	R			
C-3	Approval for removal and relocation of existing storage facilities	NR			
C-4	Evaluation of off-base community facilities	NR			
C-5	Storage and maintenance facilities (including aircraft hangars)	NR			
C-6	Coordination (hangar, medical and general facilities) with Surgeon General	NR			
C-7	Coordination of aviation facilities with USAAC	NR			
C-8	Coordination on traffic control and navigation aids with USAAC	NR			
C-9	Identification of types and numbers of aircraft	NR			
C-10	Evaluation of laboratory, research and development and technical maintenance facilities	NR			
C-11	Coordination (hangar with Chief of Engineers)	NR			
C-12	Review final source location by USATSA	NR			
C-13	Automated data processing system or equipment requirement provided when ADD specifies communication function not coordinated with related facilities	NR			
C-14	Coordination (hangar) with U.S. Post Service Region Director	NR			
C-15	Laundry and dry cleaning facilities coordination with ASCIBELI	NR			
C-16	Tenant facilities coordination with installation where site	NR			
C-17	Facilities for or of support to operations, basic command, or communication function by DBESB (see also Item E-6)	NR			
C-18	Analysis of deficiencies	R	0	1	
C-19	Consideration of alternatives	R	0	2	
C-20	Determination whether occupants will include Department members or selected persons	NR			
C-21	As-built drawings for alterations or additions	R	C		
C-22	Availability of Standard Design or standardizable designs	NR			
Other Architectural & Structural (List and number items)					
1. See Supplemental Data Detailed Project Justification Paragraphs D3.					
2. See Supplemental Data Detailed Project Justification Paragraph D4.					

REQUISITE IS NOT REQUIRED - Not relevant or no information is required. Grade "R" is item is relevant and is required for this project. Grade "NR" is item is irrelevant and is not required for this project.

REQUISITE PROVIDED - Information needed but not currently provided. Refer back to Information Source.

COMPLETLY ATTACHED - Significant information summarized or detailed and extensive.

DOCUMENT ATTACHED - Significant information on a separate sheet.

NOTIFICATION AND APPROVAL LETTER

- A = DIAIR
- B = USAF - AFSC
- C = COMUSAF - DIAIR
- D = Director
- E = Other (check Comusaf Director and AFSC)

## documentation checklist

3-3

### D. MECHANICAL, ELECTRICAL & UTILITY SYSTEMS

	ITEM
D-1	Build configurations and early construction progress
D-2	Energy requirements assessment (ERAA)
D-3	Conformance with DOD Energy Reduction Requirements
D-4	Evaluation of existing and/or proposed utility options
	Other Mechanical and Utility Systems (List and number items.)
	1. See Special Requirements, Paragraph 3 (SRP-3)

ITEM	REQUIRING INFORMATION	ITEMS DOCUMENTED	ITEMS ATTACHED	ITEMS COMMENTED
		R	D	
		R	D	1
		R	D	
		R	D	

REQUIRED OR NOT REQUIRED = INDICATES IF INFORMATION IS REQUIRED. Entry "R" if item is required and is required for this project. Entry "NR" if item is discussed but is not required for this project.

TO BE DETERMINED = INFORMATION UNKNOWN BUT NOT CURRENTLY UNKNOWN. INDICATE FOR INFORMATION SOURCE.

COMMENT ATTACHED = SIGNIFICANT INFORMATION DOCUMENTED OR DESIGNATED FOR SOURCE.

DOCUMENT ATTACHED = SIGNIFICANT INFORMATION IS IN AN ATTACHED DOCUMENT.

"O" = OTHER UNCLASSIFIED AND MOST APPROPRIATE LETTER:

A = AFAC  
 B = Utility Services  
 C = Construction Services  
 D = Design  
 E = Other (Space Comment Attached and continue)

## documentation checklist

3-2

DA FORM 5023-D-R, Feb 82

TM 1-100-3 6-11

## E. ENVIRONMENTAL CONSIDERATIONS

EIA	
E-1	Environmental Impact Assessment:
E-2	EIA conclusions reflect Environmental Impact Statement.
E-3	Determination of health characteristics of existing hazards. Assistance to determine existence of any health environmental or toxicologic hazard may be requested from Aeromedical Proving Grounds MAC 21010 or the Office of the Surgeon General, AFM 2020 USAF Army Environmental Hygiene Agency.
E-4	Air/water pollution control coordination with appropriate components with standards at federal, state and local levels.
E-5	Corrective measures associated with Environmental Impact Statement or Assessment - to accompany any package.
Other environmental considerations below and number items:	
1. See Supplemental Data Detailed Project justification Paragraph D5.	

	E	N	T	C
E				
N				
T				
C				

REQUIRED OR NOT REQUIRED = NOT REQUIRED OR NO INFORMATION OR IS UNKNOWN.  
 Required Entry "R" is from a request and is required for the project.  
 Entry "NR" is not required and is not required for the project.  
 TO BE DETERMINED = Information needed but not currently available  
 Information to be determined later.  
 COMMENT ATTACHED = Significant information commented by designer and attached  
 DOCUMENT ATTACHED = Significant information is in an attached document  
 FORM 5010-1012-0002

BY WHOM, DATE AND APPROVAL NUMBER  
 A = SP&E  
 B = Flying Service  
 C = Construction Service  
 D = Designer  
 E = Other, Enter Command Attaching and  
 Designate

## documentation checklist

3-10

DA FORM 5010-1012-0002, Feb 82

TM 5-800-3 C-13

**APPENDIX D**  
**TECHNICAL DATA CHECKLIST**

**0-1**  
**J-11**

### A. SPECIAL CONSIDERATIONS

SEN

- A-1 Function of the institution or unusual characteristics peculiar to the place being considered  
ORIGINATOR
- A-2 Construction drawings requirements
- A-3 Functional support equipment (mechanical, electrical, structures, and special) to be built in
- A-4 Equipment in place and utilization
- A-5 Other equipment and furniture (DGA & DPA) and costs
- A-6 System studies and tests (including analytical, combat, battle testing, new technology testing, etc.)
- A-7 Type of construction (permanent, temporary, semi-permanent)
- A-8 Government furnished equipment (availability, procurement time availability, one source, funding and storage requirements, funds used for procurement)

Other special considerations and their cost number items

1	2	3	4	5
SF				
PF	2			
SP				
NP				
NP				
NP				
VC				

REQUIRED OR NOT REQUIRED - Not required or no information is com  
municated from "P" if item is relevant and is required for this project.  
Item "P" is relevant and is not required for this project.

TO BE DETERMINED - Information needed but not a specific location  
Item code for information to be

COMMENT ATTACHED - Significant interpretation summarized or explained  
in comments

DOCUMENT ATTACHED - Detailed information is in or attached to  
item number or figure

\* P = PROPOSED AND NOT REQUIRED

- A = DPA
- B = Using Service
- C = Construction Service
- D = Design
- E = Other (Cross Commodity Number and  
code or)

### technical data checklist

3-12

DA FORM 5024-A.R., FEB 82

TAB 3-501(6-3) 5-8

## B. SITE DEVELOPMENT

\*IV

		R	A	NR	C	S	T	P	U
8-1	Construction restrictions or guidelines pertaining to site access and preferred construction routes		R	A					
(A)	Airfield clearance, restrictive steerer, operating hours, safety, etc.	NR							
(C)	Facilities and/or functions of adjoining areas (structures, materials, impact)		R	A					
8-2	Real estate actions (acquisition, disposal, lease, right-of-way)	NR							
8-3	Demolition/relocation required (lease)								
(A)	Special considerations due to explosives/radioactivity, chemicals, contamination/asbestos emissions/toxic gases								
(B)	Restrictions on disposal of demolished/relocated material including hazardous waste			NR					
8-4	Pavement types and requirements (including traffic surveys and NTM/C coordination)	NR							
8-5	Landscaping considerations								
(A)	Protection of existing vegetation	R	A						
(B)	Stockpile topsoil	NR							
	Other Site Development (List and number items)								
	1. There is a possibility that the existing lighting may contain PCB's in the ballasts.								

REQUIRED OR NOT REQUIRED - Enter "R" if item or information is required. Enter "NR" if item or information is not required for the project.

TO BE DETERMINED - Information needed but not currently available from DOD or information source.

COMMENT ATTACHED - Significant information summarized or explained in attached.

DOCUMENT ATTACHED - Significant information is in an enclosed document.

\*BY WHICH CHECKS AND WHAT EQUIPMENT USED

- A = DPAE
- B = Using Service
- C = Construction Service
- D = Designer
- E = Other (Check Comments Attached and Explain)

## technical data checklist

3-13

DA FORM 5024-B.R, Feb 82

TM 3-840-3 0-7

### C. ARCHITECTURAL & STRUCTURAL

#### ITEM

C-1	Vibration-producing equipment requiring isolation
C-2	Seismic zone and other design loads criteria (typhoon, hurricane, earthbound waves, high or low ion potential)
C-3	Protective shelter evaluation and resistant design criteria (environmental/nuclear threat and radiation, chemical/biological)
C-4	Unusual transmission requirements (heat, dust, carbon, noise transmission, fire, special insulation, permeable steel, coil bearing)
C-5	Designation and strength of units to be decommissioned
C-6	Requirements and data for seismic design analysis
C-7	Unusual floor and roof loads (load assignment)
C-8	Security features (area regime, vaults, interior secure areas)
	Other Architectural & Structural (list one number items)

P R E P A R A T I O N S	S U B S T A C H E W O R K	T E S T I G S	I M P L E M E N T
C	D		
NR			
NP			
NZ			

REQUIRED OR NOT REQUIRED = Enter relevant or no information to communicate. Enter "R" if item is relevant and is required for this project. Enter "NR" if item is relevant and is not required for this project.

TO BE DETERMINED = Information needed but not currently available. Enter code for information source.

COMME DT ATTACHE = Significant information summarized or attached in separate

DOCUMENT ATTACHE = Significant information is in or enclosed under same header or signature

NOT WORKING AND INSERT INDEFINITE LETTER!

- A = DFAS
- B = Using Service
- C = Construction Services
- D = Design
- E = Other (Enter Comments Attached and Enclosed)

## technical data checklist

DA FORM 5024-C-R, Feb 62

3-14

TDS 5-800-3 D-9

### D. MECHANICAL, ELECTRICAL, & UTILITY SYSTEMS

ITEM	
D-1	Special mechanical requirements (e.g. configurations required, crane, pump, etc.)
D-2	Special heat usage periods and peak cooling load (if any)
D-3	Maintenance considerations (e.g. accessibility of equipment, compatibility with existing equipment)
D-4	Plumbing—availability, general system type and characteristics (existing and/or existing, incl. compressed air and gas)
D-5	Heating—availability, general system type and characteristics (existing and/or existing)
D-6	Ventilating, air conditioning/refrigeration—availability, general system type and characteristics (existing and/or existing)
D-7	Electrical—availability, power system type and characteristics incl. building lighting, communication, etc. (existing and/or existing)
D-8	Water supply/waste treatment—availability, general system type and characteristics (existing and/or existing)
D-9	Energy requirement (fuel conversion factors, projections), loads, types of fuel etc.
D-10	Solar energy evaluation
Other Mechanical & Utility Systems (List one number item)	

TYPE CODE	• C E G H I J L M N P S T U V W X Y Z	• C E G H I J L M N P S T U V W X Y Z	• C E G H I J L M N P S T U V W X Y Z	• C E G H I J L M N P S T U V W X Y Z
NR				
NR				
R	D			
NR	D			
NR				
NR				
R	D			
NR				
NR				
R	D			
NR				
NR				

REQUIRED OR NOT REQUIRED = Not relevant or no information to determine. Enter "R" if item is relevant and is required for the project. Enter "NR" if item is irrelevant and is not required for the project.

TO BE DETERMINED = Information needed but not currently available. Enter code for information source.

COMMENT ATTACHED = Significant information summarized or detailed and attached.

DOCUMENT ATTACHED = Significant information e.g. on plans or other documents attached.

\* BY WHOM ISSUED AND WHAT APPROVING OFFICER

- A = DPAE
- B = Using Service
- C = Construction Service
- D = Designer
- E = Other (Check Commodity Address and Section)

## technical data checklist

3-15

DA FORM 5020-1, 1 Feb 82

TM 3-500-3 0-11

## F. FIRE PROTECTION

ITEM	
P-1	Special fire protection systems or features (detection and suppression equipment, firewalls, etc.) Other Fire Protection Configurations (List and number items)

Required or not required	To be determined	Comment attached	Document attached
NR			

REQUIRED OR NOT REQUIRED = Not relevant or no information to communicate. Enter "R" if none is relevant and is required for the DODNET. Enter "NR" if item is relevant and is not required for the project.

TO BE DETERMINED = Information needed but not currently available. Enter code for information source.

COMMENT ATTACHED = Significant information summarized or explained and attached.

DOCUMENT ATTACHED = Significant information is in an existing document which is attached.

TYPE WHOLE LETTER AND INSERT APPROPRIATE LETTER

- A - DOD
- B - Using Services
- C - Construction Services
- D - Designer
- E - Other (Check Comments & Reasons and explain)

## technical data checklist

3-16

DA FORM 5026-F-R, Feb 82

TM 5-800-3 D-15

1. COMPONENT ARMY	FY 18 <u>84</u> MILITARY CONSTRUCTION PROJECT DATA			2 DATE 23 September 34
3. INSTALLATION AND LOCATION Fort Campbell, Kentucky		4. PROJECT TITLE Interior/Exterior Lighting Replacement at Army Airfield		
5. PROGRAM ELEMENT	6. CATEGORY CODE	7. PROJECT NUMBER ECIP #1	8. PROJECT COST (S000) 3,770.00	
9. COST ESTIMATES				
ITEM	U/M	QUANTITY	UNIT COST (S000)	COST (S000)
Primary Facility				
Interior and Exterior Light Fixtures	Lo:	1	811.70	811.70
Subtotal				811.70
Contingency (10%)				81.20
Total Contract Cost				872.90
Supervision, Inspection and Overhead (3.5%)				31.00
Total Request				730.90

#### 10. DESCRIPTION OF PROPOSED CONSTRUCTION

The existing interior/exterior lighting is a combination of standard efficiency fluorescent, incandescent, and mercury vapor fixtures. The proposed project will replace the interior and exterior lighting fixtures with T-8 fluorescents with high efficiency electronic ballasts, compact fluorescents, LED exit signs, high pressure sodium fixtures, and metal halide fixtures. The implementation of this project will save 6,890,307 MJ/yr of electrical energy. The first year savings is \$130,856 and the Savings to Investment Ratio (SIR) is 2.21.

#### 11. REQUIREMENT

**Project:** The proposed interior and exterior lighting project replaces lighting at Campbell Army Airfield in the following buildings with energy efficient lighting: 7109, 7110, 7112, 7118, 7120, 7131, 7133, 7149, 7154, 7155, 7156, 7159, 7160, 7164, 7165, 7170, 7176, 7179, 7206, 7208, 7210, 7212, 7214, 7218, 7243, 7245, 7249, and 7251.

**Requirement:** The project is required to reduce the energy consumption of lighting and to comply with the Army Energy Resources Management Plan (ERMP) and Executive Order 12759. The proposed project will reduce annual energy consumption by 6,890,307 MJ/yr and annual energy cost by \$130,856..

**Current Situation:** The existing lighting at Campbell Army Airfield in the above listed buildings is inefficient fluorescent, incandescent, mercury vapor fixtures.

1 COMPONENT <b>ARMY</b>	2 DATE <b>23 September 94</b>
3 INSTALLATION AND LOCATION <b>Fort Campbell, Kentucky</b>	
4 PROJECT TITLE <b>INTERIOR/EXTERIOR LIGHTING REPLACEMENT AT ARMY AIRFIELD</b>	5 PROJECT NUMBER <b>ECIP #1</b>

Impact if not provided: If the proposed project is not funded, a reduction of 6,880,307 MJ/yr cannot be achieved, and excessive amounts of energy will continue to be used. There will be no contribution to energy reduction goals established for United States Army facilities by Army Headquarters.

Colonel, USA  
Commanding

ESTIMATED CONSTRUCTION START:	September 1995	INDEX:
ESTIMATED MIDPOINT OF CONSTRUCTION:	April 1996	INDEX:
ESTIMATED CONSTRUCTION COMPLETION:	November 1996	INDEX:

#### DETAILED JUSTIFICATIONS

##### D1. GENERAL

The proposed project encompasses the replacement of lighting at Campbell Army Airfield in 28 buildings. The project will decrease the energy consumption of the lighting system without reducing light levels except where necessary.

##### D2. ACCOMMODATIONS NOW IN USE:

The existing lighting systems are comprised of standard efficiency fluorescent, incandescent, and mercury vapor fixtures.

##### D3. ANALYSIS OF DEFICIENCY:

Currently, Campbell Army Airfield buildings 7109, 7110, 7112, 7118, 7120, 7131, 7133, 7149, 7154, 7155, 7156, 7159, 7160, 7164, 7165, 7170, 7178, 7179, 7208, 7210, 7212, 7214, 7218, 7243, 7245, 7249, and 7261 are using standard or low efficiency fixtures for lighting. The purpose of this project is to replace the existing lighting with new light fixtures which are much more efficient. The current deficiency results in large amounts of energy usage to maintain adequate lighting.

1 COMPONENT ARMY	2 DATE 23 September 94
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky	
4 PROJECT TITLE INTERIOR/EXTERIOR LIGHTING REPLACEMENT AT ARMY AIRFIELD	5 PROJECT NUMBER ECIP #1
<p><b>D4. CONSIDERATION OF ALTERNATIVES:</b></p> <p>The only alternatives to proposed project are to install lower efficiency light fixtures. The disadvantages of using lower efficiency light fixtures is that less energy savings can be realized without significantly reducing the construction cost. If a less efficient light fixture is selected, the project would have a lower SIR.</p> <p><b>D5. CRITERIA FOR PROPOSED PROJECT:</b></p> <p>The proposed project will conform with all applicable federal and United States Army Regulations.</p> <p><b>D6. PROGRAM FOR RELATED EQUIPMENT:</b></p> <p>No equipment funded from appropriations other than MCA are required.</p> <p><b>D7. DISPOSAL OF PRESENT ASSETS:</b></p> <p>Light fixtures in the 28 buildings at Campbell Army Airfield will be disposed.</p> <p><b>D8. SURVIVAL FACILITIES:</b></p> <p>The proposed project is not suitable for inclusion of protective shelters.</p> <p><b>D9. SUMMARY OF ENVIRONMENTAL CONSEQUENCES:</b></p> <p>The proposed project has been analyzed and will not adversely impact the environment. Energy savings resulting from the project will conserve natural resources.</p> <p><b>D10. EVALUATION OF FLOOD HAZARDS AND ENROACHMENT ON WETLANDS:</b></p> <p>It has been determined that these facilities are not located in a flood plain and they do not encroach on wetlands.</p> <p><b>D11. ECONOMIC JUSTIFICATION:</b></p> <p>The proposed project qualifies under ECIP Guidelines in AR-415-15. SIR for the project is 2.21 with a simple payback of 5.43 years. See Economic Analysis, SRP-1</p>	

1. COMPONENT ARMY	2. DATE 23 September 94
3. INSTALLATION AND LOCATION Fort Campbell, Kentucky	
4. PROJECT TITLE INTERIOR-EXTERIOR LIGHTING REPLACEMENT AT ARMY AIRFIELD	5. PROJECT NUMBER ECIP #1

**D12. UTILITY AND COMMUNICATION SUPPORT:**

- A. No related utility support projects are programmed. Adequate utilities are available to support the project.
- B. No telecommunication support is required.

**D13. PROTECTION OF HISTORIC PLACES AND ARCHEOLOGICAL SITES:**

The project involves the replacement of light fixtures in and around existing buildings. Review procedures have been implemented for this project in accordance with 36 CFR 800. The review has established that there will be no effect.

**D14. PROJECT DEVELOPMENT BROCHURE (PART 1):**

A Project Development Brochure was prepared on 23 September 94 and is attached as a part of the programming documentation.

**D15. ENERGY REQUIREMENTS:**

The proposed project will reduce present energy consumption by 6,880,307 MJ/yr at the cost savings of \$130,656 per year. See Energy Requirements Appraisal (ERA) in Special Requirements, Paragraph 3 (SRP-3).

**D16. PROVISION FOR THE HANDICAPPED:**

No provisions for the handicapped will be made since the scope of the project is in no way applicable to designing for the handicapped.

**D17. REAL PROPERTY MAINTENANCE ACTIVITY (RPTMA) ANALYSIS:**

- A. Physical impact: There will be light fixtures removed and replaced by new light fixtures. No new structures will be added.

1. COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA	2. DATE 23 September 94
3. INSTALLATION AND LOCATION Fort Campbell, Kentucky		
4. PROJECT TITLE INTERIOR/EXTERIOR LIGHTING REPLACEMENT AT ARMY AIRFIELD		5. PROJECT NUMBER ECIP #1

B. Operations and Maintenance (O&M) Impact:

YEAR	O&M
	NET CHANGE (\$000)
1994	-7.6
1995	-7.6
1996	-7.6

C. Backlog of Maintenance and Repair (BMAR) Impact:

There will be a reduction in the number of fixtures and an increase in fixture life expectancy. There will be no effect on BMAR.

D18. COMMERCIAL ACTIVITIES:

The proposed project is not a "New Start Expansion" as defined by DA Circular 235-1. The project has been reviewed in light of the requirements of commercial and industrial facilities. It has been determined that whereas the project does not affect commercial facilities, the requirements of DA Circular 235-1 does not apply.

1 COMPONENT: ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA			2 DATE 23 September 94																																																																															
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky																																																																																			
4 PROJECT TITLE INTERIOR/EXTERIOR LIGHTING REPLACEMENT AT ARMY AIRFIELD		5 PROJECT NUMBER ECIP #																																																																																	
<p><b>Life Cycle Cost Analysis</b></p> <p>Project Title: Interior/Exterior Lighting Replacements</p> <p>Fiscal Year: 1994</p> <p>Analysis Date: 09/23/94</p> <p>Economic Life Fifteen (15) Years</p> <p><b>1 INVESTMENT</b></p> <table> <tr> <td>A CONSTRUCTION COST</td> <td>645,364</td> </tr> <tr> <td>B SIOM</td> <td>32,268</td> </tr> <tr> <td>C DESIGN COST</td> <td>32,268</td> </tr> <tr> <td>D ENERGY CREDIT CALC</td> <td>-0-</td> </tr> <tr> <td>E SALVAGE VALUE</td> <td>-0-</td> </tr> <tr> <td>F. TOTAL INVESTMENT</td> <td>\$709,900</td> </tr> </table> <p><b>2. ENERGY SAVINGS</b></p> <p>ANALYSIS DATE ANNUAL SAVINGS, UNIT COST &amp; DISCOUNTED SAVINGS</p> <table> <thead> <tr> <th>FUEL</th> <th>COST \$MILLN (1)</th> <th>SAVINGS M\$YEAR(2)</th> <th>ANNUAL \$ SAVINGS(3)</th> <th>DISCOUNT FACTOR(4)</th> <th>DISCOUNTED SAVINGS(5)</th> </tr> </thead> <tbody> <tr> <td>A ELECT</td> <td>\$ 15</td> <td>6521</td> <td>46,300</td> <td>12.43</td> <td>\$30,920</td> </tr> <tr> <td>B. OIST</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>C. RESID</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>D. NG</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>E. DEMAND</td> <td></td> <td></td> <td>82,741</td> <td>11.85</td> <td>\$90,481</td> </tr> <tr> <td>F. TOTAL</td> <td></td> <td>6521</td> <td>123,041</td> <td></td> <td>1,481,467</td> </tr> </tbody> </table> <p><b>3. NON-ENERGY SAVINGS</b></p> <table> <thead> <tr> <th>ITEM</th> <th>SAVINGS (-1)</th> <th>YEAR OF OCCURRENCE (2)</th> <th>DISCOUNT FACTOR (3)</th> <th>DISCOUNTED SAVINGS (-4)</th> </tr> </thead> <tbody> <tr> <td>A ANNUAL RECURRING (1)(2)DISCOUNT FACTOR (2)(3)DISCOUNTED SAVINGS</td> <td>11.85</td> <td></td> <td></td> <td>\$7818</td> </tr> <tr> <td>B NON-RECURRING SAVINGS</td> <td></td> <td></td> <td></td> <td>\$90,238</td> </tr> <tr> <td>C. Total</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>C. TOTAL NON ENERGY DISCOUNTED SAVINGS (-1)(2)(3)(4)</td> <td></td> <td></td> <td></td> <td>\$0,238</td> </tr> </tbody> </table>					A CONSTRUCTION COST	645,364	B SIOM	32,268	C DESIGN COST	32,268	D ENERGY CREDIT CALC	-0-	E SALVAGE VALUE	-0-	F. TOTAL INVESTMENT	\$709,900	FUEL	COST \$MILLN (1)	SAVINGS M\$YEAR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)	A ELECT	\$ 15	6521	46,300	12.43	\$30,920	B. OIST						C. RESID						D. NG						E. DEMAND			82,741	11.85	\$90,481	F. TOTAL		6521	123,041		1,481,467	ITEM	SAVINGS (-1)	YEAR OF OCCURRENCE (2)	DISCOUNT FACTOR (3)	DISCOUNTED SAVINGS (-4)	A ANNUAL RECURRING (1)(2)DISCOUNT FACTOR (2)(3)DISCOUNTED SAVINGS	11.85			\$7818	B NON-RECURRING SAVINGS				\$90,238	C. Total					C. TOTAL NON ENERGY DISCOUNTED SAVINGS (-1)(2)(3)(4)				\$0,238
A CONSTRUCTION COST	645,364																																																																																		
B SIOM	32,268																																																																																		
C DESIGN COST	32,268																																																																																		
D ENERGY CREDIT CALC	-0-																																																																																		
E SALVAGE VALUE	-0-																																																																																		
F. TOTAL INVESTMENT	\$709,900																																																																																		
FUEL	COST \$MILLN (1)	SAVINGS M\$YEAR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)																																																																														
A ELECT	\$ 15	6521	46,300	12.43	\$30,920																																																																														
B. OIST																																																																																			
C. RESID																																																																																			
D. NG																																																																																			
E. DEMAND			82,741	11.85	\$90,481																																																																														
F. TOTAL		6521	123,041		1,481,467																																																																														
ITEM	SAVINGS (-1)	YEAR OF OCCURRENCE (2)	DISCOUNT FACTOR (3)	DISCOUNTED SAVINGS (-4)																																																																															
A ANNUAL RECURRING (1)(2)DISCOUNT FACTOR (2)(3)DISCOUNTED SAVINGS	11.85			\$7818																																																																															
B NON-RECURRING SAVINGS				\$90,238																																																																															
C. Total																																																																																			
C. TOTAL NON ENERGY DISCOUNTED SAVINGS (-1)(2)(3)(4)				\$0,238																																																																															

1. COMPONENT ARMY	2. DATE 23 September 94
3. INSTALLATION AND LOCATION Fort Campbell, Kentucky	
4. PROJECT TITLE INT'L: EXTERIOR LIGHTING REPLACEMENT AT ARMY AIRFIELD	5. PROJECT NUMBER ECIP #1
SPECIAL REQUIREMENTS PARAGRAPH 1 (SPR-1) (continued)	
6. FIRST YEAR DOLLAR SAVINGS	\$ 130,668
7. SIMPLE PAYBACK	5.43 Years
8. TOTAL NET DISCOUNTED SAVINGS	\$1,517,643
9. DISCOUNTED SAVINGS RATIO	2.21

DD FORM 1331  
1 DEC 71

PREVIOUS EDITIONS MAY BE USED  
UNTIL EXHAUSTED

**FOR OFFICIAL USE ONLY**  
(WHEN DATA IS ENTERED)

1 COMPONENT ARMY	2 DATE 23 September 94	
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky		
4 PROJECT TITLE INTERIOR/EXTERIOR LIGHTING REPLACEMENT AT ARMY HOSPITAL	5 PROJECT NUMBER ECIP #1	
<b>SPECIAL REQUIREMENTS PARAGRAPH 3 (SRP-3):</b>		
<p><b>Energy Requirements Appraisal (ERA)</b></p> <ol style="list-style-type: none"> <li>1. Project Description: Replace existing lighting systems with more efficient lighting systems without reducing the light levels</li> <li>2. Estimated Energy Consumption: The buildings are currently lit by standard efficiency lighting. The existing lighting system consumes 12,892.789 MJ/yr of energy. Replacing the existing lighting with high efficiency lighting will result in 6,880.307 MJ/yr of electrical energy savings, a fifty-three percent (53%) reduction in current energy consumption.</li> <li>3. Energy Sources: No new energy sources are required for the proposed project. The use of solar energy for this project is impractical.</li> <li>4. Energy Use Impacts: The proposed project will substantially reduce the consumption of electricity for lighting. The burden on the existing base distribution system will be lessened.</li> <li>5. Energy Conservation: The proposed project will reduce annual energy consumption by 6,880.307 MJ/yr with annual energy cost savings of \$130,856. The project complies with Army Resources Management Plan (ERMP) and Executive Order 12738.</li> <li>6. Energy Alternatives: The proposed project represents the greatest possible reduction in energy consumption fifty-three percent (53%), without reducing the current lighting levels. The current levels do not exceed the levels recommended by ASHRAE.</li> <li>7. Energy Effects: The proposed project provides positive environmental effects. It reduces the current energy consumption by fifty-three percent (53%), effectively reducing the consumption of non-renewable fuel sources. The degradation of environmental standards would not make more efficient energy sources available.</li> <li>8. Basis of Approval: Total energy requirements and alternative fuel sources have been considered and included in this appraisal or discarded as applicable</li> </ol>		

DD FORM 1391  
1 DEC 94

PREVIOUS EDITIONS MAY BE USED INTERIMLY  
UNTIL EXPIRED  
**FOR OFFICIAL USE ONLY**  
*(WHEN DATA IS ENTERED)*

**TABLE 3.1**  
**PROJECT SUMMARY: INTERIOR/EXTERIOR LIGHTING AT AIRFIELD**

PROJECT SUMMARY: INTERIOR/EXTERIOR LIGHTING AT AIRFIELD		TOTAL COST ESTIMATE	
ITEM	DESCRIPTION	AMOUNT	UNIT PRICE
Labor	Labor costs	\$1,362	\$100/Hr.
General	General costs	\$1,362	\$100/Hr.
Sub Total		\$2,724	
Equipment	Equipment costs	\$1,677	\$100/Hr.
Sub Total		\$1,677	
Material	Material costs	\$2,386	\$100/Hr.
Sub Total		\$2,386	
Supplies	Supplies costs	\$1,362	\$100/Hr.
Sub Total		\$1,362	
Transportation	Transportation costs	\$1,362	\$100/Hr.
Sub Total		\$1,362	
Utilities	Utilities costs	\$1,362	\$100/Hr.
Sub Total		\$1,362	
Permit	Permit fees	\$1,362	\$100/Hr.
Sub Total		\$1,362	
Other	Other costs	\$1,362	\$100/Hr.
Sub Total		\$1,362	
Total		\$10,935	

LIFE CYCLE COST ANALYSIS SUMMARY  
 ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) STUDY: ECO1AAFT  
 INSTALLATION & LOCATION: FORT CANBELL REGION NOS. LCCID 1.080  
 PROJECT NO. & TITLE: ECO1AAFT CENSUS: 3  
 FISCAL YEAR 94 DISCRETE PORTION NAME: INTERIOR LIGHTING AIRFIELD TOTAL  
 ANALYSIS DATE: 09-14-94 ECONOMIC LIFE 15 YEARS PREPARED BY: J. HOLLENS

1. INVESTMENT

A. CONSTRUCTION COST	\$ 645364.
B. SICK	\$ 32268.
C. DESIGN COST	\$ 32268.
D. TOTAL COST (1A+1B+1C)	\$ 709900.
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$ 0.
F. PUBLIC UTILITY COMPANY REBATE	\$ 0.
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$ 709900.

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU (1)	SAVINGS MBTU/YR (2)	ANNUAL S SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELECT	\$ 6.18	6521.	\$ 40300.	12.43	\$ 500926
B. DIST	\$ .00	0.	\$ 0.	13.56	\$ 0
C. RESID	\$ .00	0.	\$ 0.	15.09	\$ 0
D. NAT G	\$ .00	0.	\$ 0.	15.86	\$ 0
E. COAL	\$ .00	0.	\$ 0.	13.61	\$ 0
F. LPG	\$ .00	0.	\$ 0.	12.64	\$ 0
M. DEMAND SAVINGS			\$ 82741.		\$ 980481.
N. TOTAL		6521.	\$ 123041.		\$ 1481407.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)

(1) DISCOUNT FACTOR (TABLE A)	11.85	\$ 7615.
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 90238.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+)/ COST (-) (4)
------	--------------------------------	-----------------	------------------------	--

d. TOTAL \$ 0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+)/COST (-) (3A2+3Bd4) \$ 90238.

4. FIRST YEAR DOLLAR SAVINGS 2N3+3A+(3Bd1/(YRS ECONOMIC LIFE)) \$ 130656.

5. SIMPLE PAYBACK PERIOD (1G/4) 5.43 YEA

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 1571645.

7. SAVINGS TO INVESTMENT RATIO (SIR) = (6 / 1G) = 2.21  
 (IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 8.71 %

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

10 AUGUST 1991

INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

ADDRESS: 700 WHITE BLDG  
AREA USE:  
HOURS/DAY \_\_\_\_\_ 24  
DAYS/WEEK \_\_\_\_\_ 7  
VOLTING VOLTAGE 120V

ELECTRIC COSTS:  
PER KWH \_\_\_\_\_ \$0.0211  
PER KW \_\_\_\_\_ \$11.78

EXISTING FIXTURE DATA

FOOT	2 LAMP U • 32 WATT •	9 WATTS	
1 FOOT	1 LAMP U • 32 WATT •	0 WATTS	
15 2 LAMP U • 32 WATT •	144 WATTS	0 WATTS	
3 LAMP U • 32 WATT •	9 WATTS	0 WATTS	
4 LAMP U • 32 WATT •	32 WATTS	0 WATTS	

REPLACEMENT FIXTURE DATA

FOOT	0 1 LAMP U •	28 WATT •	0 WATTS
4 FOOT	0 2 LAMP U •	56 WATT •	0 WATTS
8 FOOT	0 3 LAMP U •	96 WATT •	825 WATTS
12 FOOT	0 4 LAMP U •	136 WATT •	67 WATT •
16 FOOT	0 2 LAMP U •	116 WATT •	116 WATT •

ECO ENERGY CONSUMPTION NOW

ECO DEMAND	NET ENERGY SAVINGS	NET DOLLAR SAVINGS
1.23 KWH	16102 KWH	\$72 MTR
	15.35 RETURN	\$167 MTR



## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR Lightings  
19 AUGUST 1994

### EXTERIOR LIGHTING REPLACES

BUILDING #: 7100	ELECTRIC COSTS: ENERGY CHARGE	\$0.0211 PER KWH
AREA USE: HOURS/H	DEMAND CHARGE	\$1.75 PER KW
EXTERIOR LIGHTING REPLACES		
EXTERIOR FIXTURES: INCANDE 100 WATTS = 9 WATTS 2' QUARTZ 200 WATTS = 40 WATTS MV 60 WATTS = 6 WATTS	REPLACEMENT ENERGY	6 WATTS 2 HPS @ 44 WATTS = \$2 WATTS 6 HPS @ 1.66 WATTS = \$1 WATTS
EXISTING ENERGY CONSUMPTION	NET ENERGY CONSUMPTION	48 KWH 1,497 MJ
BASELINE DEMAND	ECO DEMAND	0.00 KW 0.00 KW
NET ENERGY SAVINGS	4,970 KWH	NET DOLLAR SAVINGS
NET ENERGY SAVINGS	4.62 MILLION	\$23 MM

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7109 Date: 6 July 1994  
Description: Radar  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City index:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082221	DEMO, 2x4 FLOOR FIXTURES					29.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	14.07	\$0	\$387	\$0	\$0	\$387	
0207082540	DEMO, QUARTZ FIXTURES					2.00	
Unit values	1.00	0.00	27.50	0.00	0.00	27.50	
Totals	2.00	\$0	\$55	\$0	\$0	\$55	
002 SITEWORK		17	\$0	\$442	\$0	\$0	\$442

27-Jul-94

## MeansData for Lotus

Page 2

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S						
Unit values	0.94	26.74	22.52	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	49.26	
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S						
Unit values	1.00	28.65	23.82	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	52.47	
1661307001	LOW BAY, AL REFLECTOR 50W HPS						
Unit values	2.00	209.00	55.00	0.00	4.00	Ea.	
Totals	4.00	\$836	\$220	\$0	0.00	264.00	
1661307777	L.E.D. EXIT SIGN SINGLE FACE						
Unit values	1.00	185.00	27.50	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	212.50	
1661309601	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS						
Unit values	1.40	88.00	38.50	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	126.50	
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.51	84.00	42.50	0.20	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	125.50	
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS						
Unit values	1.60	90.00	44.00	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	134.00	
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS						
Unit values	1.70	94.00	47.00	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	141.00	
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.14	73.00	31.50	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	104.50	
1661309909	SUR FLUOR 1X4' W 2 32W T8						
Unit values	1.14	86.00	31.50	0.00	(qty)	Ea.	
					0.00	117.50	

27-Jul-94

## MeansData for Lotus

Page 3

## Totals

0.00 \$0 \$0 \$0 \$0 \$0 \$0

1661309910

INDUSTRIAL FLUOR 1X4' W 2 32W T8  
TWO-PIECE REFLECTOR

Unit values

1.14 60.00 31.50 0.00 16.00 EA

Totals

18.24 \$960 \$504 \$0 \$0 \$0 \$1,464

1661309913

SUR FLUOR 2X4' W 4 32W T8

Unit values

1.51 117.00 41.50 0.00 13.00 EA

Totals

19.63 \$1,521 \$540 \$0 \$0 \$0 \$2,061

1661396041

COMP FLUOR LAMP, 18 W TWIN TUBE  
GLOBE ASSEMBLY

Unit values

0.13 14.50 3.44 0.00 (qty) EA

Totals

0.00 \$0 \$0 \$0 \$0 \$0 17.94 \$0

27-Jul-94

MeansData for Lotus

Page 4

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
016 ELECTRICAL		46	\$3,317	\$1,264	\$0	\$0	\$4,581
ESTIMATE TOTAL		63	\$3,317	\$1,706	\$0	\$0	\$5,023
SALES TAX		5.00%	\$166				
MATL MARKUP		-40.00%	(-\$1,327)				
LABOR MARKUP		-13.40%		(\$229)			
EQUIPT MARKUP		0.00%			\$0		
SUB MARKUP		0.00%				\$0	
TOTAL BEFORE CONTINGENCY			\$2,156	\$1,477	\$0	\$0	\$3,633
CONTINGENCY		10.00%					\$363
BOND		2.50%					\$91
PROFIT		10.00%					\$363
JOB TOTAL							\$4,451

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7109 Date: 8 July 1994  
 Description: Radar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITWORK	17	\$0	\$442	\$0	\$0	\$442
U16 ELECTRICAL	46	\$3,317	\$1,264	\$0	\$0	\$4,581
<b>TOTAL</b>	<b>63</b>	<b>\$3,317</b>	<b>\$1,706</b>	<b>\$0</b>	<b>\$0</b>	<b>\$5,023</b>
SALES TAX	5.00%	316.5				
MATL MARKUP	-40.00%	(\$1,327)				
LABOR MARKUP	-13.40%		(5229)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$2,156</b>	<b>\$1,477</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,633</b>
CONTINGENCY	10.00%					\$363
BOND	2.50%					391
PROFIT	10.00%					\$363
<b>JOB TOTAL</b>						<b>\$4,451</b>





## FORT CAMPBELL LIGHTING SURVEY

ECO 1: EXTERIOR EXTERIOR LIGHTING  
19 AUGUST 1994

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING #: F109

FLUORESCENT EXIT SIGNS		REPLACEMENT FEATURE	
FEET SIGNS	FEET SIGNS	EXIT SIGNS	WATTAGE
3	3	1	14
WATTAGE	WATTAGE	WATTAGE	3
NET ENERGY CONSUMPTION	786 KWH/HR	792 KWH/HR	794 KWH/HR
NET ENERGY CONSUMPTION	2038 KWH/HR	2040 KWH/HR	2040 KWH/HR
NET ENERGY CONSUMPTION	0.02 KW	0.02 KW	0.02 KW
NET ENERGY SAVINGS	204 KWH/HR	NET DEMAND SAVINGS	\$11
NET ENERGY SAVINGS	2.42 KWH/HR	NET DOLLAR SAVINGS	\$28

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7110 Date: 3 July 1994  
Description: Barracks  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
02C7082121	DEMO, 2x4 FLUOR FIXTURES					16.00	
Unit values	0.49	0.00	13.35	0.00	0.00		13.35
Totals	7.76	\$0	\$214	\$0	\$0		\$214
0207082123	DEMO, INLAND FIXTURES / EXIT SIGNS					7.00	
Unit values	0.26	0.00	7.10	0.00	0.00		7.10
Totals	1.81	\$0	\$50	\$0	\$0		\$50
U02 SITEWORK		10	\$0	\$264	\$0	\$0	\$264

27-Jul-94

MeansData for Lotus

Page 2

## Line # Description

	Manhours	Matl	Labor	Equipment	Sub	Total
--	----------	------	-------	-----------	-----	-------

16613C2200	SUR FLUOR STRIP 4' W 1 40W LAMP R S				(qty)	EA.	
Unit values	0.94	26.74	22.52	0.00	0.00		49.26
Totals	C.00	\$0	\$0	\$0	\$0		\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S				(qty)	EA.	
Unit values	1.00	28.65	23.82	0.00	0.00		52.67
Totals	0.00	\$0	\$0	\$0	\$0		\$0
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE				3.00	EA	
Unit values	1.00	50.00	27.50	0.00	0.00		77.50
Totals	3.00	\$150	\$83	\$0	\$0		\$833
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-C ACRYLIC LENS				(qty)	EA	
Unit values	1.40	88.00	38.50	0.00	0.00		126.50
Totals	0.00	\$0	\$0	\$0	\$0		\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS				16.00	EA	
Unit values	1.51	84.00	41.50	0.00	0.00		125.50
Totals	24.16	\$1,344	\$664	\$0	\$0		\$2,008
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS				(qty)	EA	
Unit values	1.60	90.00	44.00	0.00	0.00		134.00
Totals	0.00	\$0	\$0	\$0	\$0		\$0
1661309804	REC FLUOR TROFFER 2X6' W 4 32W T8 ACRYLIC LENS				(qty)	EA	
Unit values	1.70	94.00	47.00	0.00	0.00		141.00
Totals	0.00	\$0	\$0	\$0	\$0		\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS				(qty)	EA	
Unit values	1.14	73.00	31.50	0.00	0.00		104.50
Totals	0.00	\$0	\$0	\$0	\$0		\$0
1661309909	SUR FLUOR 1X4' W 2 32W T8				(qty)	EA	
Unit values	1.14	86.00	31.50	0.00	0.00		117.50
Totals	0.00	\$0	\$0	\$0	\$0		\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR				(qty)	EA	
Unit values	1.14	90.00	31.50	0.00	0.00		121.50

27-Jul-94

XeansData for lotus

Page 3

*	Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661388041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY						
Unit values	0.13	14.50	3.44	0.00	(qty) 0.00	EA	17.94
Totals	0.00	\$0	\$0	\$0	\$0		\$0
1661388042	COMP FLUOR FIX, 4 13 W PL WALL / CEILING MOUNT						
Unit values	1.00	35.50	27.50	0.00	1.00 0.00	EA	63.00
Totals	1.00	\$36	\$28	\$0	\$0		\$64

27-Jul-94

## MeansData for Lotus

Page 4

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		29	\$1,530	\$775	\$0	\$0	\$2,305
ESTIMATE TOTAL		39	\$1,530	\$1,039	\$0	\$0	\$2,569
SALES TAX	5.00%		\$77				
MATL MARKUP	-40.00%		(\$612)				
LABOR MARKUP	-13.40%			(\$139)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$995	\$900	\$0	\$0	\$1,894
CONTINGENCY	10.00%						\$189
BOND	2.50%						\$47
PROFIT	10.00%						\$189
JOB TOTAL							\$2,320

27-Jul-94

MeansData for Lotus

Page 3

Estimate: Bldg. 7110 Date: 8 July 1994  
 Description: Barracks  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITWORK	10	\$0	\$264	\$0	\$0	\$264
U16 ELECTRICAL	29	\$1,530	\$775	\$0	\$0	\$2,305
<b>TOTAL</b>	<b>39</b>	<b>\$1,530</b>	<b>\$1,039</b>	<b>\$0</b>	<b>\$0</b>	<b>\$2,569</b>
SALES TAX	5.00%	\$77				
MATL MARKUP	-40.00%	(\$612)				
LABOR MARKUP	-13.40%		(\$139)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$995</b>	<b>\$900</b>	<b>\$0</b>	<b>\$0</b>	<b>\$1,894</b>
CONTINGENCY	10.00%					\$189
BOND	2.50%					\$47
PROFIT	10.00%					\$189
<b>JOB TOTAL</b>						<b>\$2,320</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

16 AUGUST 1984

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7112  
AREA: DAVRODUS  
BASELINE SOURCE/day: 14  
DAYS/WEK: 7  
BUILDING VOL/TAGE: 120V

### ESTIMATED FIXTURE DATA

2' X 4' FT	2 LAMP U	50 WATT/s	0 WATT/s
4' FOOT	1 LAMP @	40 WATT/s	0 WATT/s
	2 LAMP @	80 WATT/s	0 WATT/s
	3 LAMP @	120 WATT/s	0 WATT/s
	4 LAMP @	160 WATT/s	0 WATT/s

4' FOOT	1 LAMP @	0 WATT/s
	2 LAMP @	40 WATT/s
	3 LAMP @	80 WATT/s
	4 LAMP @	120 WATT/s

8' FOOT	2 LAMP @	80 WATT/s
	4 LAMP @	160 WATT/s

12' FOOT	2 LAMP @	120 WATT/s
	4 LAMP @	240 WATT/s

ELECTRIC COSTS:  
ENERGY CHARGE      \$0.5211 PER KWH  
DEMAND CHARGE      \$11.78 PER KW

### REPLACEMENT FIXTURE DATA

2 FOOT	0.2 LAMP U @	50 WATT/s	0 WATT/s
4 FOOT	0.1 LAMP @	20 WATT/s	0 WATT/s
	0.2 LAMP @	40 WATT/s	0 WATT/s
	0.3 LAMP @	60 WATT/s	0 WATT/s
	0.4 LAMP @	80 WATT/s	0 WATT/s

8 FOOT	0.2 LAMP @	120 WATT/s
	0.4 LAMP @	240 WATT/s

### NET DEMAND SAVINGS

\$16 MR

### NET DOLLAR SAVINGS

\$51 MR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

### INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7112	DAYROOMS	ELECTRIC COSTS:
AREA: LAMP USE:	14	PER KWH
HOURS/DAY	7	\$0.0211
DAYSTIME	1 (1-VES, 2-NOT)	PER KW
PEAK USE		\$11.74
BUILDING VOLTAGE: 120V		

EXISTING INCANDESCENT		COMPACT FLUORESCENT REPLACEMENT	
LAMPS @	52	WATTS @	0 WATTS
LAMPS @	60	WATTS @	0 WATTS
LAMPS @	72	WATTS @	0 WATTS
LAMPS @	60	WATTS @	6 WATTS
3 LAMPS @	108	WATTS @	360 WATTS

BASELINE ENERGY CONSUMPTION	1529 KWH	ECO ENERGY CONSUMPTION	397 KWH
BASELINE DEMAND	5501 MJ	ECO DEMAND	1631 MJ
	0.36 KW		0.06 KW

NET ENERGY SAVINGS	4673 MJ/YR	NET DEMAND SAVINGS	\$31 /YR
NET ENERGY SAVINGS	3.38 MJ/TUR	NET DOLLAR SAVINGS	\$53 /YR

## FORT CAMPBELL LIGHTING SURVEY

ECO 4: INTERIOR EXTERIOR LIGHTING  
10 AUGUST 1994

### INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

NUMBER	FLUORESCENT EXIT SIGNS	REPLACEMENT FIXTURES	NET ENERGY SAVINGS
7112	10	10	0.33 MWH
INCANDESCENT EXIT SIGNS	10	10	0.00 MWH
WATTAGE	10	10	0.00 MWH
BASELINE ENERGY CONSUMPTION	100 KWH/MONTH	ECO ENERGY CONSUMPTION	0.00 KWH/MONTH
PERIOD OF SURVEY	6/25/94 - 7/25/94	ECO DEMAND	0.00 KWH
NET ENERGY SAVINGS	0.00 MWH	NET DOLLAR SAVINGS	0.00
NET ENERGY SAVINGS	0.00 MWH	NET DOLLAR SAVINGS	0.00

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7112 Date: 8 July 1994  
Description: Barracks  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Suh	Total
0207082121	DEMO, 2X4 FLUOR FIXTURES					4.00	
Unit values	0.49	0.00	13.35	0.00	0.00	0.00	13.35
Totals	1.94	\$0	\$53	\$0	\$0	\$0	\$53
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					2.00	
Unit values	0.26	0.00	7.10	0.00	0.00	0.00	7.10
Totals	0.52	\$0	\$14	\$0	\$0	\$0	\$14
U02 SITWORK		3	\$0	567	\$0	\$0	\$67

27-Jul-94

## MeansData for Lotus

Page 2

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S						
Unit values	0.94	26.74	22.52	0.00		(qty) Ea.	
Totals	0.00	\$0	\$0	\$0		0.00	49.26
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S						
Unit values	1.00	28.65	23.82	0.00		(qty) Ea.	
Totals	0.00	\$0	\$0	\$0		0.00	52.47
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE						
Unit values	1.00	50.00	27.50	0.00		1.00 Ea	
Totals	1.00	\$50	\$28	\$0		0.00	77.50
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS						
Unit values	1.40	88.00	38.50	0.00		(qty) Ea	
Totals	0.00	\$0	\$0	\$0		0.00	126.50
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.51	84.00	41.50	0.00		4.00 Ea	
Totals	6.04	\$336	\$166	\$0		0.00	125.80
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS						
Unit values	1.60	90.00	44.00	0.00		(qty) Ea	
Totals	0.00	\$0	\$0	\$0		0.00	134.00
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS						
Unit values	1.70	94.00	47.00	0.00		(qty) Ea	
Totals	0.00	\$0	\$0	\$0		0.00	141.00
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.14	73.00	31.50	0.00		(qty) Ea	
Totals	0.00	\$0	\$0	\$0		0.00	104.50
1661309909	SUR FLUOR 1X4' W 2 32W T8						
Unit values	1.14	86.00	31.50	0.00		(qty) Ea	
Totals	0.00	\$0	\$0	\$0		0.00	117.50
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR						
Unit values	1.14	90.00	31.50	0.00		(qty) Ea	
						0.00	121.50

27-Jul-94

MeansData for Lotus

Page 3

Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661388041	CCMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY						
Unit values	0.13	14.50	3.44	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00	17.94	\$0
1661388042	COMP FLUOR FIX, 3 26 W PL WALL / CEILING MOUNT						
Unit values	1.00	30.50	27.50	0.00	1.00	EA	
Totals	1.00	\$31	\$28	\$0	0.00	58.00	\$59

27-Jul-94

MeansData for Lotus

Page 4

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
C16 ELECTRICAL		9	\$417	\$222	\$0	\$0	\$639
ESTIMATE TOTAL		12	\$417	\$289	\$0	\$0	\$706
SALES TAX	5.00%		\$21				
MATL MARKUP	-40.00%		(\$167)				
LABOR MARKUP	-13.40%			(\$39)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$271	\$250	\$0	\$0	\$521
CONTINGENCY	10.00%						\$52
BOND	2.50%						\$13
PROFIT	10.00%						\$52
JOB TOTAL							\$639

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7112 Date: 8 July 1994  
 Description: Barracks  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Mankhours	Matl	Labor	Equipment	Sub	Total
SC2 SITEWORK	3	\$0	\$67	\$0	\$0	\$67
U16 ELECTRICAL	9	\$417	\$222	\$0	\$0	\$639
<b>TOTAL</b>	<b>12</b>	<b>\$417</b>	<b>\$289</b>	<b>\$0</b>	<b>\$0</b>	<b>\$706</b>
SALES TAX	5.00%	\$21				
MATL MARKUP	-40.00%	(\$167)				
LABOR MARKUP	-13.40%		(\$39)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$271</b>	<b>\$250</b>	<b>\$0</b>	<b>\$0</b>	<b>\$521</b>
CONTINGENCY	10.00%					\$52
BOND	2.50%					\$13
PROFIT	10.00%					\$52
<b>JOB TOTAL</b>						<b>\$639</b>

## FORT CAMPEFELL LIGHTING SURVEY

EXC 1: SIMPLE / EXTRACTIVE

Fragile? ?

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
19 AUGUST 1984

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7118	DAYROOMS
AREA: LAMP LIFE	14
HOURS/DAY	7
DAYSWEEK	1 (1-YES, 2-MO)
PEAK USE	
BUILDING VOLTAGE: 120V	

ELECTRIC COSTS.	\$0.0211 PER KWH
ENERGY CHARGE	\$11.78 PER KW
DEMAND CHARGE	

## EXISTING INCANDESCENTS

LAMPS @ 32 WATTS	0 WATTS
LAMPS @ 60 WATTS	0 WATTS
LAMPS @ 75 WATTS	0 WATTS
LAMPS @ 80 WATTS	0 WATTS
LAMPS @ 100 WATTS	300 WATTS
3 LAMPS @	

## BASELINE ENERGY CONSUMPTION

BASELINE DEMAND	0.29 KW
-----------------	---------

337 KWH

## ECO ENERGY CONSUMPTION

0.00 KW

## ECO DEMAND

NET ENERGY SAVINGS	\$31/YR
NET ENERGY SAVINGS	\$55/YR

NET DEMAND SAVINGS	\$31/YR
NET DOLLAR SAVINGS	\$55/YR

4,973 MWH	
3.06 RETURN	

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

10 AUGUST 1984

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING #: 7110	FLUORESCENT EXIT SIGNS # EXIT SIGNS 1 WATTAGE 30	ELECTRIC COSTS: ENERGY CHARGE — <u>20.0211</u> PER kWh DEMAND CHARGE — <u>311.73</u> PER kW	REPLACEMENT FIXTURE # EXIT SIGNS 1 WATTAGE 3	NET DEMAND SAVINGS \$51.00/kW NET DOLLAR SAVINGS \$51.00
INCANDESCENT EXIT SIGNS # EXIT SIGNS 1 WATTAGE 10	PARALLELED EXISTING CONSUMPTION 846.8 kW NET DEMAND 600.0 kW	NET DEMAND SAVINGS \$51.00/kW NET DOLLAR SAVINGS \$51.00	NET DEMAND SAVINGS \$51.00/kW NET DOLLAR SAVINGS \$51.00	NET DEMAND SAVINGS \$51.00/kW NET DOLLAR SAVINGS \$51.00

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7118 Date: 8 July 1994  
Description: Barracks  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082121	DEMO, 2x4 FLUOR FIXTURES					4.00	
Unit values	0.49	0.00	13.35	0.00	0.00	\$0	13.35
Totals	1.94	\$0	\$53	\$0	\$0	\$0	\$53
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					2.00	
Unit values	0.26	0.00	7.10	0.00	0.00	\$0	7.10
Totals	0.52	\$0	\$14	\$0	\$0	\$0	\$14
W02 SITEMCRK		3	\$0	\$67	\$0	\$0	\$67

PAGE 3-5

27-Jul-94

MeansData for Lotus

Page 2

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty) Ea.	
Unit values	0.94	26.74	22.52	0.00	0.00	0.00	49.26
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty) Ea.	
Unit values	1.00	28.65	23.82	0.00	0.00	0.00	52.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE					1.00 EA	
Unit values	1.00	50.00	27.50	0.00	0.00	0.00	77.50
Totals	1.00	\$50	\$28	\$0	\$0	\$0	\$78
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					(qty) EA	
Unit values	1.40	88.00	38.50	0.00	0.00	0.00	126.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					4.00 EA	
Unit values	1.51	94.00	41.50	0.00	0.00	0.00	125.50
Totals	6.04	\$336	\$166	\$0	\$0	\$0	\$502
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty) EA	
Unit values	1.60	90.00	44.00	0.00	0.00	0.00	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					(qty) EA	
Unit values	1.70	94.00	47.00	0.00	0.00	0.00	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					(qty) EA	
Unit values	1.14	73.00	31.50	0.00	0.00	0.00	104.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309909	SUR FLUOR 1X4' W 2 32W T8					(qty) EA	
Unit values	1.14	86.00	31.50	0.00	0.00	0.00	117.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR					(qty) EA	
Unit values	1.14	90.00	31.50	0.00	0.00	0.00	121.50

PAGE 3-56

27-Jul-94

MeansData for Lotus

Page 3

<b>A</b> <b>Totals</b>	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661388041	COMP FLUOR LAMP, 19 W TWIN TUBE GLOBE ASSEMBLY						
Unit values	0.13	14.50	3.44	0.00	(qty)	EA	
<b>Totals</b>	0.00	\$0	\$0	\$0	0.00	17.94	\$0
1661388042	COMP FLUOR FIX, 3 26 W PL WALL / CEILING MOUNT						
Unit values	1.00	30.50	27.50	0.00	1.00	EA	
<b>Totals</b>	1.00	\$31	\$28	\$0	0.00	58.00	\$59

27-Jul-94

MeansData for Lotus

Page 4

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		9	\$417	\$232	\$0	\$0	\$639
ESTIMATE TOTAL		12	\$417	\$289	\$0	\$0	\$706
SALES TAX	5.00%		\$21				
MATL MARKUP	-40.00%		(\$167)				
LABOR MARKUP	-13.40%			(\$39)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENC							
CONTINGENCY	10.00%		\$271	\$250	\$0	\$0	\$521
BOND	2.50%						\$52
PROFIT	10.00%						\$13
JOB TOTAL							\$532
							\$639

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7118 Date: 6 July 1994  
 Description: Barracks  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITWORK	3	\$0	\$67	\$0	\$0	\$67
U16 ELECTRICAL	9	\$417	\$222	\$0	\$0	\$639
<b>TOTAL</b>	<b>12</b>	<b>\$417</b>	<b>\$289</b>	<b>\$0</b>	<b>\$0</b>	<b>\$706</b>
SALES TAX	5.00%	\$21				
MATERIAL MARKUP	-40.00%	(\$167)				
LABOR MARKUP	-13.40%		(\$39)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$271</b>	<b>\$250</b>	<b>\$0</b>	<b>\$521</b>	
CONTINGENCY	10.0%					\$52
BOND	2.50%					\$13
PROFIT	10.00%					\$52
<b>JOB TOTAL</b>						<b>\$639</b>

# FORT CAMPBELL LIGHTING SURVEY

ECC 1: INTERIOR / EXTERIOR LIGHTING

10 AUGUST 1984

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7120	DAYROOMS	ELECTRIC COSTS:		
AREA USE: HOURS/DAY	1	PER KWH	PER KWH	
DAYSPWEEK	5	\$0.0211	\$11.75	PER KW
BUILDING VOLTAGE: 120V				

## EXISTING FIXTURE DATA

FOOT	2 LAMP U	30 WATT	9 WATTS	
4 FOOT	1 LAMP @ 30 WATT	30 WATT	9 WATTS	0 WATTS
4 FOOT	2 LAMP @ 30 WATT	60 WATT	18 WATTS	0 WATTS
4 FOOT	3 LAMP @ 30 WATT	90 WATT	27 WATTS	0 WATTS
4 FOOT	4 LAMP @ 30 WATT	120 WATT	36 WATTS	0 WATTS
8 FOOT	2 LAMP @ 30 WATT	30 WATT	9 WATTS	0 WATTS
8 FOOT	4 LAMP @ 30 WATT	120 WATT	36 WATTS	0 WATTS

## REPLACEMENT FIXTURE DATA

FOOT	0.2 LAMP U	30 WATT	9 WATTS	
4 FOOT	0.1 LAMP @ 30 WATT	30 WATT	9 WATTS	0 WATTS
4 FOOT	0.2 LAMP @ 30 WATT	60 WATT	18 WATTS	0 WATTS
4 FOOT	0.3 LAMP @ 30 WATT	90 WATT	27 WATTS	0 WATTS
4 FOOT	0.4 LAMP @ 30 WATT	120 WATT	36 WATTS	0 WATTS
8 FOOT	0.2 LAMP @ 30 WATT	30 WATT	9 WATTS	0 WATTS
8 FOOT	0.4 LAMP @ 30 WATT	120 WATT	36 WATTS	0 WATTS

NET DEMAND SAVINGS	\$15 MVR
NET DOLLAR SAVINGS	\$23 MVR

NET ENERGY SAVINGS	1,303 MVR
NET ENERGY SAVINGS	1.29 METER

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BULBING:	7,120
AMPS:	DAIRY ROOMS
CAMP USE:	14
HOURS/DAY	5
DAYS/WEEK	-
PEAK USE	1 (1-YEAR, 2-MO)

BULBING VOLTAGE	
LAMPS @ 120V	14
LAMPS @ 110V	5

SWITCHING INCANDESCENTS	
LAMPS @ 60WATTS	52
LAMPS @ 60WATTS	52
LAMPS @ 60WATTS	60
LAMPS @ 75WATTS	72
LAMPS @ 75WATTS	72
LAMPS @ 90WATTS	60
LAMPS @ 90WATTS	60
LAMPS @ 100WATTS	100

ELECTRIC COSTS:	
ENERGY CHARGE	\$0.0211 PER KWH
DEMAND CHARGE	\$11.76 PER KW

COMPACT FLUORESCENT REPLACEMENT	
LAMPS @ 13 WATTS	0 LAMPS @ 13 WATTS
LAMPS @ 18 WATTS	0 LAMPS @ 18 WATTS
LAMPS @ 26 WATTS	3 LAMPS @ 26 WATTS

ECO ENERGY CONSUMPTION	
1,607 KWH	232 KWH
1.611 MJ	1,022 MJ
0.39 KW	0.09 KW

NET DEMAND SAVINGS	\$31 NRR
NET DOLLAR SAVINGS	\$48 NRR

NET ENERGY SAVINGS

NET ENERGY SAVINGS

## **FORT CAMPBELL LIGHTING SURVEY**

ECCLESIASTICAL LITERATURE

卷之三

四

**ELECTRIC COSTS**      **DEMAND CHARGE**      **PER kWh**

ELECTRIC CO.

四

卷之三

卷之三

卷之三

卷之三

THE JOURNAL OF

MATTACE

1

九

MATTAGE

VINTAGE

**2015 Annual - ECO STAR Y CONSUMO SUSTENTABLE**

卷之三

THE VICTORIAN

三

卷之三

NET DEBTORS PAYABLES

ECONOMIC

## **NET ENERGY SAVINGS**

二

卷之三

۳۲

NET DOMAINS

卷之三

JOURNAL OF ADVANCED

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7120 Date: 8 July 1994  
Description: Barracks  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082121	DEMO, 2x4 FLUOR FIXTURES					4.00	
Unit values	0.49	0.00	13.35	0.00	0.00	\$0	13.35
Totals	1.94	\$0	\$53	\$0	0.00	\$0	\$53
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					2.00	
Unit values	0.26	0.00	7.10	0.00	0.00	\$0	7.10
Totals	0.52	\$0	\$14	\$0	0.00	\$0	\$14
C02 SITENCRK		3	\$0	\$67	\$0	\$0	\$67

27-Jul-94

## MeansData for Lotus

Page 2

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S						
Unit values	0.94	26.74	22.52	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	49.26
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S						
Unit values	1.00	28.65	23.82	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	52.47
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE						
Unit values	1.00	50.00	27.50	0.00	1.00	EA	
Totals	1.00	\$50	\$28	\$0	0.00	\$0	77.50
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS						
Unit values	1.40	88.00	38.50	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	126.50
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.51	84.00	41.50	0.00	4.00	EA	
Totals	6.04	\$336	\$166	\$0	0.00	\$0	125.50
1661309803	REC FLUOR TROFFER 3X4' W 3 33W T8 ACRYLIC LENS						
Unit values	1.60	90.00	44.00	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	134.00
1661309804	REC FLUOR TROFFER 2X6' W 4 32W T8 ACRYLIC LENS						
Unit values	1.70	94.00	47.00	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	141.00
1661309807	REC FLUOR TROFFER 1X4' W 2 33W T8 ACRYLIC LENS						
Unit values	1.14	73.00	31.50	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	104.50
1661309909	SUR FLUOR 1X4' W 2 32W T8						
Unit values	1.14	86.00	31.50	0.00	(qty)	Ea.	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	117.50
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR						
Unit values	1.14	90.00	31.50	0.00	(qty)	Ea.	
					0.00		121.50

PAGE 3-64

27-Jul-94

MeansData for Lotus

Page 3

<b>Totals</b>	0.00	\$0	\$0	\$0	\$0	\$0
1661388041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY					
Unit values	0.13	14.50	3.44	0.00	(qty,	EA
Totals	0.00	\$0	\$0	\$0	0.00	17.94
					\$0	\$0
1661388042	COMP FLUOR FIX, 3 26 W PL WALL / CEILING MOUNT					
Unit values	1.00	30.50	27.50	0.00	1.00	EA
Totals	1.00	\$31	\$28	\$0	0.00	58.00
					\$0	\$59

PAGE 3-65

27-Jul-94

MeansData for Lotus

Page 4

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		9	\$417	\$222	\$0	\$0	\$635
ESTIMATE TOTAL		12	\$417	\$289	\$0	\$0	\$706
SALES TAX	5.00%		\$21				
MATL MARKUP	-40.00%		(\$167)				
LABOR MARKUP	-13.40%			(\$39)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$271	\$250	\$0	\$0	\$521
CONTINGENCY	10.00%						\$52
BOND	2.50%						\$13
PROFIT	10.00%						\$52
JOB TOTAL							\$639

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7120 Date: 8 July 1994  
 Description: Barracks  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITEWORK	3	\$0	\$57	\$0	\$0	\$67
U16 ELECTRICAL	9	\$417	\$222	\$0	\$0	\$639
<b>TOTAL</b>	<b>12</b>	<b>\$417</b>	<b>\$289</b>	<b>\$0</b>	<b>\$0</b>	<b>\$706</b>
SALES TAX	5.00%	\$21				
MATL MARKUP	-40.00%	(\$167)				
LABOR MARKUP	-13.40%		(\$39)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$271</b>	<b>\$250</b>	<b>\$0</b>	<b>\$0</b>	<b>\$521</b>
CONTINGENCY	10.00%					\$52
BCND	2.50%					\$13
PROFIT	10.00%					\$52
<b>JOB TOTAL</b>						<b>\$639</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #:	7131	ELECTRIC COSTS ENERGY CHARGE DEMAND CHARGE	\$0.0211 kWh \$11.78 PER KW
AREA:	12		
MEASURED HOURS/DAY	6		
DAYSM/EEK			
BUILDING VOLTAGE	120		
EXISTING FIXTURE DATA			
2 FOOT 1 2 LAMP U	85 WATT =	85 WATTS	
4 FOOT 1 LAMP G	45 WATT =	0 WATTS	
4 FOOT 2 LAMP G	24 WATT =	7342 WATTS	
4 FOOT 3 LAMP G	144 WATT =	0 WATTS	
4 FOOT 4 LAMP G	168 WATT =	9376 WATTS	
REPLACEMENT FIXTURE DATA			
2 FOOT 1 2 LAMP G	58 WATT =	58 WATTS	
4 FOOT 1 LAMP G	20 WATT =	0 WATTS	
4 FOOT 2 LAMP G	50 WATT =	5164 WATTS	
4 FOOT 3 LAMP G	87 WATT =	0 WATTS	
4 FOOT 4 LAMP G	96 WATT =	2306 WATTS	
8 FOOT 1 2 LAMP G			
8 FOOT 2 LAMP G	125 WATT =	0 WATTS	
BASELINE ENERGY CONSUMPTION			
NET DEMAND	61,088 kWh 229,935 MJR 17.84 kW	ECO ENERGY CONSUMPTION	31,784 kWh 114,935 MJR 6.47 kW
NET ENERGY SAVINGS	115,303 kWh 103,011 MJR	NET DOLLAR SAVINGS	\$1,215 P/M \$1,894 P/M

PAGE

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

## INTERIOR LIGHTING INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7131

AREA: OFFSTOCK

LAMP USE  
HOURS/DAY \_\_\_\_\_ 4  
DAYS/WEEK \_\_\_\_\_ 5  
PEAK USE \_\_\_\_\_ 2 (1-YES, 2-NON)

BUILDING VOLTAGE: 120

EXISTING INCANDESCENT LAMPS:  
LAMPS @ 52 WATTS = 9 WATTS  
3 LAMPS @ 90 WATTS = 160 WATTS  
LAMPS @ 75 WATTS = 6 WATTS  
LAMPS @ 90 WATTS = 0 WATTS  
LAMPS @ 100 WATTS = 0 WATTS

BASELINE ENERGY CONSUMPTION: 197 KWH  
BASELINE DEMAND: 674 MJ  
0.19 KW

COMPACT FLUORESCENT REPLACEMENT  
3 LAMPS @ 13 WATTS = 39 WATTS  
0 LAMPS @ 18 WATTS = 0 WATTS  
0 LAMPS @ 26 WATTS = 0 WATTS

KWH  
146 MJ  
0.84 KW  
ECO DEMAND

\$26 MMR  
\$0.59 MMUTVR  
NET ENERGY SAVINGS

NET DEMAND SAVINGS  
NET DOLLAR SAVINGS

\$0 MMR  
\$3 MMR

27-Jul-94

MeansData for Lotus

PA

Estimate: Bldg. 7031 Date: 6 July 1994  
 Description:  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City, State:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082119	DEMO, 2x2, 1x4 FLUOR FIXTURES					1.00	
Unit values	0.36	0.00	10.10	0.00	0.00	\$0	10.10
Totals	0.36	\$0	\$10	0.00	0.00	\$0	\$10.10
0207082121	DEMO, 2x4 FLUOR FIXTURES					145.00	
Unit values	0.49	0.00	13.35	0.00	0.00	\$0	13.35
Totals	70.32	\$0	\$1,936	0.00	0.00	\$0	\$1,936
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					3.00	
Unit values	0.26	0.00	7.10	0.00	0.00	\$0	7.10
Totals	0.77	\$0	\$21	0.00	0.00	\$0	\$21.00
U02 SITEWORK		72	\$0	\$2,967	\$0	\$0	\$2,967

FACT

1

27-Jul-94

MeansData for Lotus

FBI

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty)	Ea.
Unit values	3.94	26.74	22.52	0.00	0.00	\$0	49.2
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty)	Ea.
Unit values	1.00	28.65	23.82	0.00	0.00	\$0	52.4
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661307777	L.E.D. EXIT SIGN SINGLE FACE					(qty)	EA
Unit values	1.00	185.00	27.50	0.00	0.00	\$0	212.5
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-C ACRYLIC LENS					1.00	EA
Unit values	1.40	88.00	38.50	0.00	0.00	\$0	126.5
Totals	1.40	\$88	\$39	0.00	0.00	\$0	\$12
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.51	84.00	41.50	0.00	0.00	\$0	125.5
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.60	90.00	44.00	0.00	0.00	\$0	134.0
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					0.00	EA
Unit values	1.70	94.00	47.00	0.00	0.00	\$0	141.0
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309805	REC FLUOR TROFFER 2X6' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR					57.00	EA
Unit values	1.51	106.50	41.50	0.00	0.00	\$0	148.0
Totals	06.07	\$6,071	\$2,366	0.00	0.00	\$0	\$8,43
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.14	73.00	31.50	0.00	0.00	\$0	104.5
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309909	SUR FLUOR 1X4' W 2 32W T8					(qty)	EA
Unit values	1.14	86.00	31.50	0.00	0.00	\$0	117.5

PAGE : 1

27-JUL-94

## MeansData for Ictus

Page

	0.00	\$0	\$0	50	\$0	\$0
<b>Totals</b>						
1661309510	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR					
Unit values	1.14	60.60	31.50	0.00	0.00	91.50
<b>Totals</b>	100.32	\$5,280	\$2,772	\$0	\$0	\$8,052
1661322041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY				(qty)	EA
Unit values	0.13	14.50	3.44	0.00	0.00	17.94
<b>Totals</b>	0.00	\$0	\$0	\$0	\$0	\$0
1661328542	COMP FLUOR FIX, 2 13 W PL. WALL / CEILING MOUNT					
Unit values	1.00	25.50	27.50	0.00	0.00	53.00
<b>Totals</b>	3.00	\$77	\$83	\$0	\$0	\$1.60

27-Jul-94

MeansData for Lotus

Page

Line #	Description							
		Manhours	Matl	Labor	Equipment	Sub	Total	
U16 ELECTRICAL		191	\$11,516	\$3,260		\$0	\$0	\$16,776
ESTIMATE TOTAL		263	\$11,516	\$7,227		\$0	\$0	\$18,743
SALES TAX	5.00%		\$576					
MATL MARKUP	-40.00%		(\$4,606)					
LABOR MARKUP	-13.40%			(\$968)				
EQUIPT MARKUP	0.00%				\$0			
SUB MARKUP	0.00%					\$0		
TOTAL BEFORE CONTINGENCY			\$7,485	\$6,299		\$0	\$0	\$13,744
CONTINGENCY	10.00%							\$1,374
BCND	2.50%							\$344
PROFIT	10.00%							\$1,374
JOB TOTAL								\$16,836

27-Jul-94

## MeansData for Lotus

Page

Estimate: Bldg. 7131 Date: 9 July 1994  
 Description:  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITENWORK	72	\$0	\$1,967	\$0	\$0	\$1,967
U16 ELECTRICAL	191	\$11,516	\$5,260	\$0	\$0	\$16,776
<b>TOTAL</b>	<b>263</b>	<b>\$11,516</b>	<b>\$7,227</b>	<b>\$0</b>	<b>\$0</b>	<b>\$18,743</b>
SALES TAX	5.00%	\$576				
MATL MARKUP	+40.00%	(\$4,606)				
LABOR MARKUP	+13.40%		(\$968)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$7,485</b>	<b>\$6,259</b>	<b>\$0</b>	<b>\$0</b>	<b>\$13,744</b>
CONTINGENCY	10.00%					\$1,374
BDND	2.50%					\$344
PROFIT	10.00%					\$1,374
<b>JOB TOTAL</b>						<b>\$16,836</b>

FORT CAMPBELL LIGHTING SURVEY					
ECO 1: INTERIOR / EXTERIOR LIGHTING 12 AUGUST 1994					
INTERIOR LIGHTING: FLUORESCENT PAR30 REPLACEMENT					
BUILDING #: 7133	AREA: ENTIRE BLDG.	ELECTRIC COSTS: ENERGY CHARGE	\$0.0211 PER kWh		
AREA AREA:	HOURS/DAY	DEMAND CHARGE	\$11.78 PER KW		
	DAY/SWEEK				
PUBLIC VOLTAGE: 120					
EXISTING LIGHTING DATA					
2 FOOT 2 LAMP U 84 WATT = 84 WATT = 84 WATTS					
4 FOOT 1 LAMP @ 40 WATT = 0 WATTS		1 LAMP @ 20 WATT = 0 WATTS			
25.2 LAMP @ 64 WATT = 2435 WATTS		25.2 LAMP @ 12.5 WATT = 315.75 WATTS			
3 LAMP @ 100 WATT = 0 WATTS		3 LAMP @ 50 WATT = 150 WATTS			
36.4 LAMP @ 100 WATT = 14952 WATTS		36.4 LAMP @ 50 WATT = 1824 WATTS			
REPLACEMENT LIGHTING DATA					
2 FOOT 2 LAMP U 84 WATT = 84 WATT = 84 WATTS					
4 FOOT 1 LAMP @ 20 WATT = 0 WATTS		1 LAMP @ 10 WATT = 0 WATTS			
25.2 LAMP @ 12.5 WATT = 315.75 WATTS		25.2 LAMP @ 6.25 WATT = 159.375 WATTS			
3 LAMP @ 50 WATT = 150 WATTS		3 LAMP @ 25 WATT = 75 WATTS			
36.4 LAMP @ 50 WATT = 1824 WATTS		36.4 LAMP @ 25 WATT = 912 WATTS			
8 FOOT					
2 LAMP @ 100 WATT = 0 WATTS		2 LAMP @ 50 WATT = 0 WATTS			
POTENTIAL ENERGY CONSERVATION		ECO ENERGY CONSERVATION			
POTENTIAL DEMAND		ECO DEMAND			
NET ENERGY SAVINGS	180.438 WATTS	NET DEMAND SAVINGS	\$9,530 MM		
NET ENERGY SAVINGS	95.38 WATTS	NET DOLLAR SAVINGS	\$2,110 MM		

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7123	AREA: RESTROOM	ELECTRIC COSTS:	
LAMP USE:	3	ENERGY CHARGE .200211 PER KWH	
HOURS/DAY:	5	DEMAND CHARG .31176 PER KW	
DAYSP/WEEK:	2 (1-YES, 2-NOW)		
PEAK USE:			
BUILDING VOLTAGE: 120			
EXISTING INCANDESCENTS			
LAMPS @ 52 WATTS:	6 WATTS	2 LAMPS @ 13 WATTS =	26 WATTS
2 LAMPS @ 60 WATTS:	120 WATTS		
2 LAMPS @ 75 WATTS:	150 WATTS		
2 LAMPS @ 90 WATTS:	180 WATTS		
2 LAMPS @ 105 WATTS:	210 WATTS		
COMPACT FLUORESCENT REPLACEMENT			
LAMPS @ 6 WATTS:	6 WATTS	2 LAMPS @ 6 WATTS =	26 WATTS
0 LAMPS @ 16 WATTS:	0 WATTS		
0 LAMPS @ 26 WATTS:	0 WATTS		
BASELINE ENERGY CONSUMPTION			
GAS IN: 0 KWH	94 KWH	ECO ENERGY CONSUMPTION	29 KWH
	397 MJ		73 MJ
	6.92 KWH	ECO DEMAND	0.63 KWH
NET ENERGY SAVINGS			
NET ENERGY SAVINGS	204 MJ/KW	NET DEMAND SAVINGS	59 MJ
NET ENERGY SAVINGS	0.26 MJ/WHR	NET DOLLAR SAVINGS	\$2 MJ

27-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7133 Date: 8 July 1994  
 Description: Admin  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
C207082119	DEMO, 2x2, 1x4 FLUOR FIXTURES					8.00	
Unit values	0.36	0.00	10.00	0.00	0.00	10.00	
Totals	2.91	\$0	\$80	\$0	\$0	\$80	
C207082121	DEMO, 2x4 FLUOR FIXTURES					118.00	
Unit values	0.43	0.00	13.35	0.00	0.00	13.35	
Totals	57.23	\$0	\$1,575	\$0	\$0	\$1,575	
C207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					2.00	
Unit values	0.26	0.00	7.10	0.00	0.00	7.10	
Totals	0.52	\$0	\$14	\$0	\$0	\$14	
U02 SITEWORK		61	\$0	\$1,669	\$0	\$0	\$1,669

27-Jul-94

## MeansData for Locus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty)	Ea.
Unit values	0.94	26.74	22.52	0.00	0.00	0.00	49.26
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty)	Ea.
Unit values	1.00	28.65	23.82	0.00	0.00	0.00	52.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN SINGLE FACE					(qty)	EA
Unit values	1.00	185.00	27.50	0.00	0.00	0.00	212.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-J ACRYLIC LENS					6.00	EA
Unit values	1.40	88.00	36.50	0.00	0.00	0.00	126.50
Totals	11.28	\$704	\$308	\$0	\$0	\$0	\$1,012
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.51	84.00	41.50	0.00	0.00	0.00	125.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.60	90.00	44.00	0.00	0.00	0.00	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					0.00	EA
Unit values	1.70	94.00	47.00	0.00	0.00	0.00	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309805	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR					89.00	EA
Unit values	1.51	106.50	41.50	0.00	0.00	0.00	148.00
Totals	134.39	\$9,479	\$3,694	\$0	\$0	\$0	\$13,173
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.14	73.00	31.50	0.00	0.00	0.00	104.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309909	SUR FLUOR 1X4' W 2 32W T8					(qty)	EA
Unit values	1.14	86.00	31.50	0.00	0.00	0.00	117.50

PAGE 3-7.

27-Jul-94

## MeansData for Lotus

Page

	0.00	\$0	\$0	\$0	\$0	\$0	\$0
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309910	INDUSTRIAL FLUOR :X4' W 2 32W T8 TWO-PIECE REFLECTOR				29.00	EA	
Unit values	1.14	60.00	31.50	0.00	0.00		91 50
Totals	33.06	\$1,740	\$914	\$0	\$0		\$2,54
1661308041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY				(qty)	EA	
Unit values	0.13	14.50	3.44	0.00	0.00		17 94
Totals	0.00	\$0	\$0	\$0	\$0		\$0
1661308042	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT				2.00	EA	
Unit values	1.00	25.50	27.50	0.00	0.00		53 00
Totals	2.00	\$51	\$55	\$0	\$0		\$6

27-Jul-94

MeansData for Lotus

Page 4

Line #	Description						
	Manhours	Matl	Labor	Equipment	Sub	Total	
U16 ELECTRICAL	181	\$11,974	\$4,971		\$0	\$0	\$16,945
ESTIMATE TOTAL	242	\$11,974	\$6,640		\$0	\$0	\$18,614
SALES TAX	5.00%	\$599					
MATL MARKUP	-40.00%	(\$4,790)					
LABOR MARKUP	-13.40%		(\$890)				
EQUIPT MARKUP	0.00%			\$0		\$0	
SUB MARKUP	0.00%						
TOTAL BEFORE CONTINGENC		\$7,783	\$5,750		\$0	\$0	\$13,533
CONTINGENCY	10.00%						\$1,353
BOND	2.50%						\$338
PROFIT	10.00%						\$1,753
JOB TOTAL							\$16,578

27-Jul-94

KeansData for Lotus

Page:

Estimate: Bldg. 7133 Date: 8 July 1994  
 Description: Admin  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITWORK	61	\$0	\$1,669	\$0	\$0	\$1,669
U16 ELECTRICAL	161	\$11,974	\$4,971	\$0	\$0	\$16,945
<b>TOTAL</b>	<b>242</b>	<b>\$11,974</b>	<b>\$6,640</b>	<b>\$0</b>	<b>\$0</b>	<b>\$18,614</b>
SALES TAX	5.00%	\$599				
MATL MARKUP	-40.00%	(\$4,790)				
LABOR MARKUP	-13.40%		(\$890)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	3.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$7,763</b>	<b>\$5,750</b>	<b>\$0</b>	<b>\$0</b>	<b>\$13,533</b>
CONTINGENCY	10.00%					\$1,353
BOND	2.50%					\$338
<b>PROFIT</b>	<b>10.00%</b>					<b>\$1,353</b>
<b>JOB TOTAL</b>						<b>\$16,578</b>



## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

### INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

NUMBER OF:	7140
AREA:	RESTROOMS
LAMP USE:	3
HOURS/DAY:	—
WEEKS/WEK:	5
PEAK USE:	2 (1 YES, 2 NO)
SURGING VOLTING:	120

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARG \$0.1178 PER KW

EXISTING INCANDESCENTS	WATTS
LAMPS @ 32	4 WATTS
3 LAMPS @ 60	160 WATTS
1 LAMP @ 75	75 WATTS
1 LAMP @ 80	80 WATTS
1 LAMP @ 100	100 WATTS

COMPACT FLUORESCENT REPLACEMENT

3 LAMPS @ 13 WATTS	39 WATTS
0 LAMPS @ 18 WATTS	0 WATTS
6 LAMPS @ 26 WATTS	0 WATTS

BASELINE ENERGY CONSUMPTION	140 KWH
BASLINE DEMAND	500 MJ
	0.11 KW

ECO ENERGY CONSUMPTION

140 KWH	39 KWH
500 MJ	110 MJ
0.11 KW	0.04 KW

NET ENERGY SAVINGS	\$0 MVR
NET ENERGY SAVINGS	0.38 INSTVFR
	0.11 KW

NET DEMAND SAVINGS	\$0 MVR
NET DOLLAR SAVINGS	0.2 MVR



27-Jul-94

## MeansData for Lotus

Page

1

Estimate: Bldg. 7149 Date: 6 July 1994  
Description: Clinic  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City Index:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082121	DEMO, 2X4 FLUOR FIXTURES					129.00	
Unit values	0.49	0.00	13.35	0.00	0.00	0.00	13.35
Totals	62.57	\$0	\$1,722	\$0	\$0	\$0	\$1,722
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					9.00	
Unit values	0.26	0.00	7.10	0.00	0.00	0.00	7.10
Totals	2.32	\$0	\$64	\$0	\$0	\$0	\$64
302 SITEWCRK		65	\$0	\$1,786	\$0	\$0	\$1,786

PAGE 3.

27-Jul-94

MeansData for Lotus

Page

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S						
Unit values	0.94	26.74	22.52	0.00	(qty) 0.00	Ea. 49.26	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	
1661302300	SUR FLUOR STRIP 4' W 2 60W LAMP R S						
Unit values	1.00	28.65	23.62	0.00	(qty) 0.00	Ea. 52.47	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE						
Unit values	1.00	50.00	27.50	0.00	(qty) 0.00	Ea. 77.50	
Totals	6.00	\$300	\$165	\$0	\$0	\$465	
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8 ACRYLIC LENS						
Unit values	1.40	88.00	36.50	0.00	(qty) 0.00	Ea. 125.50	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.51	84.00	41.50	0.00	(qty) 0.00	Ea. 125.50	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS						
Unit values	1.60	90.00	44.00	0.00	(qty) 0.00	Ea. 134.00	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS						
Unit values	1.70	94.00	47.00	0.00	(qty) 0.00	Ea. 141.00	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	
1661309805	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR						
Unit values	1.81	106.50	41.83	0.00	(qty) 0.00	Ea. 148.00	
Totals	147.98	\$10,437	\$4,067	\$0	\$0	\$14,504	
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.14	73.00	31.50	0.00	(qty) 0.00	Ea. 104.50	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	
1661309807	REC FLUOR TROFFER 1X4' W 1 32W T8 ACRYLIC LENS/W REFLECTOR						
Unit values	1.14	89.00	31.50	0.00	(qty) 0.00	Ea. 121.50	

27-Jul-94

## MeansData for Lotus

Pag.

Totals	35.34	\$2,420	\$977	\$0	\$0	\$3,457
166139909	SUR FLUOR 1X4' W 2 32W T8					
Unit values	1.14	86.00	31.50	0.00	(qty) 0.00	EA 117.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0
166139910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR					
Unit values	1.14	80.00	31.50	0.00	(qty) 0.00	EA 121.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661398041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY					
Unit values	0.13	14.50	3.44	0.00	(qty) 0.00	EA 17.94
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661398042	COMP FLUOR FIX, 1 13 W PL WALL / CEILING MOUNT					
Unit values	1.00	20.50	27.50	0.00	3.00 0.00	EA \$0 48.00
Totals	3.00	\$62	\$83	\$0	\$0	\$145

27-JUL-94

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
J16 ELECTRICAL		193	\$13,279	\$5,292	\$0	\$0	\$18,571
ESTIMATE TOTAL		258	\$13,279	\$7,078	\$0	\$0	\$20,357
SALES TAX	5.00%		\$664				
MATL MARKUP	-40.00%		(\$5,312)				
LABOR MARKUP	-13.40%			(\$948)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$8,631	\$6,130	\$0	\$0	\$14,761
CONTINGENCY	10.00%						\$1,476
BOND	2.50%						\$369
PROFIT	10.00%						\$1,476
JOB TOTAL							\$18,082

27-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7149 Date: 9 July 1994  
 Description: Clinic  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
J02 SITWORK	65	\$0	\$1,786	\$0	\$0	\$1,786
J16 ELECTRICAL	193	\$13,279	\$5,292	\$0	\$0	\$18,571
<b>TOTAL</b>	<b>258</b>	<b>\$13,279</b>	<b>\$7,078</b>	<b>\$0</b>	<b>\$0</b>	<b>\$20,357</b>
SALES TAX	5.00%	\$664				
MATL MARKUP	-40.00%	(\$5,322)				
LABOR MARKUP	-13.40%		(\$548)			
EQUIPT MARKUP	0.00%			\$3		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$8,631</b>	<b>\$6,130</b>	<b>\$0</b>	<b>\$0</b>	<b>\$14,761</b>
CONTINGENCY	10.00%					\$1,476
BCND	2.50%					\$369
PROFIT	10.00%					\$1,476
<b>JOB TOTAL:</b>						<b>\$18,032</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: EXTERIOR / EXTERIOR LIGHTING

15 AUGUST 1984

INTERIOR LUMINARE: FLUORESCENT FIXTURES REPLACEMENT

BUILDING #: 7054  
AREA: OFFICE AREAS  
USE: HOURS/DAY 8  
DAYS/WEEK 5  
BUILDING VOLTAGE 110

ELECTRIC COSTS:  
ENERGY CHARGE \_\_\_\_\_  
DEMAND CHARGE \$1175 PER KW

## REPLACEMENT FIXTURE DATA

	2 FOOT	4 FOOT	6 FOOT	8 FOOT
2 FOOT	0 2 LAMP U			
4 FOOT	0 1 LAMP @ 0 WATTS			
6 FOOT	0 2 LAMP @ 0 WATTS			
8 FOOT	0 3 LAMP @ 0 WATTS			
	0 4 LAMP @ 0 WATTS			
NET DEMAND	125 WATTS	125 WATTS	125 WATTS	125 WATTS
NET ENERGY CONSUMPTION	4,118 kWh	4,118 kWh	4,118 kWh	4,118 kWh
NET DOLLAR SAVINGS	\$122 MTR	\$122 MTR	\$122 MTR	\$122 MTR
NET ENERGY SAVINGS	6,754 kWh	6,754 kWh	6,754 kWh	6,754 kWh
NET DOLLAR SAVINGS	\$167 MTR	\$167 MTR	\$167 MTR	\$167 MTR

FORT CAMPBELL LIGHTING SURVEY	
ECO 1: INTERIOR / EXTERIOR LIGHTING	
19 AUGUST 1994	
BUILDING #: 7154	OFFICES/SHOP AREAS
AREA:	ELECTRIC COSTS: ENERGY CHARGE \$0.0211 PER KWH DEMAND CHARG \$11.76 PER KW
LAMP USE: HOURS/DAY 6 DAYS/WEEK 5 PEAK USE 1 (1-YES, 2-NO)	INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT
BUILDING VOLTAGE 120	FLUORESCENT FIXTURE REPLACEMENT: 4 FOOT 25.2 LAMP @ .15 W/FCT = 1354 WATTS
EXISTING INCANDESCENT # LAMPS @ 200 WATTS = 1300 WATTS	ECO ENERGY CONSUMPTION 24.3W KWH 105.3W MJ 12.68 KWH
BASELINE ENERGY CONSUMPTION BASELINE DEMAND	ECO DEMAND 2.775 KWH 9.389 MJ 1.23 KW
NET ENERGY SAVINGS NET ENERGY SAVINGS	NET DEMAND SAVINGS \$1,762/YR NET DOLLAR SAVINGS \$2,318/YR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

ADDRESS:	7184 RESTROOM
LAMP USE:	3
HOURS/DAY:	5
DAY/WEEK:	2 (M-F, 240)
PEAK USE:	
BUILDING VOLTA:	120

ELECTRIC COSTS:	<u>.00 .0211</u>	PER KWH
ENERGY CHARGE:	<u>.11 .78</u>	PER KW
Demand Charge:		

COMPACT FLUORESCENT REPLACEMENT	
LAMPS:	13 WATT = 0 WATTS
LAMPS:	0 LAMPS = 0 WATTS
LAMPS:	13 WATT = 0 WATTS
LAMPS:	3 LAMPS = 75 WATTS
LAMPS:	0 WATTS = 0 WATTS
LAMPS:	240 WATTS = 240 WATTS
3 LAMPS:	0 WATTS = 0 WATTS

BASLINE ENERGY CONSUMPTION:	389 KWH	ECO ENERGY CONSUMPTION:	63 KWH
BASLINE ENERGY CONSUMPTION:	1,065 KJ	ECO ENERGY CONSUMPTION:	219 KJ
BASLINE ENERGY CONSUMPTION:	1.38 KW	ECO DEMAND:	0.58 KW
		NET DEMAND SAVINGS:	50 KW
		NET DOLLAR SAVINGS:	\$9 /HR
		NET ENERGY SAVINGS:	389 KWH
		NET ENERGY SAVINGS:	\$9 /HR

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7154 Date: 8 July 1994  
Description: Hangar  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082121	DEMO, 2x4 FLUOR FIXTURES					31.00	
Unit values	0.49	0.00	13.35	0.00	0.00	0.00	13.3
Totals	15.04	\$0	\$48.4	\$0	\$0	\$0	\$48.4
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					72.00	
Unit values	0.26	0.00	7.10	0.00	0.00	0.00	7.1
Totals	18.58	\$0	\$52.1	\$0	\$0	\$0	\$52.1
U02 SIZENWORK		34	\$0	\$925	\$0	\$0	\$925

27-Jul-94

## MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S						
Unit values	0.94	26.74	22.52	0.00	0.00	(qty) Ea.	
Totals	0.00	\$0	\$0	\$0	\$0		49.26
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S						
Unit values	1.00	28.65	23.82	0.00	0.00	(qty) Ea.	
Totals	0.00	\$0	\$0	\$0	\$0		52.47
1661307001	LOW BAY, AL REFLECTOR 50W HPS						
Unit values	2.00	209.00	55.00	0.00	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0		264.00
1661307777	L.E.D. EXIT SIGN SINGLE FACE						
Unit values	1.00	185.00	27.50	0.00	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0		212.50
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS						
Unit values	1.40	88.00	38.50	0.00	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0		126.50
1661309803	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.51	84.00	41.50	0.00	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0		125.50
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS						
Unit values	1.60	90.00	44.00	0.00	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0		134.00
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS						
Unit values	1.70	94.00	47.00	0.00	0.00	(qty) EA	
Totals	6.80	\$376	\$138	\$0	\$0		141.00
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.14	73.00	31.50	0.00	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0		104.50
1661309909	SUR FLUOR 1X4' W 2 32W T8						
Unit values	1.14	86.00	31.50	0.00	0.00	(qty) EA	
							117.50

PAGE 3-94

27-Jul-94

## MeansData for Lotus

Page

Totals	30.78	\$2,322	\$851	\$0	\$0	\$3 173
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR				23.00	EA
Unit values	1.14	60.00	31.50	0.00	0.00	91.50
Totals	26.22	\$1,380	\$725	\$0	\$0	\$2,105
1661368041	COMP FLUOR LAMP, 26W TUBE GLOBE ASSEMBLY				3.00	EA
Unit values	0.13	25.50	3.44	0.00	0.00	28.94
Totals	0.38	\$77	\$10	\$0	\$0	\$87
1661388042	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT				(Qty)	EA
Unit values	1.00	25.50	27.50	0.00	0.00	53.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0

27-Jul-94

MeansData for Lotus

Page

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		65	\$4,155	\$1,774		\$0	\$5,929
ESTIMATE TOTAL		99	\$4,155	\$2,699		\$0	\$6,854
SALES TAX	5.00%		\$208				
MATL MARKUP	-40.00%		(\$1,662)				
LABOR MARKUP	-13.40%			(\$362)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY		\$2,731	\$2,337		\$0	\$0	\$5,038
CONTINGENCY	10.00%						\$504
BOND	2.50%						\$126
PROFIT	10.00%						\$504
JCB TOTAL							\$6,172

PAGE 3.

27-Jul-94

## MeansData for Lotus

Pa

Estimate: Bldg. 7154 Date: 8 July 1994  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
J02 SITWORK	34	\$0	\$325	\$0	\$0	\$92
J16 ELECTRICAL	65	\$4,155	\$1,774	\$0	\$0	\$5,92
<b>TOTAL</b>	<b>99</b>	<b>\$4,155</b>	<b>\$2,699</b>	<b>\$0</b>	<b>\$0</b>	<b>\$6,85</b>
SALES TAX	5.00%	\$209				
MATL MARKUP	-40.00%	(-\$1,662)				
LABOR MARKUP	-13.40%		(-\$362)			
EQUIP MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$2,701	\$2,337	\$0	\$0	\$5,038
CONTINGENCY	10.00%					\$504
BOND	2.50%					\$126
PROFIT	10.00%					\$504
<b>JOB TOTAL</b>						<b>\$6,17</b>

PAGE 3.

# FORT CAMPBELL LIGHTING SURVEY

ECO #: INTERIOR / EXTERIOR LIGHTING

10 AUGUST 1984

## INTERIOR LIGHTING: FLUORESCENT FURNITURE REPLACEMENT

BUILDING #: 7150

OFFICE AREAS

AVERAGE USE  
COURTDAY  
DAYS/YEAR

FLUORESCENT VOLTAGE

120

ELECTRIC COSTS  
ENERGY CHARGE  
DEMAND CHARGE

\$0.0711 PER KWH

\$11.70 PER KW

### EXISTING FURNITURE DATA

FOOT	2 LAMP @	90 WATT @	9 WATT
------	----------	-----------	--------

FOOT	1 LAMP @	45 WATT @	9 WATT
	2 LAMP @	90 WATT @	9 WATT
	3 LAMP @	135 WATT @	9 WATT
	4 LAMP @	180 WATT @	9 WATT

REPLACEMENT FURNITURE DATA

2 FOOT 9 2 LAMP U @ 90 WATT @ 9 WATT

FOOT	1 LAMP @	29 WATT @	9 WATT
	2 LAMP @	58 WATT @	9 WATT
	3 LAMP @	87 WATT @	9 WATT
	4 LAMP @	116 WATT @	9 WATT

FOOT	1 LAMP @	29 WATT @	9 WATT
	2 LAMP @	58 WATT @	9 WATT
	3 LAMP @	87 WATT @	9 WATT
	4 LAMP @	116 WATT @	9 WATT

FOOT	1 LAMP @	29 WATT @	9 WATT
	2 LAMP @	58 WATT @	9 WATT
	3 LAMP @	87 WATT @	9 WATT
	4 LAMP @	116 WATT @	9 WATT

FOOT	1 LAMP @	29 WATT @	9 WATT
	2 LAMP @	58 WATT @	9 WATT
	3 LAMP @	87 WATT @	9 WATT
	4 LAMP @	116 WATT @	9 WATT

NET DEMAND SAVINGS  
NET DOLLAR SAVINGS

\$608 PER  
\$552 PER

26,368 DOLLAR  
24,388 DOLLAR

NET ENERGY SAVINGS  
NET ENERGY SAVINGS

# FORT CAMPBELL LIGHTING SURVEY

ECHO 1: MATERIAZIONI / ECOLOGIE

New Germany 61

WILHELM WIEBOLD UND SEIN WERK

**ELECTRIC COSTS.**      **4¢R/kWh**  
**ENERGY CHARGE** **30.8211**      **PER KW**  
**DEMAND CHARG** **\$11.70**

TESTING FLUORESCENTS	WATTS								
12 LAMPS @ 13 WATTS =	152	132	112	92	72	52	32	12	0 WATTS
13 LAMPS @ 12 WATTS =	162	142	122	102	82	62	42	22	0 WATTS
14 LAMPS @ 11 WATTS =	172	152	132	112	92	72	52	32	0 WATTS
15 LAMPS @ 10 WATTS =	182	162	142	122	102	82	62	42	0 WATTS
16 LAMPS @ 9 WATTS =	192	172	152	132	112	92	72	52	0 WATTS
17 LAMPS @ 8 WATTS =	202	182	162	142	122	102	82	62	0 WATTS
18 LAMPS @ 7 WATTS =	212	192	172	152	132	112	92	72	0 WATTS
19 LAMPS @ 6 WATTS =	222	202	182	162	142	122	102	82	0 WATTS
20 LAMPS @ 5 WATTS =	232	212	192	172	152	132	112	92	0 WATTS
21 LAMPS @ 4 WATTS =	242	222	202	182	162	142	122	102	0 WATTS
22 LAMPS @ 3 WATTS =	252	232	212	192	172	152	132	112	0 WATTS
23 LAMPS @ 2 WATTS =	262	242	222	202	182	162	142	122	0 WATTS
24 LAMPS @ 1 WATT =	272	252	232	212	192	172	152	132	0 WATTS
25 LAMPS @ .5 WATT =	282	262	242	222	202	182	162	142	0 WATTS

NET DEMAND SAVINGS	9.465 MWhr	1.21 MWhr	NET DOLLAR SAVINGS	\$9 MRR
ECO ENERGY CONSUMPTION	646 MWhr	83 MWhr	ECO DEMAND	9.75 MWhr
ECO DEMAND	9.75 MWhr	1.21 MWhr	ECO ENERGY CONSUMPTION	646 MWhr
ECO DEMAND	9.75 MWhr	1.21 MWhr	ECO ENERGY CONSUMPTION	646 MWhr
ECO DEMAND	9.75 MWhr	1.21 MWhr	ECO ENERGY CONSUMPTION	646 MWhr

PAGE 39!

27-JUL-94

## MeansData for Lotus

Page

Estimate: Bldg. 7153 Date: 8 July 1994  
 Description: OFFICE AREA  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
0207082121	DEMO. 2x4 FLUOR FIXTURES						
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	13.52	\$0	\$427	\$0	\$0	\$427	
0207082123	DEMO. INCAND FIXTURES / EXIT SIGNS						
Unit values	0.26	0.00	7.10	0.00	0.00	7.10	
Totals	1.81	\$0	\$50	\$0	\$0	\$50	
002 SITEWORK		15	\$0	\$477	\$0	\$0	\$477

PAGE 3-10X

27-Jul-94

## MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty)	EA.
Unit values	0.94	26.74	22.52	0.00	0.00	\$0	49.26
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty)	EA.
Unit values	1.03	28.65	22.82	0.00	0.00	\$0	52.47
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661307001	LOW BAY, AL REFLECTOR 50W HPS					0.00	EA
Unit values	2.00	209.00	55.00	0.00	0.00	\$0	264.00
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661307777	L.E.D. EXIT SIGN SINGLE FACE					(qty)	EA
Unit values	1.00	185.00	27.50	0.00	0.00	\$0	212.50
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					(qty)	EA
Unit values	1.40	88.00	38.50	0.00	0.00	\$0	126.50
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.51	84.00	42.50	0.00	0.00	\$0	125.50
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.63	90.00	44.00	0.00	0.00	\$0	134.00
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					0.00	EA
Unit values	1.70	94.00	47.00	0.00	0.00	\$0	141.00
Totals	0.00	\$0	\$0	0.00	0.00	\$0	\$0
1661309805	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR					32.00	EA
Unit values	1.51	106.50	42.50	0.00	0.00	\$0	148.00
Totals	48.32	\$3,468	\$1,328	0.00	0.00	\$0	\$4,736
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.34	73.00	32.50	0.00	0.00	\$0	104.50

27-Jul-94

## MeansData for Lotus

Page

	0.30	\$0	\$0	\$0	\$0	\$0	\$0
Totals	0.30	\$0	\$0	\$0	\$0	\$0	\$0
1661309909	SUR FLUOR 1X4' X 2 32W T8						
Unit values	1.14	86.00	31.50	0.00	0.00	EA	
Totals	0.00	\$0	\$0	\$0	0.00	117.50	\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR						
Unit values	1.14	90.00	31.50	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00	121.50	\$0
1661388041	COMP FLUOR LAMP, 26W TUBE GLOBE ASSEMBLY						
Unit values	0.13	25.50	3.44	0.00	7.00	EA	
Totals	0.88	\$179	\$24	\$0	0.00	25.94	\$203
1661388042	COMP FLUOR FIX. 2 13 W PL WALL / CEILING MOUNT						
Unit values	1.00	25.50	27.50	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00	53.00	\$0

27-Jul-94

MeansData for Lotus

Page

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		50	\$3,587	\$1,352	\$0	\$0	\$6,939
ESTIMATE TOTAL		68	\$3,587	\$1,825	\$0	\$0	\$5,416
SALES TAX	5.00%		\$179				
MATL MARKUP	+40.00%		(\$1,435)				
LABOR MARKUP	+13.40%			(\$245)			
EQUIP MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$2,332	\$1,584	\$0	\$0	\$3,915
CONTINGENCY	10.00%						\$392
BCND	2.50%						\$98
PROFIT	10.00%						\$392
JOB TOTAL							\$4,796

27-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7155 Date: 8 July 1994  
 Description: OFFICE AREA  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
J02 SITENWORK	18	\$0	\$477	\$0	\$0	\$477
U16 ELECTRICAL	50	\$3,587	\$1,352	\$0	\$0	\$4,939
<b>TOTAL</b>	<b>68</b>	<b>\$3,587</b>	<b>\$1,829</b>	<b>\$0</b>	<b>\$0</b>	<b>\$5,416</b>
SALES TAX	5.00%	\$179				
MATL MARKUP	-40.00%	(\$1,435)				
LABOR MARKUP	-13.40%		(\$245)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$2,332</b>	<b>\$1,584</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,915</b>
CONTINGENCY	10.00%					\$392
BOND	2.50%					\$98
PROFIT	10.00%					\$392
<b>JOB TOTAL</b>						<b>\$4,796</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO & INTERIOR / EXTERIOR LIGHTING

14 ALICHT 1994

INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 738  
AREA: SHOTGUN STORAGE AREAS  
AVERAGE USE: 8  
COURSES/DAY: 5  
DAYS/WEK: 5  
BUILDING VOLTAGE: 120

INTERIOR FIXTURE DATA  
3 FOOT 2 LAMP U 80 WATT 0 WATTS  
4 FOOT 2 LAMP U 80 WATT 0 WATTS  
5 FOOT 2 LAMP U 80 WATT 0 WATTS  
6 FOOT 2 LAMP U 80 WATT 0 WATTS  
7 FOOT 2 LAMP U 80 WATT 0 WATTS  
8 FOOT 2 LAMP U 80 WATT 0 WATTS  
9 FOOT 2 LAMP U 80 WATT 0 WATTS  
10 FOOT 2 LAMP U 80 WATT 0 WATTS

ELECTRIC COSTS  
ENERGY CHARGE 30.0211 PER kWh  
DEMAND CHARGE \$11.78 PER kW

INTERIOR ENERGY CONSUMPTION	2000 kWhr	4000 kWhr	6000 kWhr	8000 kWhr	10000 kWhr
NET ENERGY SAVINGS	10,452 kWhr	20,904 kWhr	31,356 kWhr	41,808 kWhr	52,260 kWhr
NET ENERGY SAVINGS	9.02 kWhr				

REPLACEMENT FIXTURE DATA	2 FOOT 0.2 LAMP U 0 WATT 0 WATTS	4 FOOT 0.2 LAMP U 0 WATT 0 WATTS	6 FOOT 0.2 LAMP U 0 WATT 0 WATTS	8 FOOT 0.2 LAMP U 0 WATT 0 WATTS	10 FOOT 0.2 LAMP U 0 WATT 0 WATTS
NET DOLLAR SAVINGS	\$718 /yr				
NET DOLLAR SAVINGS	\$237 /yr				

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
19 AUGUST 1984

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #:	7186
AREA:	OFFICE AREAS
LAMP USE:	8
WEEKDAY	5
DAY/NIGHT	1 (1-MON. 2-FRI)
PEAK USE	
BUILDING VOLTAG:	120

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KW/H  
DEMAND CHARGE \$11.78 PER KW

INCANDESCENT LIGHTING REPLACEMENT - 4 FOOT	
36 2 LAMP @ 50 WATTS =	1740 WATTS
36 2 LAMP @ 50 WATTS X .95	1740 WATTS
ECO ENERGY CONSUMPTION	
37,380 KWH	3,619 KWH
123,296 MJ	12,629 MJ
177.8 KW	1.74 KW
ECO DEMAND	
NET DEMAND SAVINGS	\$2,270 MYR
NET DOLLAR SAVINGS	\$2,973 MYR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #:	7155
AREA:	RESTROOMS
LAMP USE:	3
HOURS/DAY:	5
1/3-YEAR WEEK:	3
PEAK USE:	2 (1-YEARS, 2-AON)
BUILDING VOLTA:	120

ELECTRIC COSTS:	
ENERGY CHARGE	\$0.0211 PER KWH
DEMAND CHARGE	\$11.78 PER KW

EXISTING:	3 DECEMPS	22 WATTS	6 WATTS
L.	3 @	60 WATTS	6 WATTS
LAMP 1 @	60 WATTS	6 WATTS	6 WATTS
LAMP 2 @	75 WATTS	0 WATTS	0 WATTS
LAMP 3 @	60 WATTS	0 WATTS	0 WATTS
LAMP 4 @	60 WATTS	0 WATTS	0 WATTS
3 LAMP @	200 WATTS	0 WATTS	0 WATTS

COMPACT FLUORESCENT REPLACEMENT		
6 LAMPS @	13 WATTS =	9 WATTS
9 LAMPS @	18 WATTS =	9 WATTS
3 LAMPS @	26 WATTS =	7.5 WATTS

BASELINE ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

0.38 KW

ECO DEMAND

0 KWH

0 MJ

0 KW

ECO ENERGY CONSUMPTION

480 KWH

1,092 MJ

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7156 Date: 8 July 1994  
Description: Hangar  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082121	DEMO, 2x4 FLUOR FIXTURES					45.00	
Unit values	0.49	0.00	13.35	0.00	0.00	0.00	13.35
Totals	21.83	\$0	\$601	\$0	\$0	\$0	\$601
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					92.00	
Unit values	0.26	0.00	7.10	0.00	0.00	0.00	7.10
Totals	23.74	\$0	\$653	\$0	\$0	\$0	\$653
U02 SITENWORK		46	\$0	\$1,254	\$0	\$0	\$1,254

27-Jul-94

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty)	Ea.
Unit values	0.94	26.74	22.52	0.00	0.00	\$0	49.26
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty)	Ea.
Unit values	1.00	28.65	23.82	0.00	0.00	\$0	52.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661307001	LOW BAY, AL REFLECTOR 50W HPS					0.00	EA
Unit values	2.00	209.00	55.00	0.00	0.00	\$0	264.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN SINGLE FACE					(qty)	EA
Unit values	1.00	185.00	27.50	0.00	0.00	\$0	212.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					(qty)	EA
Unit values	1.40	88.00	38.50	0.00	0.00	\$0	126.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					30.00	EA
Unit values	1.51	84.00	41.50	0.00	0.00	\$0	125.50
Totals	48.30	\$2,520	\$1,245	\$0	\$0	\$0	\$3,765
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.60	90.00	44.00	0.00	0.00	\$0	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.70	94.00	47.00	0.00	0.00	\$0	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.14	73.00	31.50	0.00	0.00	\$0	104.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309909	SUR FLUOR 1X4' W 2 32W T8					40.00	EA
Unit values	1.14	86.00	31.50	0.00	0.00	\$0	117.50

27-JUL-94

## MeansData for Lotus

Pag

Totals	45.60	\$3,440	\$1,260	\$0	\$0	\$4,700
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8. TWO-PIECE REFLECTOR				(qty)	EA
Unit values	1.14	60.00	31.50	0.00	0.00	91.50
Totals	6.00	\$0	\$0	\$0	\$0	\$0
1661309911	SLR FLUOR 2X4' W 2 32W T8					
Unit values	1.29	95.00	35.50	0.00	0.00	130.50
Totals	2.58	\$190	\$71	\$0	\$0	\$261
1661309913	SUR FLUOR 2X4' W 4 32W T8					
Unit values	1.51	117.00	41.50	0.00	0.00	158.50
Totals	4.53	\$351	\$125	\$0	\$0	\$476
1661388041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY				(qty)	EA
Unit values	0.13	14.50	3.44	0.00	0.00	17.94
Totals	6.00	\$0	\$0	\$0	\$0	\$0
1661388042	COMP FLUOR FIX, 3 26 W PL WALL / CEILING MOUNT					
Unit values	1.00	30.50	27.50	0.00	0.00	58.00
Totals	1.00	\$31	\$28	\$0	\$0	\$59

27-JUL-94

MeansData for Lotus

PR:

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
UL6 ELECTRICAL	100	\$6,532	\$2,729	\$0	\$0	\$0	\$9,261
ESTIMATE TOTAL	146	\$6,532	\$3,983	\$0	\$0	\$0	\$10,515
SALES TAX	5.00%	\$327					
MATL MARKUP	.40.00%	(\$2,613)					
LABOR MARKUP	.13.40%		(\$534)				
EQUIPT MARKUP	0.00%			\$0		\$0	
SUB MARKUP	0.00%						
TOTAL BEFORE CONTINGENCY		\$4,246	\$3,449	\$0	\$0	\$0	\$7,694
CONTINGENCY	10.00%						\$774
BOND	2.50%						\$193
PROFIT	50.00%						\$770
JOB TOTAL							\$9,421

27-Jul-94

MeansData for lotus

Page

Estimate: Bldg. 7156 Date: 8 July 1994  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
UC2 SITEWORK	46	\$0	\$1,254	\$0	\$0	\$1,254
U16 ELECTRICAL	100	\$6,532	\$2,729	\$0	\$0	\$9,261
<b>TOTAL</b>	<b>146</b>	<b>\$6,532</b>	<b>\$3,983</b>	<b>\$0</b>	<b>\$0</b>	<b>\$10,515</b>
SALES TAX	5.00%	\$327				
MATL MARKUP	-40.00%	(\$2,613)				
LABOR MARKUP	-13.40%		(\$534)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$4,246</b>	<b>\$3,449</b>	<b>\$0</b>	<b>\$0</b>	<b>\$7,695</b>
CONTINGENCY	10.00%					\$770
BOND	2.50%					\$192
PROFIT	10.00%					\$770
<b>JOB TOTAL</b>						<b>\$9,426</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

LOCATION: 1000  
OFFICE/COMMON AREA.

AREA:  
HEADLINE  
HOURS/DAY  
DAYS/MONTH

INDUCED VOL. /AGE: 120V  
10 years

EXISTING FIXTURE DATA

2' FOOT 2 LAMP U • 10 WATT • 0 WATTS

2' FOOT	2 LAMP @	10 WATT =	0 WATTS
1 LAMP @	as w Watt	0 WATTS	0 WATTS
2 LAMP @	as w Watt	20 WATTS	20 WATTS
3 LAMP @	as w Watt	30 WATTS	30 WATTS
4 LAMP @	as w Watt	40 WATTS	40 WATTS
		WIRE REFLECTOR	WIRE REFLECTOR

8' FOOT	2 LAMP @	125 WATT =	0 WATTS
1 LAMP @	as w Watt	0 WATTS	0 WATTS
2 LAMP @	as w Watt	25 WATTS	25 WATTS
3 LAMP @	as w Watt	37.5 WATTS	37.5 WATTS
4 LAMP @	as w Watt	50 WATTS	50 WATTS
		WIRE REFLECTOR	WIRE REFLECTOR

12' FOOT	2 LAMP @	125 WATT =	0 WATTS
1 LAMP @	as w Watt	0 WATTS	0 WATTS
2 LAMP @	as w Watt	25 WATTS	25 WATTS
3 LAMP @	as w Watt	37.5 WATTS	37.5 WATTS
4 LAMP @	as w Watt	50 WATTS	50 WATTS
		WIRE REFLECTOR	WIRE REFLECTOR

NET DEMAND SAVINGS	8638 MYR
NET DOLLAR SAVINGS	2035 MYR

PAGE 3-113

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1992

### INTERIOR LIGHTING - INCANDESCENT LAMP REPLACEMENT

BUILDING #:	710	
AREA:	LAMP LOC.	
LAMP LOC.	MONDAY	8
MONDAY	TUESDAY	5
DAY/ WEEK	WEDNESDAY	3
DAY/ WEEK	THURSDAY	1
DAY/ WEEK	FRIDAY	2
DAY/ WEEK	SATURDAY	0
DAY/ WEEK	SUNDAY	0
VOLTAG	120	

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.76 PER KW

NUMBER OF LAMPS	WATTS	WATTS
1	22	0
1	60	0
1	75	0
1	80	0
16	100	1000

COMPACT FLUORESCENT REPLACEMENT  
13 WATTS = 0 WATTS  
16 WATTS = 0 WATTS  
20 WATTS = 260 WATTS

NET DEMAND CONSUMPTION	KWH	KWH
2,000 KWH	7,680 KWH	1,367 KWH
1,400 KWH	5,200 KWH	6,250 KWH

NET ENERGY SAVINGS	KWH	KWH
6,541 KWH	6,205 KWH	137 KWH
6,205 KWH	5,200 KWH	0 KWH

NET DOLLAR SAVINGS	\$	\$
\$137 KWH	\$105 KWH	\$137 KWH

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7159 Date: 8 July 1994  
Description: OFFICE/CCNF AREA  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description					
		Manhours	Matl	Labor	Equipment	Sub Total
C207082121	DENO, 2X4 FLUOR FIXTURES					
Unit values	0.49	0.00	13.35	0.00	0.00	13.35
Totals	30.07	\$0	\$820	\$0	\$0	\$820
C207082123	DENO, INCAND FIXTURES / EXIT SIGNS					
Unit values	0.26	0.00	7.10	0.00	0.00	7.10
Totals	2.58	\$0	\$71	\$0	\$0	\$71
U02 SITEWORK		33	\$0	\$899	\$0	\$899

27-Jul-94

## MeansData for Lotus

Page :

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty)	Ea.
Unit values	0.94	26.74	22.52	0.00	0.00	\$0	49.26
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty)	Ea.
Unit values	2.00	28.65	23.82	0.00	0.00	\$0	52.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN SINGLE FACE					(qty)	EA
Unit values	1.00	185.00	27.50	0.00	0.00	\$0	212.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-C ACRYLIC LENS					(qty)	EA
Unit values	1.40	88.00	38.50	0.00	0.00	\$0	126.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 1 32W T8 ACRYLIC LENS W REFLECTOR					42.00	EA
Unit values	1.51	84.00	41.50	0.00	0.00	\$0	125.50
Totals	63.42	\$3,528	\$1,743	\$0	\$0	\$0	\$3,271
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.60	90.00	44.00	0.00	0.00	\$0	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					0.00	EA
Unit values	1.70	94.00	47.00	0.00	0.00	\$0	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309805	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR					20.00	EA
Unit values	1.51	106.50	41.50	0.00	0.00	\$0	148.00
Totals	30.20	\$2,130	\$830	\$0	\$0	\$0	\$2,960
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.14	73.00	31.50	0.00	0.00	\$0	104.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309909	SUR FLUOR 1X4' W 2 32W T8					0.00	EA
Unit values	1.14	86.00	31.50	0.00	0.00	\$0	117.50

	27-Jul-94	MeansData for Lotus					Page
<b>Totals</b>	0.00	\$0	\$0	\$0	\$0	\$0	
1661309510	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR				(qty)	EA	
Unit values	1.14	90.00	31.50	0.00	0.00		121.50
<b>Totals</b>	0.00	\$0	\$0	\$0	\$0	\$0	
1661389040	COMP FLUOR LAMP, 26 W QUAD				10.00	EA	
Unit values	0.50	10.50	13.75	0.00	0.00		24.25
<b>Totals</b>	5.00	\$105	\$138	\$0	\$0	\$0	\$243
1661389041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY				(qty)	EA	
Unit values	0.13	14.50	3.44	0.00	0.00		17.94
<b>Totals</b>	0.00	\$0	\$0	\$0	\$0	\$0	

27-Jul-94

## MeansData for Lotus

Page

Line #	Description							
		Manhours	Matl	Labor	Equipment	Sub	Total	
C16 ELECTRICAL	99	\$5,763		\$2,711		\$0	\$0	\$5,474
ESTIMATE TOTAL	132	\$5,763		\$3,610		\$0	\$0	\$9,373
SALES TAX	5.00%		\$286					
MATL MARKUP	-40.00%		(-\$2,305)					
LABOR MARKUP	-13.40%			(\$484)				
EQUIPT MARKUP	0.00%				\$0			
SUB MARKUP	0.00%					\$0		
TOTAL BEFORE CONTINGENCY		\$3,746		\$3,126		\$0	\$0	\$6,872
CONTINGENCY	10.00%							\$687
BOND	2.50%							\$172
PROFIT	10.00%							\$687
JOB TOTAL								\$8,418

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7159 Date: 8 July 1994  
 Description: OFFICE/CONF AREA  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
002 SITWORK	33	\$0	\$299	\$0	\$0	\$299
016 ELECTRICAL	99	\$5,763	\$2,711	\$0	\$0	\$8,474
<b>TOTAL</b>	<b>132</b>	<b>\$5,763</b>	<b>\$3,610</b>	<b>\$0</b>	<b>\$0</b>	<b>\$9,373</b>
SALES TAX	5.00%	\$288				
MATL MARKUP	-40.00%	(\$2,305)				
LABOR MARKUP	-13.40%		(-\$456)			
EQUIPT MARKUP	0.00%			\$0	\$0	
STB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$3,746</b>	<b>\$3,126</b>	<b>\$0</b>	<b>\$0</b>	<b>\$6,872</b>
CONTINGENCY	10.00%					\$687
BOND	2.50%					\$172
<b>PROFIT</b>	<b>10.00%</b>					<b>\$687</b>
<b>JOB TOTAL</b>						<b>\$8,418</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
19 AUGUST 1984

### INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7100  
AREA: SLEEPING AREA  
MEALTIME HOURS/DAY: 16  
DAY/WEEK: 7  
BUILDING VOLTAGE: 120

### EXTERIOR FIXTURE DATA

2 FOOT	2 LAMP U	0 WFTXT =	0 WATTS
4 FOOT	1 LAMP G	0 WFTXT =	0 WATTS
4 FOOT	2 LAMP G	0 WFTXT =	20 WATTS
4 FOOT	3 LAMP G	0 WFTXT =	30 WATTS
4 FOOT	4 LAMP G	0 WFTXT =	40 WATTS

1 FOOT 2 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 3 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 4 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 5 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 6 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 7 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 8 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 9 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 10 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 11 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 12 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 13 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 14 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 15 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 16 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 17 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 18 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 19 LAMP G 0 WFTXT = 0 WATTS

1 FOOT 20 LAMP G 0 WFTXT = 0 WATTS

### REPLACEMENT FIXTURE DATA

2 FOOT	0 2 LAMP U	50 WFTXT =	0 WATTS
4 FOOT	0 1 LAMP G	20 WFTXT =	0 WATTS
4 FOOT	0 2 LAMP G	50 WFTXT =	30 WATTS
4 FOOT	0 3 LAMP G	87 WFTXT =	45 WATTS
4 FOOT	0 4 LAMP G	118 WFTXT =	60 WATTS

1 FOOT 0 2 LAMP U 50 WFTXT = 0 WATTS

1 FOOT 0 1 LAMP G 20 WFTXT = 0 WATTS

1 FOOT 0 2 LAMP G 50 WFTXT = 30 WATTS

1 FOOT 0 3 LAMP G 87 WFTXT = 45 WATTS

1 FOOT 0 4 LAMP G 118 WFTXT = 60 WATTS

1 FOOT 0 5 LAMP G 155 WFTXT = 75 WATTS

1 FOOT 0 6 LAMP G 182 WFTXT = 90 WATTS

1 FOOT 0 7 LAMP G 210 WFTXT = 105 WATTS

1 FOOT 0 8 LAMP G 238 WFTXT = 120 WATTS

1 FOOT 0 9 LAMP G 266 WFTXT = 135 WATTS

1 FOOT 10 LAMP G 294 WFTXT = 150 WATTS

1 FOOT 11 LAMP G 322 WFTXT = 165 WATTS

1 FOOT 12 LAMP G 350 WFTXT = 180 WATTS

1 FOOT 13 LAMP G 378 WFTXT = 195 WATTS

1 FOOT 14 LAMP G 406 WFTXT = 210 WATTS

1 FOOT 15 LAMP G 434 WFTXT = 225 WATTS

1 FOOT 16 LAMP G 462 WFTXT = 240 WATTS

1 FOOT 17 LAMP G 490 WFTXT = 255 WATTS

1 FOOT 18 LAMP G 518 WFTXT = 270 WATTS

1 FOOT 19 LAMP G 546 WFTXT = 285 WATTS

1 FOOT 20 LAMP G 574 WFTXT = 300 WATTS

1 FOOT 0 5 LAMP G 155 WFTXT = 75 WATTS

1 FOOT 0 6 LAMP G 182 WFTXT = 90 WATTS

1 FOOT 0 7 LAMP G 210 WFTXT = 105 WATTS

1 FOOT 0 8 LAMP G 238 WFTXT = 120 WATTS

1 FOOT 0 9 LAMP G 266 WFTXT = 135 WATTS

1 FOOT 0 10 LAMP G 294 WFTXT = 150 WATTS

1 FOOT 0 11 LAMP G 322 WFTXT = 165 WATTS

1 FOOT 0 12 LAMP G 350 WFTXT = 180 WATTS

1 FOOT 0 13 LAMP G 378 WFTXT = 195 WATTS

1 FOOT 0 14 LAMP G 406 WFTXT = 210 WATTS

1 FOOT 0 15 LAMP G 434 WFTXT = 225 WATTS

1 FOOT 0 16 LAMP G 462 WFTXT = 240 WATTS

1 FOOT 0 17 LAMP G 490 WFTXT = 255 WATTS

1 FOOT 0 18 LAMP G 518 WFTXT = 270 WATTS

1 FOOT 0 19 LAMP G 546 WFTXT = 285 WATTS

1 FOOT 0 20 LAMP G 574 WFTXT = 300 WATTS

1 FOOT 0 5 LAMP G 155 WFTXT = 75 WATTS

1 FOOT 0 6 LAMP G 182 WFTXT = 90 WATTS

1 FOOT 0 7 LAMP G 210 WFTXT = 105 WATTS

1 FOOT 0 8 LAMP G 238 WFTXT = 120 WATTS

1 FOOT 0 9 LAMP G 266 WFTXT = 135 WATTS

1 FOOT 0 10 LAMP G 294 WFTXT = 150 WATTS

1 FOOT 0 11 LAMP G 322 WFTXT = 165 WATTS

1 FOOT 0 12 LAMP G 350 WFTXT = 180 WATTS

1 FOOT 0 13 LAMP G 378 WFTXT = 195 WATTS

1 FOOT 0 14 LAMP G 406 WFTXT = 210 WATTS

1 FOOT 0 15 LAMP G 434 WFTXT = 225 WATTS

1 FOOT 0 16 LAMP G 462 WFTXT = 240 WATTS

1 FOOT 0 17 LAMP G 490 WFTXT = 255 WATTS

1 FOOT 0 18 LAMP G 518 WFTXT = 270 WATTS

1 FOOT 0 19 LAMP G 546 WFTXT = 285 WATTS

1 FOOT 0 20 LAMP G 574 WFTXT = 300 WATTS

NET DEMAND SAVINGS

NET DOLLAR SAVINGS

\$22 / HR

\$41 / HR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

## INTERIOR LIGHTING: FLUORESCENT FTURE REPLACEMENT

BUILDING #: 7900  
AREA: INSC AREAS  
AREA USE: HOURS/DAY: 16  
DAYS/WEEK: 1  
BUILDING VOLTAGE: 120

## EXISTING FTURE DATA

2 FOOT 2 LAMP U @ 50 WATT = 0 WATTS

ELECTRIC COSTS  
ENERGY CHARGE  
DEMAND CHARGE

\$0.2211 PER KWH  
\$1.16 PER KW

## REPLACEMENT FTURE DATA

2 FOOT 0 2 LAMP U @ 50 WATT = 0 WATTS

4 FOOT 0 1 LAMP @ 29 WATT = 0 WATTS  
1 1/2 LAMP @ 58 WATT = 58 WATTS  
0 3 LAMP @ 87 WATT = 87 WATTS  
1 1/2 LAMP @ 116 WATT = 116 WATTS  
4 FOOT 0 2 LAMP @ 125 WATT = 0 WATTS

8 FOOT 0 1 LAMP @ 29 WATT = 0 WATTS  
1 1/2 LAMP @ 58 WATT = 58 WATTS  
0 3 LAMP @ 87 WATT = 87 WATTS  
1 1/2 LAMP @ 116 WATT = 116 WATTS  
4 FOOT 0 2 LAMP @ 125 WATT = 0 WATTS

ECO ENERGY CONSERVATION  
NET DEMAND SAVINGS  
NET DOLLAR SAVINGS  
NET ENERGY SAVINGS

\$68 KWR  
\$158 KWR  
1.17 KW

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
11 August 1983

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUSINESS #:	7180
ADDRESS:	RESTROOMS/MAIN LIGHTS
LAMP USE:	0
HOURS/DAY:	5
DAY/SWEEK:	1 (1-YEES, 2-NOT)
PEAK USE:	
BUILDING VOL/TAG:	120

EXISTING INCANDESCENTS	13 WATTS =
6 LAMPS @ 52 WATTS =	312 WATTS
2 LAMPS @ 60 WATTS =	120 WATTS
1 LAMPS @ 75 WATTS =	75 WATTS
1 LAMPS @ 90 WATTS =	90 WATTS
1 LAMPS @ 130 WATTS =	130 WATTS

BASELINE ENERGY CONSUMPTION	66 KW
BASELINE DEMAND	2.23 KW
ECO ENERGY CONSUMPTION	37.6 KW
ECO DEMAND	0.63 KW

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$1.78 PER KW

COMPACT FLUORESCENT REPLACEMENT  
8 LAMPS @ 13 WATTS = 104 WATTS  
0 LAMPS @ 18 WATTS = 0 WATTS  
8 LAMPS @ 26 WATTS = 0 WATTS

NET DEMAND SAVINGS \$48 MYR

NET DOLLAR SAVINGS \$61 MYR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

10 AUGUST 1986

INTERIOR LIGHTING: LED LIGHTING REPLACEMENT		NET ENERGY SAVINGS	
NUMBER OF TRACK BAYS:	24	NET DOLLAR SAVINGS	\$1,019 / yr
AREA USE:	2400 sq ft	NET DEMAND SAVINGS	\$462 / yr
HOURS/DAY	24	ELECTRIC COSTS	\$0.021 / per kWh
DAY/SWEEK	7	ENERGY CHARGE	\$0.021 / per kWh
PEAK USE	1 (100% 2400)	DEMAND CHARGE	\$11.73 / per kw
PERIODIC VOLTAGE			
EXISTING FIXTURES		NET ENERGY CONSUMPTION	15.7 kWh
NUMBER OF TRACK BAYS:	24	NET ENERGY CONSUMPTION	16.7 kWh
AREA USE:	2400 sq ft	NET ENERGY CONSUMPTION	16.7 kWh
HOURS/DAY	24	NET ENERGY CONSUMPTION	16.7 kWh
DAY/SWEEK	7	NET ENERGY CONSUMPTION	16.7 kWh
PEAK USE	1 (100% 2400)	NET ENERGY CONSUMPTION	16.7 kWh

27-Jul-94

## MeansData for Lotus

Page

Estimate: Bldg. 7160 Date: 5 July 1994  
 Description: Fire Station  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total					
0207082121	DEMO, 2x4 FLUCC FIXTURES						
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	10.19	\$0	\$280	\$0	\$0	\$280	
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS						
Unit values	0.26	0.00	7.10	0.00	0.00	7.10	
Totals	2.06	\$0	\$57	\$0	\$0	\$57	
0207082540	DEMO, HIGH DAY FIXTURES						
Unit values	1.00	0.00	27.50	0.00	0.00	27.50	
Totals	25.00	\$0	\$633	\$0	\$0	\$633	
UC2 SITEWORK	36	\$0	\$970	\$0	\$0	\$970	

27-JUL-94

MeansData for Lotus

Page

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
16613C2200	SUR FLUOR STRIP 6' W 1 40W LAMP R S						
Unit values	0.94	26.74	22.52	0.00	(qty) 0.00	Ea.	49.26
Totals	0.00	\$0	\$0	\$0	\$0		\$0
16613C2300	SUR FLUOR STRIP 6' W 2 40W LAMP R S						
Unit values	1.03	28.65	23.82	0.00	(qty) 0.00	Ea.	52.47
Totals	0.00	\$0	\$0	\$0	\$0		\$0
16613G7001	LOW BAY, AL REFLECTOR 50W HPS						
Unit values	3.00	209.00	55.00	0.00	23.00	EA	264.00
Totals	45.00	\$4,807	\$1,265	\$0	\$0		\$6,072
16613G7777	L.E.D. EXIT SIGN SINGLE FACE						
Unit values	1.00	185.00	27.50	0.00	(qty) 0.00	EA	212.50
Totals	0.00	\$0	\$0	\$0	\$0		\$0
16613G9801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS						
Unit values	1.40	88.00	38.50	0.00	(qty) 0.00	EA	126.50
Totals	0.00	\$0	\$0	\$0	\$0		\$0
16613G9802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.51	84.00	41.50	0.00	37.00	EA	125.50
Totals	25.67	\$1,428	\$736	\$0	\$0		\$2,134
16613G9803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS						
Unit values	1.60	90.00	46.00	0.00	(qty) 0.00	EA	134.00
Totals	0.00	\$0	\$0	\$0	\$0		\$0
16613G9804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS						
Unit values	1.70	94.00	47.00	0.00	4.00	EA	141.00
Totals	6.80	\$376	\$188	\$0	\$0		\$564
16613G9807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.14	73.00	31.50	0.00	(qty) 0.00	EA	104.30
Totals	6.89	\$0	\$0	\$0	\$0		\$0
16613G9809	SUR FLUOR 1X4' W 3 32W T8						
Unit values	1.16	96.00	31.50	0.00	(qty) 0.00	EA	117.50

PAGE 3-1:

27-Jul-94

## MeansData for Lotus

Page

**Totals**

0.00 \$0 .50 \$0 \$0 \$0 \$0

1661309910

INDUSTRIAL FLUOR 1X4' W 2 32W T8  
TWO-PIECE REFLECTORUnit values  
Totals1.34 90.00 31.50 .50 0.00 EA 121.50  
0.00 \$0 .50 \$0 \$0 \$0 \$0

1661388041

CCMP FLUOR LAMP, 18 W TWIN TUBE  
GLOBE ASSEMBLYUnit values  
Totals0.13 14.50 3.44 .50 0.00 EA 17.94  
0.00 \$0 .50 \$0 \$0 \$0 \$0

1661388042

CCMP FLUOR FIX, 2 13 W PL  
WALL / CEILING MOUNTUnit values  
Totals1.00 25.50 27.50 .50 0.00 EA 53.00  
0.00 \$204 \$220 \$0 \$0 \$0 \$424

27-Jul-94

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		87	\$6,815	\$2,375		\$0	\$9,194
ESTIMATE TOTAL		123	\$6,815	\$3,369		\$0	\$10,164
SALES TAX	5.00%		\$341				
MATL MARKUP	40.00%		(\$2,726)				
LABOR MARKUP	23.40%			(\$449)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$4,430	\$2,900		\$0	\$7,330
CONTINGENCY	10.00%						\$733
BOND	2.50%						\$183
PROFIT	10.00%						\$733
JOB TOTAL							\$8,979

27-Jul-94

MeansData for LOCUS

Page 1

Estimate: Bldg. 7163 Date: 8 July 1994  
 Description: Fire Station  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITWORK	35	\$0	\$970	\$0	\$0	\$970
U16 ELECTRICAL	87	\$6,815	\$2,375	\$0	\$0	\$9,194
<b>TOTAL</b>	<b>123</b>	<b>\$6,815</b>	<b>\$3,349</b>	<b>\$0</b>	<b>\$0</b>	<b>\$10,164</b>
SALES TAX	5.00%	\$341				
MATERIAL MARKUP	-40.00%	(\$2,726)				
LABOR MARKUP	-13.40%		(\$449)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$4,430	\$2,900	\$0	\$0	\$7,330
CONTINGENCY	10.00%					\$733
BOND	2.50%					\$183
PROFIT	10.00%					\$733
<b>JOB TOTAL</b>						<b>\$8,979</b>



# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
10 AUGUST 1984

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUDGETED #: 7004  
AREA: INSTRUMENT ROOM  
LAMP USE: 3  
HOURS/DAY: 5  
DAYS/WEEK: 2  
PEAK USE: 211 VERS. 240V  
BUILDING VOLTAGE: 120

ELECTRIC COSTS,  
ENERGY CHARGE: \$0.0211 PER KWH  
DEMAND CHARGE: \$11.76 PER KW

EXISTING INCANDESCENT:  
LAMP 1: 32 WATTS  
LAMP 2: 40 WATTS  
LAMP 3: 40 WATTS  
LAMP 4: 40 WATTS  
LAMP 5: 40 WATTS  
LAMP 6: 40 WATTS  
LAMP 7: 40 WATTS  
LAMP 8: 160 WATTS

COMPACT FLUORESCENT REPLACEMENT:  
1 LAMPS @ 13 WATTS = 13 WATTS  
0 LAMPS @ 10 WATTS = 0 WATTS  
0 LAMPS @ 26 WATTS = 0 WATTS

BASELINE ENERGY CONSUMPTION:  
PER LINE DEMAND: 47 KWH  
PER KW: 0.0211  
PER H: 0.0044

ECO ENERGY CONSUMPTION:  
PER LINE DEMAND: 37 KWH  
PER KW: 0.0176  
PER H: 0.0037

NET ENERGY SAVINGS:  
NET ENERGY SAVINGS: \$13 RETURN

NET DEMAND SAVINGS:  
NET DOLLAR SAVINGS: \$1 M/R

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

19 AUGUST 1984

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING #: 7164

ELECTRIC COSTS:	
ENERGY CHARGE	\$0.0211 PER KWH
DEMAND CHARGE	\$1.175 PER KW

FLUORESCENT EXIT SIGNS

# EXIT SIGNS	2
WATTAGE	10

INCANDESCENT EXIT SIGNS

# EXIT SIGNS	2
WATTAGE	30

NET DEMAND ENERGY CONSUMPTION

KWH/HR	533 KWH/HR
MWH/HR	1,066 MWH/HR
KW	8.66 KW

NET ENERGY SAVINGS

KWH/HR	533 KWH/HR
MWH/HR	1,066 MWH/HR
KW	8.66 KW

NET DEMAND SAVINGS

KWH/HR	\$0.0211 PER KWH
MWH/HR	\$1.175 PER KW

27-Jul-94

## MeansData for Lotus

Page 1

Estimate: Bldg. 7164 Date: 8 July 1994  
 Description: Flight Control  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
0207082119	DEMO, 2x2, 1x4 FLUOR FIXTURES						
Unit values	0.36	0.00	10.00	0.00	5.00		
Totals	1.82	\$0	\$50	\$0	\$0	10.00	
0207082121	DEMO, 2x4 FLUOR FIXTURES						
Unit values	0.49	0.00	13.35	0.00	74.00		
Totals	35.09	\$0	\$988	\$0	\$0	13.35	
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS						
Unit values	0.26	0.00	7.10	0.00	3.00		
Totals	0.77	\$0	\$21	\$0	\$0	7.10	
U02 SITWORK		39	\$0	\$1,059	\$0	\$1,059	

27-Jul-94

MeansData for Locus

Page 2

Line #	Description					
		Manhours	Matl	Labor	Equipment	Sub
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					
Unit values	0.94	26.74	22.52	0.00	0.00	49.26
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					
Unit values	1.00	28.65	23.82	0.00	0.00	52.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE					
Unit values	1.00	50.00	27.50	0.00	0.00	77.50
Totals	3.00	\$100	\$55	\$0	\$0	\$155
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					
Unit values	1.40	88.00	38.50	0.00	0.00	126.50
Totals	7.02	\$440	\$193	\$0	\$0	\$633
1661309802	REC FLUOR TROFFER 2X4' W 1 32W T8 ACRYLIC LENS W REFLECTOR					
Unit values	1.51	84.00	41.30	0.00	0.00	125.50
Totals	15.10	\$140	\$415	\$0	\$0	\$1,255
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					
Unit values	1.60	90.00	44.00	0.00	0.00	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					
Unit values	1.70	94.00	47.00	0.00	0.00	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309805	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR					
Unit values	1.51	106.50	41.30	0.00	0.00	148.00
Totals	96.64	\$6,816	\$2,656	\$0	\$0	\$9,472
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					
Unit values	1.14	73.00	31.90	0.00	0.00	104.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309909	SUR FLUOR 1X4' W 2 32W T8					
Unit values	1.14	86.00	32.90	0.00	0.00	127.50

PAGE 3-133

27-Jul-94

## MeansData for Lotus

Page 3

Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR					
Unit values	1.14	90.00	31.50	0.00	(qty)	EA
Totals	0.00	\$0	\$0	\$0	0.00	121.50
					\$0	\$0
1661388041	COMP FLUOR LAMP, 13 W TUBE GLOBE ASSEMBLY					
Unit values	0.13	14.50	3.44	0.00	1.00	EA
Totals	0.13	\$15	\$3	\$0	0.00	17.94
					\$0	\$18
1661388042	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT					
Unit values	1.00	25.50	27.50	0.00	(qty)	EA
Totals	0.00	\$0	\$0	\$0	0.00	53.00
					\$0	\$0

27-Jul-94

MeansData for Lotus

Page 6

Line #	Description						Total
		Manhours	Matl	Labor	Equipment	S.	
U16 ELECTRICAL	121	\$8,211	\$3,322	\$0	\$0	\$11,533	
ESTIMATE TOTAL	150	\$8,211	\$4,381	\$0	\$0	\$12,592	
SALES TAX	5.00%	\$411					
MATL MARKUP	-40.00%	(\$3,284)					
LABOR MARKUP	-13.40%		(\$587)				
EQUIPT MARKUP	0.00%			\$0			
SUB MARKUP	0.00%				\$0		
TOTAL BEFORE CONTINGENCY		\$5,337	\$3,794	\$0	\$0	\$9,131	
CONTINGENCY	10.00%					\$913	
BOND	2.50%					\$228	
PROFIT	10.00%					\$913	
JOB TOTAL						\$21,106	

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7164 Date: 9 July 1994

Description: Flight Control

Project: Lighting Study

Bid Date:

Location: Ft. Campbell

Job d:

Sq. footage:

City indx:

SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U92 SITEWORK	39	\$0	\$1,059	\$0	\$0	\$1,059
U16 ELECTRICAL	121	\$8,211	\$3,322	\$0	\$0	\$11,533
TOTAL	160	\$8,211	\$4,381	\$0	\$0	\$12,592
SALES TAX	5.00%	\$411				
MATERIAL MARKUP	-40.00%	(\$3,284)				
LABOR MARKUP	-13.40%		(\$567)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$5,337	\$3,794	\$0	\$0	\$9,131
CONTINGENCY	10.00%					\$913
BOND	2.50%					\$228
PROFIT	10.00%					\$913
JOB TOTAL						\$11,166

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: METERED / EXTERIOR LIGHTING  
10 AUGUST 1984

INTERIOR LIGHTING: FLUORESCENT FURNITURE REPLACEMENT

BUILDING #: 7103  
AREA: ENTIRE BLDG  
AREA USE:  
HOURS/DAY 24  
DAYS/WEEK 7  
BUILDING VOLTAGE 120

ELECTRIC COSTS:  
ENERGY CHARGE — \$0.0211 PER KWH  
DEMAND CHARGE — \$11.76 PER KW

## EXISTING FIXTURE DATA

2 FOOT	2 LAMP U	50 WATT	0 WATT	0 WATT
4 FOOT	1 LAMP G	50 WATT	0 WATT	0 WATT
	1 1/2 LAMP G	50 WATT	0 WATT	0 WATT
	2 LAMP G	50 WATT	0 WATT	0 WATT
	7 1/2 LAMP G	144 WATT	1008 WATT	283 WATT
	4 LAMP G	102 WATT	0 WATT	0 WATT

## REPLACEMENT FIXTURE DATA

2 FOOT	0.2 LAMP U G	50 WATT	0 WATT	0 WATT
4 FOOT	0.1 LAMP G	50 WATT	50 WATT	0 WATT
	1/2 LAMP G	50 WATT	50 WATT	0 WATT
	1 LAMP G	50 WATT	50 WATT	0 WATT
	1 1/2 LAMP G	50 WATT	50 WATT	0 WATT
	4 LAMP G	118 WATT	0 WATT	0 WATT

6 FOOT  
2 LAMP G 50 WATT = 0 WATT

8 FOOT  
0.2 LAMP G 125 WATT = 0 WATT

BASELINE ENERGY CONSUMPTION	9,662 KWH	ECO ENERGY CONSUMPTION	—
BASELINE DEMAND	170 KW	ECO DEMAND	—

NET ENERGY SAVINGS	26,323 KWH	NET DOLLAR SAVINGS	\$118 MVR
NET ENERGY SAVINGS	24.95 AMT/HR	NET DOLLAR SAVINGS	\$273 MVR

27-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7165 Date: 8 July 1994  
Description: Runway - Radio  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City index:

Line # Description

	Manhours	Matl	Labor	Equipment	Sub	Total
0207082121 DENO. 2x4 FLUOR FIXTURES						
Unit values	0.49	0.00	13.35	0.00	0.00	6.65
Totals	3.88	\$0	\$107	\$0	\$0	\$107
002 SITEWORK	4	\$0	\$107	\$0	\$0	\$107

F013-138

27-JUL-94

## MeansData for Locals

Page

Line #	Description	Manhours	Mail	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty)	EA.
Unit values	0.39	26.74	22.52	0.00	0.00	0.00	49.26
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty)	EA.
Unit values	1.00	26.65	23.82	0.00	0.00	0.00	32.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN SINGLE FACE					(qty)	EA
Unit values	1.00	185.00	27.50	0.00	0.00	0.00	212.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309501	REC FLUOR TROFFER 2X2' W 2 32W TS ACRYLIC LENS					(qty)	EA
Unit values	1.40	88.00	38.90	0.00	0.00	0.00	126.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 3 32W TS ACRYLIC LENS W REFLECTOR					7.00	EA
Unit values	1.51	64.00	41.50	0.00	0.00	0.00	125.50
Totals	10.57	\$595	\$291	\$0	\$0	\$0	\$879
1661309803	REC FLUOR TROFFER 2X4' W 3 32W TS ACRYLIC LENS					(qty)	EA
Unit values	1.69	90.00	44.00	0.00	0.00	0.00	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W TS ACRYLIC LENS					(qty)	EA
Unit values	1.79	94.00	47.00	0.00	0.00	0.00	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W TS ACRYLIC LENS					(qty)	EA
Unit values	1.14	73.00	31.50	0.00	0.00	0.00	104.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309909	SUR FLUOR 1X4' W 2 32W TS					0.00	EA
Unit values	1.14	86.00	31.50	0.00	0.00	0.00	117.50
Totals	1.14	\$86	\$32	\$0	\$0	\$0	\$118
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W TS TWO-PIECE REFLECTOR					(qty)	EA
Unit values	1.14	93.00	31.50	0.00	0.00	0.00	124.50

PAGE 3-139

27-JUL-94

## MeansData for Lotus

Page 3

Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661368061	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY					
Unit values	0.13	14.80	3.44	0.00	(qty) EA	17.94
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661368062	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT					
Unit values	1.00	25.50	27.00	0.00	3.00 EA	53.00
Totals	2.00	\$51	\$55	\$0	\$0	\$106

PACS 3-140

27-JUL-94

## MeansData for Lot 6

Page 4

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
CIC ELECTRICAL	14	\$725	\$379	\$0	\$0	\$0	\$1,103
ESTIMATE TOTAL	16	\$725	\$485	\$0	\$0	\$0	\$1,210
SALES TAX		\$36					
INITL MARKUP		-40.00%	(\$290)				
LABOR MARKUP		-13.40%		(\$65)			
EQUIPT MARKUP		0.00%			\$0		
SLB MARKUP		0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$471	\$620	\$0	\$0	\$0	\$991
CONTINGENCY		10.00%					\$99
SEND		2.50%					\$22
PROFIT		10.00%					\$99
JOB TOTAL							\$1,092

PAGE 3-141

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7163 Date: 2 July 1994  
 Description: Runway - Radic  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
202 SITEWORK	4	\$0	\$157	\$0	\$0	\$107
206 ELECTRICAL	14	\$725	\$378	\$0	\$0	\$1,103
<b>TOTAL</b>	<b>18</b>	<b>\$725</b>	<b>\$535</b>	<b>\$0</b>	<b>\$0</b>	<b>\$1,210</b>
SALES TAX	5.00%	\$36				
MATL MARKUP	40.00%	(-\$290)				
LEBOR MARKUP	13.40%		(-\$65)			
EQUIPT MARKUP	0.50%			\$0		
SUB MARKUP	0.50%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$471</b>	<b>\$429</b>	<b>\$0</b>	<b>\$0</b>	<b>\$892</b>
CONTINGENCY	10.00%					\$89
BORR	2.50%					\$22
PROFIT	10.00%					\$89
<b>JOB TOTAL</b>						<b>\$1,092</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR Lighting

INTERIOR LUMEN: FLUORESCENT FATURE REPLACEMENT

BUDGETS:  
1110  
EXTERIOR 1000

PLATE  
DAYS/DAY  
KWH/PLATE

DEMAND CHARGE  
\$/HR

LIGHTING COSTS,  
ENERGY CHARGE  
DEMAND CHARGE  
\$0.091 PER KWH  
\$11/8 PER KW

REPLACEMENT FUTURE DATA

	2 FOOT	4 FOOT	6 FOOT	8 FOOT	10 FOOT	12 FOOT	14 FOOT	16 FOOT	18 FOOT	20 FOOT	22 FOOT	24 FOOT	26 FOOT	28 FOOT	30 FOOT	32 FOOT	34 FOOT	36 FOOT	38 FOOT	40 FOOT
2 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
4 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
6 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
8 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
10 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
12 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
14 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
16 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
18 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
20 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
22 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
24 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
26 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
28 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
30 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
32 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
34 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
36 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
38 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				
40 LAMP	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT	0 WATT				

	2 LAMP	4 LAMP	6 LAMP	8 LAMP	10 LAMP	12 LAMP	14 LAMP	16 LAMP	18 LAMP	20 LAMP	22 LAMP	24 LAMP	26 LAMP	28 LAMP	30 LAMP	32 LAMP	34 LAMP	36 LAMP	38 LAMP	40 LAMP
INTERIOR ENERGY CONSUMPTION	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	30.877	
INTERIOR DEMAND	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	92.77	
NET ENERGY SAVINGS	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	70.304	
NET DOLLAR SAVINGS	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	\$1,178	

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: EXTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

EXTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

AREA: HALLWAY RESTROOMS

LAMP USE:  
HOURS/DAY  
DAYS/WEEK  
PEAK USE

BUILDING VOL VAC: 120

ELECTRIC COSTS:  
ENERGY CHARGE .000211 PER KW/H  
DEMAND CHARG .31174 PER KW

EXISTING INCANDESCENTS  
LAMPS @ 52 WATTS @ 60 WATTS @ 75 WATTS @ 90 WATTS @ 100 WATTS  
54 LAMPS @ 300 WATTS

COMPACT FLUORESCENT REPLACEMENT  
9 LAMPS @ 13 WATTS = 0 WATTS  
6 LAMPS @ 16 WATTS = 0 WATTS  
84 LAMPS @ 26 WATTS = 1404 WATTS

BASELINE ENERGY CONSUMPTION

12.00 KWH

41,600 MJ

120 KW

BASELINE DEMAND

ECO DEMAND

3,283 KWH

11,827 MJ

1,40 KW

NET ENERGY SAVINGS

32,602 MJ/YR

31.30 MJS/YR

NET DEMAND SAVINGS

\$565 YR

NET DOLLAR SAVINGS

\$762 YR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

16 AUGUST 1994

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

QUANTITY:	1118	FLUORESCENT EXIT SIGNS			REPLACEMENT FEATURE			NET DOLLAR SAVINGS
		EXIT SIGNS	WATTAGE	16.	WATTAGE	10.	PER KWH	
INCANDESCENT EXIT SIGNS	13	8	30.	16.	10.	24.3	\$0.07/kwh	\$32 NR
BASELINE ENERGY CONSUMPTION		2,690 KWH/HR	8.812 KWH/HR		2,020 KWH/HR	6.03 KWH/HR		\$32 NR
BASELINE DOLLAR CONSUMPTION		191.30	54.46		141.60	39.48		\$32 NR
NET ENERGY SAVINGS		748.70	297.98		588.40	154.92		\$32 NR
NET ENERGY SAVINGS		5.97 NR/mm	1.77 NR/mm		4.60 NR/mm	1.28 NR/mm		\$32 NR

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7170 Date: 6 July 1994  
Description: Admin  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207062122	DEMO, 2x4 FLUCR FIXTURES					129.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	62.57	\$0	\$1,722	\$0	\$0	\$0	\$1,722
0207062123	DEMO, INCAND FIXTURES / EXIT SIGNS					54.09	
Unit values	0.26	0.00	7.10	0.00	0.00	7.10	
Totals	16.51	\$0	\$454	\$0	\$0	\$0	\$454
002 SITEWORK		\$0	\$0	\$2,176	\$0	\$0	\$2,176

27-Jul-94

MeansData for Lotus

Page 2

Line #	Description	Manhours Matl Labor Equipment Sub Total				
		Manhours	Matl	Labor	Equipment	Sub
1661302200	SUR FLUOR STRIP 4' W 1 32W LAMP R S					
Unit values	0.94	26.74	22.52	0.00	2.00	Ea.
Totals	1.88	\$53	\$45	\$0	\$0	\$58
1661302300	SUR FLUOR STRIP 4' W 2 32W LAMP R S					
Unit values	1.00	26.65	23.52	0.00	(qty)	Ea.
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN RETROFIT KIT					
Unit values	1.00	\$0.00	27.50	0.00	10.00	Ea
Totals	10.00	\$500	\$275	\$0	\$0	\$775
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					
Unit values	1.40	88.00	38.50	0.00	(qty)	Ea
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					
Unit values	1.51	84.00	41.50	0.00	(qty)	Ea
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					
Unit values	1.60	90.00	44.00	0.00	(qty)	Ea
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					
Unit values	1.70	94.00	47.00	0.00	(qty)	Ea
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309805	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR					
Unit values	1.51	106.50	42.50	0.00	24.00	Ea
Totals	36.24	\$2,556	\$996	\$0	\$0	\$3,552
1661309807	REC FLUOR TROFFER 1Y4' W 1 32W T8 ACRYLIC LENS					
Unit values	1.14	80.00	31.50	0.00	95.00	Ea
Totals	106.30	\$7,600	\$2,993	\$0	\$0	\$10,593
1661309909	SUR FLUOR 1X4' W 2 32W T8					
Unit values	1.14	93.00	37.50	0.00	0.00	Ea

PAGE 3-147

27-Jul-94

## MeansData for Lotus

Page 3

Totals	9.12	\$744	\$252	\$0	\$0	\$996
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR					(qty) EA
Unit values	1.14	90.00	31.50	0.00	0.00	121.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661388041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY					(qty) EA
Unit values	0.13	14.50	3.44	0.00	0.00	17.54
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661388042	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT					54.00 EA
Unit values	1.00	25.50	27.50	0.00	0.00	53.00
Totals	54.00	\$1,377	\$1,485	\$0	\$0	\$2,862

27-Jul-94

MeansData for Lotus

Page 4

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
J16 ELECTRICAL		220	\$12,830	\$6,346	\$0	\$0	\$18,876
ESTIMATE TOTAL		300	\$12,830	\$8,222	\$0	\$0	\$21,052
SALES TAX	5.00%		\$642				
MATL MARKUP	-40.00%		(\$5,132)				
LABOR MARKUP	-13.40%			(\$1,102)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$8,340	\$7,120	\$0	\$0	\$15,460
CONTINGENCY	10.00%						\$1,546
BOND	2.50%						\$386
PROFIT	10.00%						\$1,546
JOB TOTAL							\$18,938

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7270 Date: 8 July 1994  
 Description: Admin  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
UC2 SETEWCRK	80	\$0	\$2,176	\$0	\$0	\$2,176
U16 ELECTRICAL	220	\$12,830	\$6,046	\$0	\$0	\$18,876
<b>TOTAL</b>	<b>300</b>	<b>\$12,830</b>	<b>\$8,222</b>	<b>\$0</b>	<b>\$0</b>	<b>\$21,052</b>
SALES TAX	5.00%	\$642				
MATL MARKUP	-40.00%	(-\$5,132)				
LABOR MARKUP	-13.40%		(-\$1,102)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	0.00%					
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$8,340</b>	<b>\$7,120</b>	<b>\$0</b>	<b>\$0</b>	<b>\$15,460</b>
CONTINGENCY	10.00%					\$1,546
BOND	2.50%					\$386
PROFIT	10.00%					\$1,546
<b>JOB TOTAL</b>						<b>\$18,938</b>

1023-150

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

18 AUGUST 1984

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7178	AREA: SHOP/OFFICE
AREA USE: HOURS/DAY	8
HOURS/WEEK	5
BUILDING VOLTAGE: 110	

### EXISTING FIXTURE DATA

4 FOOT 2 LAMP @ 90 WATT = 0 WATTS

4 FOOT	1 LAMP @ 90 WATT = 0 WATTS
40	2 LAMP @ 90 WATT = 180 WATTS
40	3 LAMP @ 90 WATT = 270 WATTS
40	4 LAMP @ 90 WATT = 360 WATTS

6 FOOT 2 LAMP @ 90 WATT = 0 WATTS

6 FOOT	1 LAMP @ 90 WATT = 0 WATTS
125	2 LAMP @ 90 WATT = 180 WATTS
125	3 LAMP @ 90 WATT = 270 WATTS
125	4 LAMP @ 90 WATT = 360 WATTS

### NET ENERGY SAVINGS

0.303 GJ/HOUR

0.41 GJ/HOUR

### NET DOLLAR SAVINGS

\$169/MR

\$222/MR

ELECTRIC COSTS:	\$.0221 PER KWH
ENERGY CHARGE:	\$1178 PER KW
DEMAND CHARGE:	

### REPLACEMENT FIXTURE DATA

2'00" 0.2 LAMP @ 5 WATT = 0 WATTS

4 FOOT	0.1 LAMP @ 22 V - 0 WATTS
40	2 LAMP @ 50 WATT = 2320 WATTS
40	3 LAMP @ 50 WATT = 348 WATTS
40	4 LAMP @ 50 WATT = 0 WATTS

6 FOOT 0.2 LAMP @ 125 WATT = 0 WATTS

6 FOOT	0.1 LAMP @ 22 V - 0 WATTS
125	2 LAMP @ 125 WATT = 15625 WATTS
125	3 LAMP @ 125 WATT = 2375 WATTS
125	4 LAMP @ 125 WATT = 3625 WATTS

### NET ENERGY CONSUMPTION

6.007 KWH/HR

20,000 KWH

3,000 KWH

ECO ENERGY CONSUMPTION

10,978 KWH

2,477 KWH

ECO DEMAND

2.477 KW

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR EXTERIOR LIGHTING

10 AUGUST 1992

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

EXISTING:	71% WATTAGE	REPLACEMENT:	10% WATTAGE	NET ENERGY SAVINGS WATTAGE	NET ENERGY SAVINGS WATTAGE	NET DOLLAR SAVINGS PER YEAR	NET DOLLAR SAVINGS PER YEAR
EXISTING COSTS:	\$10710 PER MONTH	REPLACEMENT COSTS:	\$1118 PER MONTH	NET ENERGY SAVINGS	\$1118 PER MONTH	\$111 PER YEAR	\$111 PER YEAR
WATTAGE CHARGE:	210000 KW/H	WATTAGE CHARGE:	400 KW/H	NET ENERGY SAVINGS	206000 KW/H	NET DOLLAR SAVINGS	328 PER YEAR
BASELINE ENERGY CONSUMPTION:	2,300 KW/H	BASELINE ENERGY CONSUMPTION:	400 KW/H	NET ENERGY SAVINGS	2,300 KW/H	NET DOLLAR SAVINGS	311 PER YEAR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
19 AUGUST 1994

## INTERIOR LIGHTING - HID LIGHTING REPLACEMENT

BUILDING #: 712  
SQUARE FEET: 8,000  
AREA USE: 10% SAWAY  
DAYS/NW IN: 2400  
PEAK USE: 14-VES 2400

OPERATING VOLTAGE: 277

ELECTRIC COSTS:  
ENERGY CHARGE: 30.0211 PER kWh  
DEMAND CHARGE: \$11.78 PER kW

EXISTING FIXTURES:  
30' HV @ 200 WATTS: 1000 WATTS  
40' LV @ 400 WATTS: 0 WATTS  
40' HV @ 1075 WATTS: 0 WATTS

EXISTING ENERGY CONSUMPTION:

30' HV DEMAND: 81,996 KWH

40' LV DEMAND: 19,63 KWH

## REPLACEMENT FIXTURES

30' HV @ 100 WATTS: 100 WATTS  
40' LV @ 500 WATTS: 300 WATTS  
40' HV @ 460 WATTS: 460 WATTS

EXISTING ENERGY CONSUMPTION:

30' HV DEMAND: 81,996 KWH

40' LV DEMAND: 19,63 KWH

NET ENERGY SAVINGS: 69,275 KWH/  
30.0211 MJ  
d.g. KW

\$1.001/kWh

\$633/YR

NET DEMAND SAVINGS: \$1,001/YR

\$1,001/YR

27-Jul-94

## MeansData for Lotus

Page

Estimate: Bldg. 7176 Date: 8 July 1994  
 Description: SHOP/OFFICE  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082121	DEMO, 2x4 FLUOR FIXTURES					44.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	21.34	\$0	\$587	\$0	\$0	\$587	
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					3.00	
Unit values	0.26	0.00	7.10	0.00	0.00	7.10	
Totals	0.77	\$0	\$21	\$0	\$0	\$21	
0207082540	DEMO, HIGH BAY FIXTURES					58.00	
Unit values	1.00	0.00	27.50	0.00	0.00	27.50	
Totals	58.00	\$0	\$1,595	\$0	\$0	\$1,595	
UCL SITENWORK		\$1	\$0	\$2,203	\$0	\$0	\$2,203

27-Jul-94

## MeansData for Lotus

Page 2

Line #	Description					
		Manhours	Matl	Labor	Equipment	Sub Total
1661302200	SUR FLUOR STRIP 4' W 2 40W LAMP R S					0.00 EA.
Unit values	0.94	26.74	22.82	0.00	0.00	49.26
Totals	0.00	\$0	\$0	0.00	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S				(qty) EA.	
Unit values	1.00	28.65	23.82	0.00	0.00	52.47
Totals	0.00	\$0	\$0	0.00	\$0	\$0
1661307001	LOW BAY, AL REFLECTOR 50W HPS				38.00 EA	
Unit values	2.00	209.00	55.00	0.00	0.00	264.00
Totals	76.00	\$7,542	\$2,090	0.00	\$0	\$10,032
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE				3.00 EA	
Unit values	1.00	50.00	27.50	0.00	0.00	77.50
Totals	3.00	\$150	\$83	0.00	\$0	\$233
1661309801	REC FLUOR TROFFER 2X2' W 2 32W T8-U ACRYLIC LENS				(qty) EA	
Unit values	1.40	88.00	38.00	0.00	0.00	126.80
Totals	0.00	\$0	\$0	0.00	\$0	\$0
1661309802	REC FLUOR TROFFER 2X2' W 2 32W T8 ACRYLIC LENS				0.00 EA	
Unit values	1.51	86.00	41.50	0.00	0.00	125.50
Totals	0.00	\$0	\$0	0.00	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS				4.00 EA	
Unit values	1.60	90.00	44.00	0.00	0.00	134.00
Totals	6.40	\$360	\$176	0.00	\$0	\$536
1661309804	REC FLUOR TROFFER 3X4' W 4 32W T8 ACRYLIC LENS				(qty) EA	
Unit values	1.73	94.00	47.00	0.00	0.00	141.00
Totals	0.00	\$0	\$0	0.00	\$0	\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS				0.00 EA	
Unit values	1.14	73.00	36.50	0.00	0.00	109.50
Totals	0.00	\$0	\$0	0.00	\$0	\$0
1661309900	SUR FLUOR 1X4' W 2 32W T8				0.00 EA	
Unit values	2.14	86.00	31.50	0.00	0.00	117.50

27-Jul-94

## MeansData for Lotus

Page 3

**Totals**

0.00 \$0 .50 \$0 \$0 .50

1661329910 INDUSTRIAL FLUOR 1X4' W 2 32W TB  
 TWO-PIECE REFLECTOR  
 Unit values 1.14 60.00 31.50 0.00 40.00 EA  
 Totals 45.60 \$2,600 \$1,260 \$0 0.00 \$0 91.50

1661388041 COMP FLUOR LAMP, 18 W TWIN TUBE  
 GLOBE ASSEMBLY  
 Unit values 0.13 16.50 3.44 0.00 (qty) EA  
 Totals 0.00 \$0 .50 \$0 0.00 \$0 17.94

1661388042 COMP FLUOR FIX, 2 13 W RL  
 WALL / CEILING MOUNT  
 Unit values 0.00 25.50 27.50 0.00 0.00 EA  
 Totals 0.00 \$0 .50 \$0 0.00 \$0 53.00

27-JUL-94

MeansData for LOTUS

Page 4

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total	
016 ELECTRICAL		131	\$10,852	\$3,609		\$0	\$0	\$14,461
ESTIMATE TOTAL		212	\$10,852	\$5,812		\$0	\$0	\$16,664
SALES TAX	5.00%			\$543				
MATL MARKUP	-40.00%			(-\$4,341)				
LABOR MARKUP	-13.40%				(S779)			
EQUIPT MARKUP	0.00%					\$0		
SUB MARKUP	0.00%						\$0	
TOTAL BEFORE CONTINGENCY			\$7,054	\$5,033		\$0	\$0	\$12,087
CONTINGENCY	10.00%							\$1,209
BOND	2.50%							\$302
PROFIT	10.00%							\$1,209
JOB TOTAL								\$16,807

27-Jul-94

MeansData for Lotus

Page 5

Estimate: Bldg. 7176 Date: 8 July 1994  
 Description: SHCP/OFFICE  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITEWORK	81	\$0	\$2,203	\$0	\$0	\$2,203
U16 ELECTRICAL	131	\$10,852	\$3,609	\$0	\$0	\$14,661
<b>TOTAL</b>	<b>212</b>	<b>\$10,852</b>	<b>\$5,812</b>	<b>\$0</b>	<b>\$0</b>	<b>\$16,664</b>
SALES TAX	5.00%	\$543				
MATERIAL MARKUP	-40.00%	(\$4,341)				
LABOR MARKUP	-13.40%		(\$779)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	0.00%				\$0	\$0
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$7,054</b>	<b>\$5,033</b>	<b>\$0</b>	<b>\$0</b>	<b>\$12,087</b>
CONTINGENCY	10.00%					\$1,209
BOND	2.50%					\$302
PROFIT	10.00%					\$1,209
<b>JOB TOTAL</b>						<b>\$16,607</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

10 AUGUST 1984

INTERIOR LIGHTING: FLUORESCENT FURNITURE REPLACEMENT

BUILDING #: 7112  
AREA: ENTIRE BLDG.  
HOURS/DAY: 16  
DAYS/WEEK: 5  
BUILDING VOLTAGE: 120V

## EXISTING FURNITURE DATA

2 FOOT	2 LAMP @	92 WATT	0 WATTS
4 FOOT	1 LAMP @	48 WATT	0 WATTS
	2 LAMP @	91 WATT	0 WATTS
	3 LAMP @	144 WATT	0 WATTS
	4 LAMP @	192 WATT	0 WATTS

## REPLACEMENT FURNITURE DATA

2 FOOT	0.2 LAMP @	34 WATT	0 WATTS
4 FOOT	0.1 LAMP @	29 WATT	0 WATTS
	0.2 LAMP @	58 WATT	2407 WATTS
	0.3 LAMP @	87 WATT	0 WATTS
	16.2 LAMP @	54 WATT	928 WATTS

4 FOOT 2 LAMP @ 92 WATT = 0 WATTS

8 FOOT 0.2 LAMP @ 125 WATT = 0 WATTS

4 FOOT ENERGY CONSUMPTION  
WATER USE DEMAND

4.671 KWH/HR  
37.276 MJ/HR  
1.34 KW

NET ENERGY SAVINGS  
NET ENERGY SAVINGS  
NET ENERGY SAVINGS

\$894 MJR  
\$1,264 MJR  
\$1,264 MJR

# FORT CAMPBELL LIGHTING SURVEY

ECO #: INTERIOR / EXTERIOR LAMPING

19 AUGUST 1984

INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BULB COUNT:	7078
AREA:	RESTROOMS
LAMP USE:	1
HOURS/DAY	5
DAYS/WEEK	2 (1-YES, 2-NO)
PEAK USE	
BLUNDING VOL TAG	120

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.76 PER KW

EXISTING INCANDESCENTS	
LAMP #1	52 WATTS
LAMP #2	60 WATTS
LAMP #3	60 WATTS
LAMP #4	72 WATTS
LAMP #5	58 WATTS
LAMP #6	100 WATTS

COMPACT FLUORESCENT REPLACEENT

LAMPS @ 0 WATTS @ 13 WATTS =	0 WATTS
0 LAMPS @ 0 WATTS =	0 WATTS
3 LAMPS @ 26 WATTS =	130 WATTS

BASELINE ENERGY CONSUMPTION	371 KWH
CURRENT DEMAND	0.255 KW
NET ENERGY SAVINGS	\$0.00

ECO ENERGY CONSUMPTION	167 KWH
ECO DEMAND	0.13 KW
NET DEMAND SAVINGS	\$9 MFR
NET DOLLAR SAVINGS	\$3 MFR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

19 AUGUST 1984

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING:	7179	ELECTRIC COSTS:	\$0.021 PER KWH
		ENERGY CHARGE:	\$1.76 PER KW
		DEMAND CHARGE:	\$1.76 PER KW
INCANDESCENT EXIT SIGNS	4	FLUORESCENT EXIT SIGNS	4
EXIT SIGNS	8	EXIT SIGNS	8
WATTAGE	30	WATTAGE	15
WATTAGE	30	WATTAGE	15
BASELINE ENERGY CONSUMPTION	1617 kWh/yr	ECO ENERGY CONSUMPTION	809 kWh/yr
BASELINE DEMAND	0.12 kW	ECO DEMAND	0.06 kW
NET ENERGY SAVINGS	2,408 kWh/yr	NET DOLLAR SAVINGS	\$15 /yr
NET ENERGY SAVINGS	3.23 kWh/yr	NET DOLLAR SAVINGS	\$3.50 /yr

27-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7179 Date: 8 July 1994  
Description: Control Group  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207092121	DEMO, 2x4 FLUOR FIXTURES					99.00	
Unit values	0.49	0.00	13.35	0.00	0.00	0.00	13.35
Totals	48.02	\$0	\$1,322	\$0	\$0	\$0	\$1,322
0207092123	DEMO, INCAND FIXTURES / EXIT SIGNS					9.00	
Unit values	0.26	0.00	7.10	0.00	0.00	0.00	7.10
Totals	2.32	\$0	\$64	\$0	\$0	\$0	\$64
U02 SITWORK		51	\$0	\$1,386	\$0	\$0	\$1,386

PAGE 3-162

27-Jul-94

MeansData for Job#

Page 2

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty)	Ea.
Unit values	0.94	26.74	22.52	0.00	0.00	0.00	49.26
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty)	Ea.
Unit values	1.00	28.65	23.82	0.00	0.00	0.00	52.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE					4.00	EA
Unit values	1.00	50.00	27.50	0.00	0.00	0.00	77.50
Totals	4.00	\$200	\$110	\$0	\$0	\$0	\$310
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					(qty)	EA
Unit values	1.40	88.00	38.50	0.00	0.00	0.00	126.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.51	84.00	41.50	0.00	0.00	0.00	125.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.60	90.00	44.00	0.00	0.00	0.00	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					0.00	EA
Unit values	1.70	94.00	47.00	0.00	0.00	0.00	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309805	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR					16.00	
Unit values	1.51	106.50	41.50	0.00	0.00	0.00	148.00
Totals	24.16	\$1,704	\$664	\$0	\$0	\$0	\$2,368
1661309807	REC FLUOR TROFFER 1X4' W 1 32W T8 ACRYLIC LENS					83.00	EA
Unit values	1.14	80.00	31.50	0.00	0.00	0.00	111.50
Totals	94.62	\$6,640	\$2,615	\$0	\$0	\$0	\$9,255
1661309909	SUR FLUOR 1X4' W 2 32W T8					(qty)	EA
Unit values	1.14	86.00	32.50	0.00	0.00	0.00	117.50

PAGE 3-163

27-Jul-94

## MeansData for Lotus

Page 3

	0.00	\$0	\$0	\$0	\$0	\$0	\$0
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
16613C9910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR						
Unit values	1.14	90.00	31.50	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	\$0	121.50	\$0
16613B8041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY						
Unit values	0.13	14.50	3.44	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	\$0	17.94	\$0
16613B8042	COMP FLUOR FIX, 2 13 W FL WALL / CEILING MOUNT						
Unit values	1.00	25.50	27.50	0.00	5.00	EA	
Totals	5.00	\$128	\$138	\$0	\$0	53.00	\$264

27-Jul-94

MeansData for Lotus

Page 4

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
116 ELECTRICAL		126	\$8,672	\$3,517		\$0	\$0 \$12,195
ESTIMATE TOTAL		179	\$8,672	\$4,913		\$0	\$0 \$13,565
SALES TAX	5.00%		\$434				
MATL MARKUP	-40.0%		(53,469)				
LABOR MARKUP	-13.4%			(S658)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$5,637	\$4,255		\$0	\$0 \$9,891
CONTINGENCY	10.00%						\$989
BOND	2.50%						\$247
PROFIT	10.00%						\$999
JOB TOTAL							\$12,117

27-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7179 Date: 8 July 1994  
 Description: Control Group  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
J12 SITWORK	51	\$0	\$1,386	\$0	\$0	\$1,386
J16 ELECTRICAL	129	\$8,672	\$3,527	\$0	\$0	\$12,199
<b>TOTAL</b>	<b>179</b>	<b>\$8,672</b>	<b>\$4,913</b>	<b>\$0</b>	<b>\$0</b>	<b>\$13,585</b>
SALES TAX	5.00%	\$434				
MATL MARKUP	-40.00%	(\$3,469)				
LABOR MARKUP	-13.40%		(\$658)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$5,637	\$4,255	\$0	\$0	\$9,892
CONTINGENCY	10.00%					\$98
BOND	2.50%					\$24
PROFIT	10.00%					\$98
<b>JOB TOTAL</b>						<b>\$12,111</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

18 AUGUST 1994

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7208  
 AREA: ENTIRE BLDG  
 AREA USE:  
 HOURS/DAY 19  
 DAYS/WEEK 5  
 BUILDING VOLTAGE: 120

ELECTRIC COSTS:  
 ENERGY CHARGE \$0.0211 PER KWH  
 DEMAND CHARGE \$116 PER KW

## EXISTING FIXTURE DATA

2 FOOT 2 LAMP U 80 WATT = 0 WATTS  
 4 FOOT 15 1 LAMP @ 45 WATT = 675 WATTS  
 11 2 LAMP @ 90 WATT = 10170 WATTS  
 2 3 LAMP @ 135 WATT = 270 WATTS  
 4 LAMP @ 180 WATT = 0 WATTS

8 FOOT 2 LAMP @ 180 WATT = 0 WATTS  
 BASELINE ENERGY CONSUMPTION 26709 KWH/MONTH  
 BASELINE DEMAND 11.12 KW

## REPLACEMENT FIXTURE DATA

2 FOOT 0.2 LAMP U @ 56 WATT = 0 WATTS  
 4 FOOT 15 1 LAMP @ 20 WATT = 300 WATTS  
 11 2 LAMP @ 55 WATT = 605 WATTS  
 2 3 LAMP @ 87 WATT = 174 WATTS  
 4 LAMP @ 116 WATT = 0 WATTS

BASELINE ENERGY CONSUMPTION 10,624 KWH/MONTH  
 BASELINE DEMAND 7.16 KW

NET DEMAND SAVINGS \$559 NR  
 NET DOLLAR SAVINGS \$775 NR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING  
19 AUGUST 1984

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING #: 7208

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.70 PER KW

FLUORESCENT EXIT SIGNS  
# EXIT SIGNS 10  
WATTAGE 30

REPLACEMENT FIXTURE  
# EXIT SIGNS 10  
WATTAGE 10  
3

BASELINE ENERGY CONSUMPTION  
BASELINE DEMAND

1,537 KWH/MONTH  
5,676 MWH/YR  
0.18 KW  
ECO DEMAND

263 KWH/MONTH  
846 MWH/YR  
0.03 KW  
ECO DEMAND

NET DEMAND SAVINGS \$211/YR  
NET DOLLAR SAVINGS \$49/YR

4,738 MWH/YR  
4.46 MBTU/YR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

10 AUGUST 1994

BUILDING #: 7206  
 AREA: HANGAR AND SHOP BAYS  
 AREA USE: 10  
 HOURS/DAY: 5  
 DAYS/WEEK: 5 (1-VFS, 2-MO)  
 PEAK USE:

BUILDING VOLTAGE: 277

ELECTRIC COSTS:  
 ENERGY CHARGE - \$0.0211 PER KWH  
 DEMAND CHARGE - \$11.70 PER KW

EXISTING FIXTURES	WATTS	WATTS
MACADO @ 200	200	0 WATTS
20 MV @ 454	454	9000 WATTS
42 LV @ 6075	6075	15150 WATTS

BASELINE ENERGY CONSUMPTION	KWH	KWH
	143,598 KWH	143,598 KWH
	567,593 MJ	567,593 MJ
	54.23 KW	54.23 KW

BASELINE DEMAND

REPLACEMENT FIXTURES	WATTS	WATTS	WATTS
IPS @ 20 MV @	20	300	0 WATTS
42 LV @	42	463	6000 WATTS

ECO ENERGY CONSUMPTION	KWH	KWH
	65,432 KWH	65,432 KWH
	216,995 MJ	216,995 MJ
	25.32 KW	25.32 KW

NET ENERGY SAVINGS	KWH	KWH
	270,598 KWH	270,598 KWH
	250,47 MJ	250,47 MJ

NET DOLLAR SAVINGS	\$R	\$R
	\$4,087	\$4,087
	\$5,673	\$5,673

27-JUL-94

## MeansData for Lotus

Page

Estimate: Bldg. 7206 Date: 5 July 1994  
 Description: hangar Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
0207062121	DEMO, 2x4 FLUOR FIXTURES						
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	63.05	\$0	\$1,736	\$0	\$0	\$1,736	
0207062123	DEMO, INCAND FIXTURES / EXIT SIGNS						
Unit values	0.26	0.00	7.10	0.00	0.00	7.10	
Totals	2.58	\$0	\$71	\$0	\$0	\$71	
0207062540	DEMO, HIGH BAY FIXTURES						
Unit values	1.00	0.00	27.50	0.00	0.00	27.50	
Totals	62.00	\$0	\$1,705	\$0	\$0	\$1,705	
UG2 SITENWORK		126	\$0	\$3,512	\$0	\$3,512	

27-Jul-94

## MeansData for Locus

Page

Line #	Description						
	Manhours	Matl	Labor	Equipment	Sub	Total	
1661302200	SUR FLUOR STRIP 4' W 1 32W LAMP R S						15.00 Ea.
Unit values	0.94	26.74	22.52	0.00	0.00	45.26	
Totals	14.12	\$401	\$325	\$0	50	\$739	
1661302300	SUR FLUOR STRIP 4' W 2 32W LAMP R S						30.00 Ea.
Unit values	1.00	28.65	23.82	0.00	0.00	52.47	
Totals	30.00	\$860	\$714	\$0	50	\$1,574	
1661304291	HIGH BAY, AL REFLECTOR 400W XH						42.00 EA
Unit values	3.48	295.00	95.50	0.00	0.00	390.50	
Totals	146.08	\$5,2390	\$4,011	\$0	50	\$16,401	
1661304292	HIGH BAY, AL REFLECTOR 250W XH						20.00 EA
Unit values	3.48	243.00	95.50	0.00	0.00	338.50	
Totals	69.56	\$4,860	\$1,910	\$0	50	\$6,770	
1661307777	L.E.D. EXIT SIGN SINGLE FACE						10.00 EA
Unit values	1.00	50.00	27.50	0.00	0.00	30	
Totals	10.00	\$500	\$275	\$0	50	15	
1661309801	REC FLUOR TROFFER 2X2' W 2 32W T8-U ACRYLIC LENS						(qty) EA
Unit values	1.40	88.00	38.50	0.00	0.00	126	
Totals	0.00	\$0	\$0	\$0	50	0	
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T9 ACRYLIC LENS						(qty) EA
Unit values	1.51	84.00	41.50	0.00	0.00	125.50	
Totals	0.00	\$0	\$0	\$0	50	0	
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS						2.00 EA
Unit values	1.60	90.00	44.00	0.00	0.00	134.00	
Totals	3.20	\$180	\$88	\$0	50	\$268	
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS						(qty) EA
Unit values	1.70	94.00	47.00	0.00	0.00	141.00	
Totals	0.00	\$0	\$0	\$0	50	0	
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS						83.00 EA
Unit values	1.14	73.00	31.50	0.00	0.00	104.50	

PAGE 3-17

27-Jul-94

## MeansData for Lotus

Page

Totals	94.62	\$6,059	\$2,615	\$0	\$0	\$0	\$8,674
1661309909	SUR FLUOR	1X4' W 2 32W T8					
Unit values	1.14	66.00	31.50	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00		117.50
1661309910	INDUSTRIAL FLUOR	1X4' W 2 32W T8					
Unit values	1.14	90.00	31.50	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00		121.50
1661388041	CCMP FLUOR LAMP,	16 W TWIN TUBE					
Unit values	0.13	14.50	3.44	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00		17.94

27-Jul-94

MeansData for Lotus

Page 1

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		368	\$25,250	\$9,951		\$0	\$35,201
ESTIMATE TOTAL		496	\$25,250	\$13,463		\$0	\$38,713
SALES TAX	5.00%		\$1,263				
MATL MARKUP	-40.00%		(\$10,100)				
LABOR MARKUP	-13.40%			(\$1,804)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY		\$16,413	\$11,659		\$0	\$0	\$28,071
CONTINGENCY	10.00%						\$2,807
BCND	2.50%						\$702
PROFIT	10.00%						\$2,807
JOB TOTAL							\$34,388

27-Jul-94

MeansData for Lotus

Page

Ultimate: Bldg. 7206 Date: 8 July 1994  
 Description: hangar

Project: Lighting Study Bid Date:

Location: Ft. Campbell Job #:

Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
J02 SITENWORK	126	\$0	\$3,512	\$0	\$0	\$3,512
J16 ELECTRICAL	368	\$25,250	\$9,951	\$0	\$0	\$35,201
<b>TOTAL</b>	<b>496</b>	<b>\$25,250</b>	<b>\$13,463</b>	<b>\$0</b>	<b>\$0</b>	<b>\$38,713</b>
SALES TAX	5.00%	\$1,263				
MATL. MARKUP	-40.00%	(\$10,100)				
LABOR MARKUP	-13.40%		(\$1,804)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENC		\$16,413	\$11,659	\$0	\$0	\$28,071
CONTINGENCY	10.00%					\$2,807
BOND	2.50%					\$702
PROFIT	10.00%					\$2,807
<b>JOB TOTAL</b>						<b>\$34,388</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7208  
AREA: ENTIRE BLDG  
USE: OFFICE  
HOURS/DAY: 10  
DAYS/WEEK: 5  
BUILDING VOLTAGE: 277

### EXISTING FIXTURE DATA

2 FOOT 2 LAMP U 98 WATT = 0 WATTS

ELECTRIC COSTS  
ENERGY CHARGE:  
DEMAND CHARGE

\$0.0211 PER KWH

\$11.76 PER KW

### EXISTING FIXTURE DATA

4 FOOT 2 LAMP U 48 WATT = 0 WATTS

### REPLACEMENT FIXTURE DATA

2 FOOT 0.2 LAMP U @ 58 WATT = 0 WATTS

4 FOOT 0.1 LAMP @ 22 WATT = 0 WATTS  
180 2 LAMP @ 55 WATT = 1020 WATTS  
16 3 LAMP @ 87 WATT = 1216 WATTS  
0 4 LAMP @ 118 WATT = 0 WATTS

8 FOOT 0.2 LAMP @ 125 WATT = 0 WATTS

4 FOOT 1 LAMP @ 48 WATT = 0 WATTS  
180 2 LAMP @ 84 WATT = 15120 WATTS  
16 3 LAMP @ 126 WATT = 1216 WATTS  
0 4 LAMP @ 192 WATT = 0 WATTS

8 FOOT 0.2 LAMP @ 125 WATT = 0 WATTS

25,412 KWH/YR  
\$14,548 METER  
12.24 KW

NET DEMAND SAVINGS  
NET DOLLAR SAVINGS

\$778 MTR  
\$1,076 MTR

NET ENERGY SAVINGS  
NET ENERGY SAVINGS

81,349 KWH  
43,67 METER/YR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

10 AUGUST 1994

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7208	AREA: RESTROOMS
LAMP USE HOURS/DAY	3
DAYSWEEK	5
PEAK USE	2 (1-YES, 2-NO)
MAIN DING VOLTAGE	120

EXISTING INCANDESCENTS	52 WATTS = 0 WATTS
LAMPS @ 60 WATTS	240 WATTS
4 LAMPS @ 75 WATTS	0 WATTS
5 LAMPS @ 60 WATTS	0 WATTS
10 LAMPS @ 60 WATTS	0 WATTS

BASELINE ENERGY CONSUMPTION	187 KWH 674 MJ 6.26 KW
BASELINE DEMAND	ECO ENERGY CONSUMPTION 41 KWH 146 MJ 0.95 KW

NET ENERGY SAVINGS	538 MJ/YR 0.59 MBTU/YR
NET ENERGY SAVINGS	ECO ENERGY CONSUMPTION NET DEMAND SAVINGS NET DOLLAR SAVINGS \$0 NYR \$3 NYR

ELECTRIC COSTS  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.76 PER KW

COMPACT FLUORESCENT REPLACEMENT  
4 LAMPS @ 13 WATTS = 52 WATTS  
0 LAMPS @ 15 WATTS = 0 WATTS  
0 LAMPS @ 26 WATTS = 0 WATTS

ECO ENERGY CONSUMPTION  
41 KWH  
146 MJ  
0.95 KW  
ECO DEMAND  
NET DEMAND SAVINGS  
NET DOLLAR SAVINGS  
\$0 NYR  
\$3 NYR

## FORT CAMPBELL LIGHTING SURVEY

ECD : INTELLIGENT / AUTOMATED LIGHTING

卷之三

INTERIOR LUCIDING INCANDESCENT LAMP REPLACEMENT		FLUORESCENT FIXTURE REPLACEMENT		NET DEMAND SAVINGS	
BUILDING #:	723	ELECTRIC COSTS.		\$1065 /MHR	\$1065 /MHR
AREA:	OFFICE	ENERGY CHARGE	90.0211 PER KWH	6.67 MERTHUR	6.67 MERTHUR
APP USE:	10	DEMAND CHARGE	\$11.78 PER KW		
HOURS/EEK:	5				
TEAK USE	1 (1-YES 2-NO)				
BUILDING VOLTAGE	120				
INTERIOR INCANDESCENTS		NET DEMAND SAVINGS	NET DOLLAR SAVINGS		
2 LAMPS @ 405 WATTS =	810 WATTS	2,160 KWH	137 KWH		
LAYS/EEK		7,502 MJ	543 MJ		
TEAK USE		8.81 KW	0.86 KW		

PAGE 3-177

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

BUILDING #: 7208	HAZARD RAY STORAGE
AREA: 1	
PHASE USE	10
POURINARY	5
DAYSMITH	1
PEAK USE	11-YEARS, 2400
BUILDING VOLTAGE:	277

ELECTRIC COST \$.	\$0.0211	PER KWH
ENERGY CHARGE	\$11.79	PER KW
Demand Charge		

EXISTING FIXTURES	0 WATTS	0 WATTS	0 WATTS
ECO-LAND 9	200 WATTS = 12112 WATTS	64 WATTS = 300 WATTS	0 WATTS
28 MV @	456 WATTS = 103200 WATTS	28 WATTS = 400 WATTS	3400 WATTS
28 MV @	1075 WATTS = 103200 WATTS	86 WATTS = 44160 WATTS	44160 WATTS
BASELINE ENERGY CONSUMPTION	307,377 KWH	ECO ENERGY CONSUMPTION	136,656 KWH
BASELINE DEMAND	1,044.936 KW	ECO DEMAND	491.962 KW
BASELINE DEMAND	1,155.91 KW	ECO DEMAND	52.56 KW

NET ENERGY SAVINGS	692,976 MJ/YR	NET DEMAND SAVINGS	\$8,965 MYR
NET ENERGY SAVINGS	562.91 MJ/TW	NET DOLLAR SAVINGS	\$12,431 MYR

27-JUL-94

MeansData for Lotus

Page

Estimate: Bldg. 7206 Date: 8 July 1994  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description					
		Manhours	Matl	Labor	Equipment	Sub
C207092121	DEMO, 2x4 FLUOR FIXTURES				204.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.35
Totals	98.94	\$0	\$2,723	\$0	\$0	\$2,723
C207092123	DEMO, INCANDE FIXTURES / EXIT SIGNS				5.00	
Unit values	0.26	0.00	7.10	0.00	0.00	7.10
Totals	1.35	\$0	\$43	\$0	\$0	\$43
C20709254C	DEMO, HIGH BAY FIXTURES				124.00	
Unit values	1.00	0.00	27.50	0.00	0.00	27.50
Totals	124.00	\$0	\$3,410	\$0	\$0	\$3,410
UCA SITEWORK	225	\$0	\$6,176	\$0	\$0	\$6,176

27-Jul-94

MeansData for Lotus

P

Line #	Description	Manhours Matl Labor Equipment Sub Total				
		(qty)	Ea.			
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					
Unit values	0.94	26.74	22.52	0.00	0.00	49.
Totals	0.00	\$0	\$0	\$0	\$0	
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					
Unit values	1.00	28.65	23.82	0.00	0.00	52.
Totals	0.00	\$0	\$0	\$0	\$0	
1661304291	HIGH BAY. AL REFLECTOR 400W MH					
Unit values	3.48	295.00	95.50	0.00	0.00	390.
Totals	333.89	\$28,320	\$9,168	\$0	\$0	\$37,4
1661304292	HIGH BAY. AL REFLECTOR 250W MH					
Unit values	3.48	243.00	95.50	0.00	0.00	338.
Totals	97.38	\$6,804	\$2,674	\$0	\$0	\$9.4
1661307777	L.E.D. EXIT SIGN SINGLE FACE					
Unit values	1.00	165.00	27.50	0.00	0.00	212.
Totals	0.00	\$0	\$0	\$0	\$0	
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					
Unit values	1.40	88.00	38.50	0.00	0.00	126.
Totals	0.00	\$0	\$0	\$0	\$0	
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					
Unit values	1.51	84.00	41.50	0.00	0.00	125.
Totals	0.00	\$0	\$0	\$0	\$0	
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					
Unit values	1.60	90.00	44.00	0.00	0.00	134.
Totals	22.40	\$1,260	\$616	\$0	\$0	\$1.8
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					
Unit values	1.70	94.00	47.00	0.00	0.00	141.
Totals	0.00	\$0	\$0	\$0	\$0	
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					
Unit values	1.14	73.00	31.50	0.00	190.00	104.

PAGE

1:

27-Jul-94

MeansData for Lotus

P.

<b>Totals</b>	216.60	\$13,871	\$5,955	\$0	\$0	\$19,81
1661309909	SUR FLUOR 1X4' W 2 32W T8					
Unit values	1.14	66.00	31.50	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0	117.0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR					
Unit values	1.14	57.00	31.50	0.00	1.00 EA	
Totals	1.14	\$57	\$32	\$0	\$0	88.0
1661309912	SUR FLUOR 2X4' W 3 32W T8					
Unit values	1.43	115.00	38.80	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0	153.0
1661309941	COMP FLUOR LAMP, 16 W TWIN TUBE GLOBE ASSEMBLY					
Unit values	0.13	14.50	3.44	0.00	(qty) EA	
Totals	0.00	\$0	\$0	\$0	\$0	17.0
1661309942	COMP FLUOR FIX. 2 13 W PL WALL / CEILING MOUNT					
Unit values	1.00	25.50	27.50	0.00	4.00 EA	
Totals	4.00	\$102	\$110	\$0	\$0	53.0

27-Jul-94

MeansData for Ictus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
CJG ELECTRICAL		676	\$50,413	\$18,565		\$0	\$68,998
ESTIMATE TOTAL		901	\$50,413	\$24,761		\$0	\$75,174
SALES TAX	5.00%		\$2,511				
MATL MARKUP	+40.00%	(-\$20,168)					
LABOR MARKUP	+13.40%			- \$3,318			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENC			\$32,768	\$21,443		\$0	\$54,211
CONTINGENCY	10.00%						\$5,421
BOND	2.50%						\$1,355
PROFIT	10.00%						\$5,421
JOB TOTAL							\$66,409

27-JUL-94

MeansData for Lotus

Page

Estimate: Bidg. 720A Date: 8 July 1994  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City Index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
J02 SITWORK	225	\$0	\$6,176	\$0	\$0	\$6,176
J16 ELECTRICAL	676	\$50,413	\$15,585	\$0	\$0	\$68,998
<b>TOTAL</b>	<b>901</b>	<b>\$50,413</b>	<b>\$24,761</b>	<b>\$0</b>	<b>\$0</b>	<b>\$75,174</b>
SALES TAX	5.00%	\$2,521				
MATERIAL MARKUP	-40.00%	(\$20,165)				
LABOR MARKUP	-13.40%		(\$3,318)			
EQUIPT. MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY	\$32,768	\$21,443		\$0	\$0	\$54,211
CONTINGENCY	10.00%					\$5,421
BOND	2.50%					\$1,355
PROFIT	10.00%					\$5,421
<b>JOB TOTAL</b>						<b>\$66,409</b>



# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #:	7210
AREA:	
LAMP USE:	
HOURS/DAY	10
DAYS/WEEK	5
PEAK USE	
BUILDING VOL TAG	120

EXISTING INCANDESCENTS	WATTS	WATTS	WATTS
LAMPS @ 52	52	0	0
LAMPS @ 60	60	0	0
LAMPS @ 75	75	0	0
LAMPS @ 90	90	0	0
LAMPS @ 100	100	0	0

ELECTRIC COSTS.  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.78 PER KW

BASELINE ENERGY CONSUMPTION	155 KWH	ECO ENERGY CONSUMPTION	34 KWH
BASELINE DEMAND	342 KW	ECO DEMAND	122 KW
	0.66 KW		0.07 KW

COMPACT FLUORESCENT REPLACEMENT

1 LAMPS @	13 WATTS	13 WATTS
0 LAMPS @	0 WATTS	0 WATTS
3 LAMPS @	26 WATTS	0 WATTS

NET ENERGY SAVINGS	449 MWHR	NET DEMAND SAVINGS	\$7 MHR
NET ENERGY SAVINGS	0.42 MBTU/H	NET DOLLAR SAVINGS	\$9 MHR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

19 AUGUST 1994

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING #:	T210	ELECTRIC COSTS ENERGY CHARGE DEMAND CHARGE	\$0.0211 PER KWH \$11.76 PER KW
INCANDESCENT EXIT SIGNS	FLUORESCENT EXIT SIGNS	# OF EXIST SIGNS	REPLACEMENT FUTURE
WATTAGE	30	10	10 # EXIT SIGNS
WATTAGE	18	18	18 WATTAGE
BASELINE ENERGY CONSUMPTION	1,577 KWH/MONTH	ECO ENERGY CONSUMPTION	202 KWH/MONTH
BASELINE DEMAND	8.579 KW	ECO DEMAND	0.03 KW
NET ENERGY SAVINGS	4,730 MWH	NET DEMAND SAVINGS	\$21 M/R
NET ENERGY SAVINGS	4.48 MWTU/R	NET DOLLAR SAVINGS	\$49 M/R

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

BUILDING #: 7210  
 AREA: HANGAR BAY  
 DAILY USE: 10  
 HOURS/DAY 5  
 DAYS/WEEK 1 (YES, 2 NO)  
 PEAK USE:  
 BUILDING VOLTAGE: 277

ELECTRIC COSTS,  
 ENERGY CHARGE -- \$0.0211 PER KWH  
 DEMAND CHARGE -- \$11.76 PER KW

EXISTING FIXTURES SIZE AND Q	WATTS =	WATTS	WATTS =	WATTS
30 KW Q	200	0	64	0
456 KW Q	456	17760 WATTS	30 KW Q	11760 WATTS
50 KW Q	5075	63750 WATTS	50 KW Q	23660 WATTS

BASELINE ENERGY CONSUMPTION  
 105,700 KWH  
 662,000 MJ  
 71.49 KW

BASELINE DEMAND  
 326,792 MJ

NET ENERGY SAVINGS  
 244,938 MJ/YR  
 326,071 KWH/YR

NET ENERGY SAVINGS  
 326,071 KWH/YR

REPLACEMENT FEATURES SIZE AND Q	WATTS =	WATTS	WATTS =	WATTS
30 KW Q	64	0	64	0
30 KW Q	30	11760 WATTS	30 KW Q	11760 WATTS
50 KW Q	460	23660 WATTS	50 KW Q	23660 WATTS

ECO ENERGY CONSUMPTION  
 99,220 KWH  
 34,760 MJ

ECO DEMAND  
 34,760 MJ

NET DEMAND SAVINGS  
 \$5,196 MJ/YR

NET DOLLAR SAVINGS  
 \$7,212 MJ/YR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

15 AUGUST 1994

### EXTERIOR LIGHTING REPLACEMENT

BUILDING #: 72N	AREA USE: 4,400	ELECTRIC COSTS: ENERGY CHARGE — \$0.0211 PER KWH DEMAND CHARGE — \$11.78 PER KW
EXTERIOR FEATURES	REPLACEMENT FEATURES	
6 INCAN. @ 100 WATTS	6 IPS @ 100 WATTS	46 WATTS = 276 WATTS
200 WATTS	0 WATTS	0 WATTS = 0 WATTS
6 QUARTZ @ 454 WATTS	0 WATTS	0 WATTS = 0 WATTS
6 MV @ 2,600 WATTS	6 IPS @ 2,600 WATTS	136 WATTS = 0 WATTS
BASELINE ENERGY CONSUMPTION	ECO ENERGY CONSUMPTION	3,214 KWH
2,600 KWH	856 KWH	4,372 KWH
BASELINE DEMAND	ECO DEMAND	6.28 KW
NET ENERGY SAVINGS	NET DOLLAR SAVINGS	\$30 MYR
NET ENERGY SAVINGS	NET DOLLAR SAVINGS	\$132 KLYR
NET ENERGY SAVINGS	NET DOLLAR SAVINGS	0.85 RETURN

27-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7210 Date: 8 July 1994  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082121	DEMO. 2x4 FLUOR FIXTURES					237.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	114.95	\$0	\$3,164	\$0	\$0	\$3,164	
0207082123	DEMO. INCAND FIXTURES / EXIT SIGNS					17.00	
Unit values	2.26	0.00	7.10	0.00	0.00	7.10	
Totals	4.39	\$0	\$121	\$0	\$0	\$121	
0207082540	DEMO. HIGH BAY FIXTURES					89.00	
Unit values	1.00	0.00	27.50	0.00	0.00	27.50	
Totals	89.00	\$0	\$2,448	\$0	\$0	\$2,448	
J02 SITWORK		209	\$0	\$5,733	\$0	\$5,733	

27-Jul-94

MeansData for Lotus

Page 2

Line #	Description	Manhours	Matl	Laser	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 32W LAMP R S					24.00 EA.	
Unit values	6.94	26.74	22.52	0.00	0.00	0.00	49.26
Totals	22.58	\$642	\$540	\$0	\$0	\$0	\$1,182
1661302300	SUR FLUOR STRIP 4' W 2 32W LAMP R S				(qty)	EA.	
Unit values	1.00	28.65	23.82	0.00	0.00	0.00	32.67
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661304289	EXTERIOR 35W HPS WALL PACK				6.00 EA		
Unit values	1.00	75.00	27.50	0.00	0.00	0.00	102.50
Totals	6.00	\$450	\$165	\$0	\$0	\$0	\$615
1661304291	HIGH BAY, AL REFLECTOR 400W MH				\$0.00 EA		
Unit values	3.48	295.00	95.50	0.00	0.00	0.00	390.50
Totals	172.90	\$14,750	\$4,775	\$0	\$0	\$0	\$19,525
1661304292	HIGH BAY, AL REFLECTOR 250W MH				39.00 EA		
Unit values	3.48	243.00	95.50	0.00	0.00	0.00	338.50
Totals	135.64	\$9,477	\$3,725	\$0	\$0	\$0	\$13,202
1661307777	L.E.D. EXIT SIGN SINGLE FACE				10.00 EA		
Unit values	1.00	50.00	27.50	0.00	0.00	0.00	77.50
Totals	10.00	\$500	\$275	\$0	\$0	\$0	\$775
1661309601	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS				(qty)	EA	
Unit values	1.40	88.00	38.50	0.00	0.00	0.00	124.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS				(qty)	EA	
Unit values	1.51	84.00	41.50	0.00	0.00	0.00	123.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS				0.00 EA		
Unit values	1.60	90.00	44.00	0.00	0.00	0.00	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS				(qty)	EA	
Unit values	1.70	94.00	47.00	0.00	0.00	0.00	141.00

27-Jul-94

## MeansData for Lotus

Page 3

Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309607	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.14	73.00	31.50	0.00	213.00	EA	
Totals	242.82	\$15,549	\$6,710	\$0	0.00	\$0	304.50
							\$22,259
1661309909	SUR FLUOR 1X4' W 2 32W T8						
Unit values	1.14	96.00	31.50	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	117.50
							\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR						
Unit values	1.14	97.00	31.50	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	121.50
							\$0
1661309912	SUR FLUOR 2X4' W 3 32W T8						
Unit values	1.40	115.00	38.50	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	153.50
							\$0
1661388041	COMP FLUOR LAMP, 10 W TWIN TUBE GLCBE ASSEMBLY						
Unit values	0.13	14.50	3.44	0.00	(qty)	EA	
Totals	0.00	\$0	\$0	\$0	0.00	\$0	17.94
							\$0
1661388042	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT						
Unit values	1.00	25.50	27.50	0.00	1.00	EA	
Totals	1.00	\$25	\$28	\$0	0.00	\$0	53.00
							\$54

27-Jul-94

MeansData for Lotus

Page 4

Line #	Description	Manhours		Matl	Labor	Equipment	Sub	Total
J16 ELECTRICAL		592	\$41,394	\$16,216		\$0	\$0	\$57,612
ESTIMATE TOTAL		501	\$41,394	\$21,951		\$0	\$0	\$63,345
SALES TAX	5.00%		\$2,070					
MATL MARKUP	-40.00%		\$16,558					
LABOR MARKUP	-13.40%			(\$2,941)				
EQUIPT MARKUP	0.00%				\$0			
SUB MARKUP	0.00%					\$0		
TOTAL BEFORE CONTINGENCY			\$26,906	\$19,010		\$0	\$0	\$45,916
CONTINGENCY	10.00%							\$4,592
BOND	2.50%							\$1,148
PROFIT	10.00%							\$4,592
<b>JOB TOTAL</b>								<b>\$56,247</b>

27-Jul-94

## MeansData for Lotus

Page

Estimate: Bldg. 7210 Date: 6 July 1994  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
C02 SITECRK	209	\$0	\$5,733	\$0	\$0	\$5,733
U16 ELECTRICAL	592	\$41,394	\$16,218	\$0	\$0	\$57,612
<b>TOTAL</b>	<b>801</b>	<b>\$41,394</b>	<b>\$21,951</b>	<b>\$0</b>	<b>\$0</b>	<b>\$63,345</b>
SALES TAX	5.00%	\$2,070				
MATL MARKUP	-40.00%	(-\$16,558)				
LABOR MARKUP	-13.40%		(\$2,942)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	0.00%					
<b>TOTAL BEFORE CONTINGENC</b>	<b>\$26,906</b>	<b>\$19,010</b>		<b>\$0</b>	<b>\$0</b>	<b>\$45,916</b>
CONTINGENCY	10.00%					\$4,592
BOND	2.50%					\$1,148
PROFIT	10.00%					\$4,592
<b>JOB TOTAL</b>						<b>\$56,247</b>

## FORT CAMPBELL LIGHTING SURVEY

**ECO 4: INTERIOR / EXTERIOR LIGHTING**  
VALUATION: 100%

卷之三

BUILDING #:	7112
AREA:	OFFICES/STAFF/RELAX ROOM
AREA USE:	HOURS/DAY DAYS/WEEK
BUILDING VOL/TAGE	24 7 120

EXECUTIVE DATA

21 AMP G 500 WATT - 0 WATTS  
AC/DC/220V ENERGY CONSUMPTION 22.36  
DC/220V ENERGY CONSUMPTION 80.52  
ON/OFF INDICATOR 2.52

**NET ENERGY SAVINGS  
21.2% IN 2011**

LET DOLIA SAVAGE

三  
四  
一  
九

REPLACEMENT ESTIMATE DATA

2 FOOT	0.2 LUMENS	58 WFMXT =	-	0 WATTS
4 FOOT	0.1 LUMENS	29 WFMXT =	-	0.05 WATTS
6 FOOT	0.05 LUMENS	14 WFMXT =	-	0.01 WATTS
8 FOOT	0.025 LUMENS	7 WFMXT =	-	0.005 WATTS
10 FOOT	0.0125 LUMENS	3.5 WFMXT =	-	0.0025 WATTS

3' FOOT      0.2 LAMP @      125 WATT = 0 WATTS

ECO ENERGY CONSUMPTION

ECO DEMAND

三一堂

NET DESIGN

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
19 AUGUST 1994

INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7212  
AREA: RESTROOM/OFFICE  
CFL USE: 0  
HOURS/DAY: 10  
DAYS/WEEK: 7  
PEAK USE: 1 (1.YES, 2.NO)

BUILDING VOLTAGE:

EXISTING INCANDESCENTS  
6 LAMPS @ 32 WATTS = 312 WATTS  
1 LAMP @ 60 WATTS = 60 WATTS  
1 LAMP @ 75 WATTS = 75 WATTS  
1 LAMP @ 90 WATTS = 90 WATTS  
1 LAMP @ 100 WATTS = 100 WATTS

BASELINE ENERGY CONSUMPTION  
1,500 KWH  
5,395 MJ  
0.01 KW

COMPACT FLUORESCENT REPLACEMENT  
6 LAMPS @ 13 WATTS = 78 WATTS  
0 LAMPS @ 18 WATTS = 0 WATTS  
1 LAMPS @ 26 WATTS = 26 WATTS

BASELINE DEMAND  
1,500 KWH  
5,395 MJ  
0.01 KW

ECO ENERGY CONSUMPTION  
375 KWH  
1,363 MJ  
0.10 KW

ECO DEMAND  
NET DEMAND SAVINGS  
NET DOLLAR SAVINGS

4,036 MJ/YR  
3,033 MJ/YR

\$44 /YR  
\$67 /YR

27-JUL-94

MeansData for Locus

P&amp;I

Estimate: Bldg. 7212 Date: 8 July 1994  
 Description: Control Tower  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total				
		Manhours	Matl	Labor	Equipment	Sub
0207082121	DEMO, 2x4 FLUOR FIXTURES				35.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.3
Totals	16.98	\$0	\$467	\$0	\$0	\$46
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS				7.00	
Unit values	0.26	0.00	7.10	0.00	0.00	7.1
Totals	1.81	\$0	\$50	\$0	\$0	\$5
U02 SITWORK	19	\$0	\$517	\$0	\$0	\$51

27-JUL-94

MeansData for Lotus

Pag

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 32W LAMP R S					21.00	Ea.
Unit values	0.94	26.74	22.52	0.00	0.00	\$0	49.26
Totals	19.76	\$562	\$473	\$0	\$0	\$0	\$1,035
1661302300	SUR FLUOR STRIP 4' W 2 32W LAMP R S					(qty)	Ea.
Unit values	1.00	26.65	23.82	0.00	0.00	\$0	53.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661307777	L.E.D. EXIT SIGN SINGLE FACE					(qty)	EA
Unit values	1.00	185.00	27.50	0.00	0.00	\$0	212.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-C ACRYLIC LENS					(qty)	EA
Unit values	1.40	89.00	38.50	0.00	0.00	\$0	126.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.51	84.00	41.50	0.00	0.00	\$0	125.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.60	90.00	44.00	0.00	0.00	\$0	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					6.00	EA
Unit values	1.70	94.00	47.00	0.00	0.00	\$0	141.00
Totals	10.20	\$564	\$282	\$0	\$0	\$0	\$846
1661309807	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					6.00	EA
Unit values	1.14	73.00	31.50	0.00	0.00	\$0	104.50
Totals	9.12	\$584	\$252	\$0	\$0	\$0	\$836
1661309909	SUR FLUOR 1X4' W 2 32W T8					(qty)	EA
Unit values	1.14	86.00	31.50	0.00	0.00	\$0	117.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR					(qty)	EA
Unit values	1.14	90.00	31.50	0.00	0.00	\$0	121.50

27-Jul-94

## MeansData for Lotus

Page

	0.00	\$0	\$0	\$0	\$0	\$0	\$0
Totals							
1661388041	COMP FLUOR LAMP, 18 W TWIN TUBE GLCBE ASSEMBLY						
Unit values	0.13	14.50	3.44	0.00	(qty) 0.00	EA	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	17.94
1661388042	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT						
Unit values	1.00	25.50	27.50	0.00	7.00 0.00	EA	
Totals	7.00	\$179	\$193	\$0	\$0	\$0	53.00
							\$372

27-Jul-94

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		47	\$1,889	\$1,200	\$0	\$0	\$3,089
ESTIMATE TOTAL		66	\$1,889	\$1,717	\$0	\$0	\$3,606
SALES TAX	5.00%		\$94				
MATL MARKUP	-40.00%		(\$756)				
LABOR MARKUP	-13.40%			(\$230)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENC			\$1,228	\$1,487	\$0	\$0	\$2,715
CONTINGENCY	10.00%						\$271
BOND	2.50%						\$68
PROFIT	10.00%						\$271
JOB TOTAL							\$3,326

27-Jul-94

## MeansData for Lotus

Page

Estimate: Bldg. 7212 Date: 8 July 1994  
 Description: Control Tower  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
C02 SITWORK	19	\$0	\$517	\$0	\$0	\$517
U16 ELECTRICAL	47	\$1,889	\$1,200	\$0	\$0	\$3,089
<b>TOTAL</b>	<b>66</b>	<b>\$1,889</b>	<b>\$1,717</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,606</b>
SALES TAX	5.00%	\$94				
MATL MARKUP	-40.00%	(\$756)				
LABOR MARKUP	-13.40%		(\$230)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENC</b>		<b>\$1,228</b>	<b>\$1,487</b>	<b>\$0</b>	<b>\$0</b>	<b>\$2,715</b>
CONTINGENCY	10.00%					\$271
BCND	2.50%					\$68
<b>PROFIT</b>	<b>10.00%</b>					<b>\$271</b>
<b>JOB TOTAL</b>						<b>\$3,326</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7214  
AREA: ENTIRE BLDG  
AREA USE:  
MONDAY - 14  
TUESDAY - 5  
DAYS/WEEK  
BUILDING VOLTAGE 277

ELECTRIC COSTS,  
ENERGY CHARGE  
DEMAND CHARGE

\$0.0711 PER KWH  
\$11.76 PER KW

### EXISTING FIXTURE DATA

2 FOOT 2 LAMP U 68 W/FXT = 0 WATTS

4 FOOT 1 LAMP @ 40 W/FXT = 0 WATTS  
180 2 LAMP @ 84 W/FXT = 15420 WATTS  
5 3 LAMP @ 126 W/FXT = 630 WATTS  
4 LAMP @ 132 W/FXT = 0 WATTS

8 FOOT 2 LAMP @ 100 W/FXT = 0 WATTS  
Baseline Energy Consumption  
Baseline Demand

35,215 KWH/YR

184,373 KWH/YR

1007 KW

ECO ENERGY CONSUMPTION

ECO DEMAND

NET ENERGY SAVINGS  
NET ENERGY SAVINGS

57,868 KWH  
54,930 KWH

NET DEMAND SAVINGS  
NET DOLLAR SAVINGS

\$616 MYR  
\$359 MYR

### REPLACEMENT FIXTURE DATA

2 FOOT 0 2 LAMP U @ 56 W/FXT = 0 WATTS

4 FOOT 0 1 LAMP @ 20 W/FXT = 0 WATTS  
160 2 LAMP @ 56 W/FXT = 9240 WATTS  
5 3 LAMP @ 87 W/FXT = 435 WATTS  
4 LAMP @ 116 W/FXT = 0 WATTS

8 FOOT 0 2 LAMP @ 125 W/FXT = 0 WATTS

Baseline Energy Consumption  
Baseline Demand

35,253 KWH/YR

127,363 KWH/YR

9.72 KW

FORT CAMPBELL LIGHTING SURVEY	
ECO 1: INTERIOR / EXTERIOR LIGHTING	
19 AUGUST 1984	
INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT	
BUILDING #: 7214	RESTROOM
AREA: CLASS USE:	3
HOURS/DAY: 5	
DAYS/WEEK: 2 (1-YE3, 2-MO)	
BUILDING VOL TAG: 120	
EXISTING INCANDESCENTS	
LAMPS @ 52 WATTS =	0 WATTS
1 Lamps @ 60 WATTS =	60 WATTS
1 Lamps @ 75 WATTS =	75 WATTS
1 Lamps @ 90 WATTS =	90 WATTS
1 Lamps @ 100 WATTS =	100 WATTS
COMPACT FLUORESCENT REPLACEMENT	
1 Lamps @ 13 WATTS =	13 WATTS
0 Lamps @ 16 WATTS =	0 WATTS
0 Lamps @ 25 WATTS =	0 WATTS
BASELINE ENERGY CONSUMPTION	
67 KWH/	67 KWH
168 MJ/	168 MJ
616 KJ/	616 KJ
ECO ENERGY CONSUMPTION	
132 KWH/	132 KWH
0.13 MJ/	0.13 MJ
NET ENERGY SAVINGS	50 KWH
NET ENERGY SAVINGS	\$1 /JR
NET DEMAND	661 KJ
NET DEMAND	
NET DOLLAR SAVINGS	

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
19 AUGUST 1994

### INTERIOR LIGHTING - INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7214	OFFICE	ELECTRICAL COSTS.	\$0.0211 PER KWH
AREA:	LAMP USE:	ENERGY CHARGE	\$11.78 PER KW
	HOURS/DAY	Demand Charge	
	5		
	PEAK USE		
	1 (1-YES, 2-NON)		
BUILDING VOLTAGE	120		
<hr/>			
EXISTING INCANDESCENTS	405 WATTS =	880 WATTS	58 WATTS
2 LAMPS @			12 LAMP @
BASELINE ENERGY CONSUMPTION		1,693 KWH	121' KWH
BASELINE DEMAND		4.645 KW	4.34 KW
		0.81 KW	0.64 KW
<hr/>			
NET ENERGY SAVINGS	6,631 KWH	NET DEMAND SAVINGS	\$196 MTR
NET ENERGY SAVINGS	6.34 MTR/W	NET DOLLAR SAVINGS	\$133 MTR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

19 AUGUST 1984

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

NUMBER OF:	724	ELECTRIC COSTS: ENERGY CHARGE DEMAND CHARGE	\$0.0211 PER KWH \$11.75 PER KW
INCANDESCENT EXIT SIGNS EXIT SIGNS	0	REPLACEMENT FIXTURE: EXIT SIGNS	1
VATTAGE	30	WATTAGE	10
FLUORESCENT EXIT SIGNS EXIT SIGNS	?	WATTAGE	3
BASELINE ENERGY CONSUMPTION BASELINE DEMAND	132 KWH/MONTH 546 KWH/YR 0.08 KW	ECO ENERGY CONSUMPTION ECO DEMAND	26 KWH/MONTH 55 KWH/YR 0.03 KW
NET ENERGY SAVINGS	473 KWH/YR 0.65 KW/HOUR	NET DOLLAR SAVINGS NET ENERGY SAVINGS	\$2 NR \$5 NR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
11 AUGUST 1994

**BUILDING #:** 7214      **HANGAR/SHOP BAYS:** 14  
**AREA:** 11,745 SF      **USE:** 14 BAYS, 2 ROOF  
**LINE:** 14'0" x 20'0"      **ROOF:** 5'  
**HOURS/DAY:** 24 HRS      **WEEK:** 5 DYS.  
**DAY/SWEEK:** 144 HRS      **YEAR:** 117.45  
**PLAN USE:** 14 BAYS, 2 ROOF

ELECTRIC COSTS.  
ENERGY CHARGE — \$0.0211 PER KWH  
DEMAND CHARGE — \$11.74 PER KW

EXISTING FIXTURES	REPLACEMENT FIXTURES	WATTS	WATTS
200 WATTS - AND @ 200 WATTS - 0 WATTS	HPS @ 23 Mw @ 96 Mw @	64 WATTS = 0 WATTS	64 WATTS = 0 WATTS
454 WATTS - 106442 WATTS	- 23 Mw @	300 WATTS = 630 WATTS	300 WATTS = 630 WATTS
1075 WATTS - 153260 WATTS	- 96 Mw @	460 WATTS = 4460 WATTS	460 WATTS = 4460 WATTS

EEG EMESES COWS UNDER 1200  
1600/1600 MM

**NET DEMAND SAVINGS**  
**NET DOLLAR SAVINGS**  
\$12,653 NVR  
\$8,867 NVR

620,075 square  
miles

NET EQUITY COMES

27-Jul-94

MeansData for Lotus

Page :

Estimate: Eldg. 7214 Date: 8 July 1994  
 Description: Hanger  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total					
0207082119	DEMO, 2x2, 1x4 FLUOR FIXTURES						
Unit values	0.36	0.00	10.00	0.00	0.00	10.00	
Totals	58.24	\$0	\$1,600	\$0	\$0	\$1,600	
0207082121	DEMO, 2x4 FLUOR FIXTURES						
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	3.43	\$0	\$57	\$0	\$0	\$57	
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS						
Unit values	0.26	0.00	7.10	0.00	0.00	7.10	
Totals	1.03	\$0	\$28	\$0	\$0	\$28	
0207082560	DEMO, HIGH BAY FIXTURES						
Unit values	1.00	0.00	27.50	0.00	0.00	27.50	
Totals	119.00	\$0	\$3,273	\$0	\$0	\$3,273	
U02 SITWORK	181	\$0	\$4,968	\$0	\$0	\$4,968	

27-Jul-94

## MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total	(qty)	EA.
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S								
Unit values	0.94	26.74		22.52		0.00		0.00	49.25
Totals	0.00	\$0		\$0		\$0		\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S							(qty)	EA.
Unit values	1.00	28.65		23.82		0.00		0.00	52.47
Totals	0.00	\$0		\$0		\$0		\$0	\$0
1661304291	HIGH BAY, AL REFLECTOR 400W MH							96.00	EA
Unit values	3.49	295.00		95.50		0.00		0.00	390.50
Totals	333.89	\$28,320		\$9,168		\$0		\$0	\$37,488
1661304292	HIGH BAY, AL REFLECTOR 250W MH							23.00	EA
Unit values	3.49	243.00		95.50		0.00		0.00	338.50
Totals	75.99	\$5,889		\$2,197		\$0		\$0	\$7,786
1661307777	L.E.D. EXIT SIGN SINGLZ FACE							1.00	EA
Unit values	1.00	50.00		27.50		0.00		0.00	77.50
Totals	1.00	\$50		\$28		\$0		\$0	\$78
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS							(qty)	EA
Unit values	1.40	88.00		38.50		0.00		0.00	126.50
Totals	0.00	\$0		\$0		\$0		\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS							(qty)	EA
Unit values	1.51	84.00		41.50		0.00		0.00	125.50
Totals	0.00	\$0		\$0		\$0		\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS							(qty)	EA
Unit values	1.60	90.00		44.00		0.00		0.00	134.00
Totals	0.00	\$0		\$0		\$0		\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS							(qty)	EA
Unit values	1.70	94.00		47.00		0.00		0.00	141.00
Totals	0.00	\$0		\$0		\$0		\$0	\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS							(qty)	EA
Unit values	1.14	73.00		31.50		0.00		0.00	104.50

27-Jul-94

## MeansData for Lotus

Pg

<b>Totals</b>	0.00	\$0	\$0	\$0	\$0	\$0	\$
1861303309	SUR FLUOR 1X4' W 2 32W T8						
Unit values	1.14	66.00	31.50	0.00	106.00	EA	
<b>Totals</b>	120.84	\$9,116	\$3,339	\$0	0.00	\$17.5	
					\$0	\$12,45	
1861303310	INDUSTRIAL FLUOR 1X4' W 2 32W T8						
Unit values	1.14	66.00	31.50	0.00	55.00	EA	
<b>Totals</b>	62.70	\$3,300	\$1,733	\$0	0.00	\$1.5	
					\$0	\$5,00	
1861303312	SUR FLUOR 2X4' W 3 32W T8						
Unit values	1.40	115.00	38.50	0.00	5.00	EA	
<b>Totals</b>	7.00	\$575	\$193	\$0	0.00	\$153.5	
					\$0	\$76	
1861328041	COMP FLUOR LAMP, 15 W TWIN TUBE GLOBE ASSEMBLY						
Unit values	0.13	14.50	3.44	0.00	(qty)	EA	
<b>Totals</b>	0.00	\$0	\$0	\$0	0.00	\$17.5	
					\$0	\$1	
1861388042	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT						
Unit values	1.00	25.50	27.50	0.00	1.00	EA	
<b>Totals</b>	1.00	\$26	\$28	\$0	0.00	\$53.0	
					\$0	\$8	

13

27-JUL-94

MeansData for Lotus

P

Line #	Description							
		Manhours	Matl	Labor	Equipment	Sub	Total	
U16 ELECTRICAL	607	\$46,976	\$16,686			\$0	\$0	\$63,6
ESTIMATE TOTAL	738	\$46,976	\$21,654			\$0	\$0	\$68,6
SALES TAX	5.00%	\$2,349						
NATL MARKUP	-40.00%	(\$18,790)						
LABOR MARKUP	-13.40%			(\$2,902)				
EQUIPT MARKUP	0.00%				\$0			
SUB MARKUP	0.00%					\$0		
TOTAL BEFORE CONTINGENCY	\$30,534	\$18,752				\$0	\$0	\$49.2
CONTINGENCY	10.00%							\$4.3
BOND	2.50%							\$1.2
PROFIT	10.00%							\$4.9
JOB TOTAL								\$60,3

PAGE 3

27-Jul-94

MeansData for Lotus

Pc

Estimate: Bldg. 7214 Date: 8 July 1994  
 Description: Hanger  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
J02 SITWORK	:81	\$0	\$4,965	\$0	\$0	\$4,96
J16 ELECTRICAL	607	\$46,976	\$16,686	\$0	\$0	\$63,66
<b>TOTAL</b>	<b>788</b>	<b>\$46,976</b>	<b>\$21,654</b>	<b>\$0</b>	<b>\$0</b>	<b>\$68,61</b>
SALES TAX	5.00%	\$2,349				
MATL. MARKUP	-40.00%	(\$18,790)				
LABOR MARKUP	-13.40%		(\$2,902)			
EXCPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENC</b>		<b>\$30,534</b>	<b>\$18,732</b>	<b>\$0</b>	<b>\$0</b>	<b>\$49,26</b>
CONTINGENCY	10.00%					\$4,92
BOND	2.50%					\$1,23
PROFIT	10.00%					\$4,92
<b>JOB TOTAL</b>						<b>\$60,31</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

卷之三

BUILDING #: 7218 ENTIRE BLDG AREA: 14-5 DUE TO BUILDING VOLTAGEx 277

ELECTRIC COSTS  
ENERGY CHARGE  
DEMAND CHARGE

REPLACEMENT FIXTURE DATA

6 FOOT 2 LAMP @ NO VARIABILITY = 9 WATTS  
BASELINE ENERGY CONSUMPTION  
BASELINE DEMAND

	6.75¢ / KWHR	11.4¢ / KWHR	18.9¢ / KW
247,664	247,664	247,664	
18.9¢			

WILTTENBERG'S

२५३ मन्त्र

**NET DEMAND SAVINGS  
NET DONATION SAVINGS**

3927 MR  
39276 MR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7218  
 AREA: RESTROOM  
 LAMP USE: 3  
 HOURS/DAY: 5  
 DAYS/WEEK: 2 (1-YES, 2-NO)  
 PEAK USE: 2  
 PLUGGING VOLTAGE: 120

INCANDESCENTS		COMPACT FLUORESCENT REPLACEMENT		ECO ENERGY CONSUMPTION	
LAMPS @	WATTS @	1 LAMPS @	13 WATTS =	10 KWH	\$0 YR
1 LAMPS @	52 WATTS =	0 LAMPS @	0 WATTS =	37 MJ	\$1 YR
1 LAMPS @	60 WATTS =	0 LAMPS @	0 WATTS =	0.91 KW	
1 LAMPS @	75 WATTS =	0 LAMPS @	0 WATTS =		
1 LAMPS @	90 WATTS =	0 LAMPS @	0 WATTS =		
1 LAMPS @	100 WATTS =	0 LAMPS @	0 WATTS =		
BASELINE ENERGY CONSUMPTION		47 KWH			
BASELINE DEMAND		168 MJ			
NET ENERGY SAVINGS		132 MJ/YR			
NET ENERGY SAVINGS		0.13 MJ/UNIT/HR			
NET DOLLAR SAVINGS					

# FORT CAMPBELL LIGHTING SURVEY

ECO 4: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

## INTERIOR LIGHTING - FLUORESCENT LAMP REPLACEMENT

BUILDING #: 7248	OFFICE	ELECTRIC COSTS, ENERGY CHARGE DEMAND CHARGE	\$0.0211 PER KWH \$11.76 PER KW
AREA: LAMP USE:	6 5 1 (1-YES, 2-NO)		
HOURS/DAY			
DAYSPR/EK:			
PER DAY USE			
BUILDING VOLTAGE: 120			
ESTIMATED RECHANGES:	405 WATTS = 819 WATTS	FLUORESCENT FIXTURE REPLACEMENT 12 LAMP @ 55 WATT =	58 WATTS
2 LAMPS @			
BASELINE ENERGY CONSUMPTION	7,685 KWH 4,665 MJ 6,611 KJW	ECO ENERGY CONSUMPTION	171 KWH 434 MJ 6,66 KJW
BASELINE DEMAND		ECO DEMAND	
NET ENERGY SAVINGS	\$,631 MAYA \$,34 MEFUNIR	NET DEMAND SAVINGS	\$106 MFR
NET ENERGY SAVINGS		NET DOLLAR SAVINGS	\$139 MFR

FORT CAMPBELL LIGHTING SURVEY					
Eco 1: INTERIOR/EXTERIOR LIGHTING					
11 AUGUST 1994					
<b>INTERIOR LIGHTING: EXIT SIGN REPLACEMENT</b>					
NUMBER OF:	7218	ELECTRIC COSTS: ENERGY CHARGE	\$0.0211 PER KWH \$11.78 PER KW	REPLACEMENT FIXTURE # EXIT SIGNS	3
DEMAND CHARGE				#	
FLUORESCENT EXIT SIGNS		16	WATTAGE		3
EXIT SIGNS					
WATTAGE	30				
BASELINE ENERGY CONSUMPTION	473 KWH/YR	ECO ENERGY CONSUMPTION	79 KWH/YR		
	1,162 KWH/YR		284 KWH/YR		
BASELINE DEMAND	0.45 KW	ECO DEMAND	0.09 KW		
NET ENERGY SAVINGS	1,419 KWH/YR	NET DEMAND SAVINGS	\$6 NR		
NET ENERGY SAVINGS	1.36 MWH/YR	NET DOLLAR SAVINGS	\$15 NR		
NET ENERGY SAVINGS					

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: EXTERIOR / EXTERIOR LIGHTING

12 AUGUST 1994

BUILDING #: 7218  
 AREA: HANGAR/SHOP BAYS  
 AREA USE: 14  
 HOURS/DAY 5  
 DAYSPREEK 1 (1-YES, 2-NOT)  
 PEAK USE 1  
 BUILDING VOLTAGE: 227.

ELECTRIC COSTS.  
 ENERGY CHARGE \$0.0211 PER KWH  
 DEMAND CHARGE \$1178 PER KW

EXISTING FIXTURES		REPLACEMENT FIXTURES		ECO ENERGY CONSUMPTION	
INCANDE @ 200 WATTS	0 WATTS	HPS @ 300 WATTS	64 WATTS	0 WATTS	0 WATTS
INCANDE @ 454 WATTS	12712 WATTS	300 WATTS	300 WATTS	8400 WATTS	8400 WATTS
INCANDE @ 903 WATTS	16988 WATTS	300 WATTS	400 WATTS	44160 WATTS	44160 WATTS
BASELINE ENERGY CONSUMPTION		421,928 KWH		197,318 KWH	
BASELINE DEMAND		1,518,911 MJ		699,746 MJ	
NET ENERGY SAVINGS		830,165 MJ/YR		\$8,965 YR	
NET ENERGY SAVINGS		766,811 MJ/YR		\$13,821 YR	
NET DOLLAR SAVINGS		ECO DEMAND		52.56 KW	

27-Jul-94

## MeansData for Lotus

Page

Estimate: Bldg. 7218 Date: 8 July 1994  
 Description: Hanger  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description					
		Manhours	Matl	Labor	Equipment	Sub
0207082119	DEMO, 2x2, 1x4 FLUOR FIXTURES				201.00	
Unit values	0.36	0.00	10.00	.00	0.00	10.00
Totals	73.16	\$0	\$2,010	\$0	\$0	\$2,010
0207082121	DEMO, 2x4 FLUOR FIXTURES				16.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.35
Totals	7.76	\$0	\$214	\$0	\$0	\$214
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS				6.00	
Unit values	0.26	0.00	7.10	0.00	0.00	7.10
Totals	1.55	\$0	\$43	\$0	\$0	\$43
0207082540	DEMO, HIGH BAY FIXTURES				124.00	
Unit values	1.00	0.00	27.50	0.00	0.00	27.50
Totals	124.00	\$0	\$3,410	\$0	\$0	\$3,410
002 SITENWORK	207	\$0	\$5,677	\$0	\$0	\$5,677

27-Jul-94

MeansData for Iocus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R.S.					(qty)	EA.
Unit values	0.94	26.74	22.52	0.00	0.00	0.00	40.26
Totals	0.00	\$0	\$0	\$0	\$0	.50	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R.S.					(qty)	EA.
Unit values	1.00	28.65	23.82	0.00	0.00	0.00	52.47
Totals	0.00	\$0	\$0	\$0	\$0	.50	\$0
1661304291	HIGH BAY, AL REFLECTOR 400W MH					96.00	EA
Unit values	3.48	295.00	95.50	0.00	0.00	0.00	390.50
Totals	333.89	\$28,320	\$9,168	\$0	\$0	\$0	\$37,488
1661304292	HIGH BAY, AL REFLECTOR 250W MH					28.00	EA
Unit values	3.48	243.00	95.50	0.00	0.00	0.00	338.50
Totals	97.38	\$6,094	\$2,676	\$0	\$0	\$0	\$9,478
1661307777	L.E.D. EXIT SIGN SINGLE FACE					3.00	EA
Unit values	1.00	50.00	27.50	0.00	0.00	0.00	77.50
Totals	3.00	\$150	\$83	\$0	\$0	\$0	\$233
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					(qty)	EA
Unit values	1.40	88.00	38.50	0.00	0.00	0.00	126.50
Totals	0.00	\$0	\$0	\$0	\$0	.50	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.51	84.00	41.50	0.00	0.00	0.00	125.50
Totals	0.00	\$0	\$0	\$0	\$0	.50	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.60	90.00	44.00	0.00	0.00	0.00	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.70	94.00	47.00	0.00	0.00	0.00	141.00
Totals	0.00	\$0	\$0	\$0	\$0	.50	\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					0.00	EA
Unit values	1.14	73.00	31.50	0.00	0.00	0.00	104.50

PAGE 3-21

27-Jul-94

## MeansData for Lotus

Page : 1

Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
16613099C9	SUR FLUOR 1X4' W 2 32W T8				114.00 EA		
Unit values	1.14	86.00	31.50	0.00	0.00	117.50	
Totals	129.96	\$9,804	\$3,591	\$0	\$0	\$13,395	
16613099C0	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR				68.00 EA		
Unit values	1.14	60.00	31.50	0.00	0.00	91.50	
Totals	100.32	\$5,280	\$2,772	\$0	\$0	\$6,052	
1661309512	SUR FLUOR 2X4' W 3 32W T8				16.00 EA		
Unit values	1.40	115.00	38.50	0.00	0.00	153.50	
Totals	22.40	\$1,840	\$616	\$0	\$0	\$2,456	
1661388C41	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY				(qty) EA		
Unit values	0.13	14.50	3.44	0.00	0.00	17.94	
Totals	0.00	\$0	\$0	\$0	\$0	\$0	
1661388C42	COMP FLUOR FIX, 2 13 W PL WALL / CEILING MOUNT				1.00 EA		
Unit values	1.00	25.50	27.50	0.00	0.00	53.00	
Totals	1.00	\$26	\$28	\$0	\$0	\$54	

27-JUL-94

## MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
J16 ELECTRICAL		699	\$32,224	\$18,932		\$0	\$71,156
ESTIMATE TOTAL		695	\$52,224	\$24,609		\$0	\$76,833
SALES TAX	5.00%		\$2,611				
MATL MARKUP	40.00%	(-\$20,890)					
LABOR MARKUP	13.40%			(\$3,298)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY		\$33,946	\$21,311		\$0	\$0	\$55,257
CONTINGENCY	10.00%						\$5,526
SEND	2.50%						\$1,381
PROFIT	10.00%						\$5,526
JOB TOTAL							\$67,690

27-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7218 Date: 6 July 1994  
 Description: Hanger  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
UC2 SITEWORK	207	\$0	\$5,677	\$0	\$0	\$5,677
U16 ELECTRICAL	588	\$52,224	\$18,932	\$0	\$0	\$71,156
<b>TOTAL</b>	<b>895</b>	<b>\$52,224</b>	<b>\$24,609</b>	<b>\$0</b>	<b>\$0</b>	<b>\$76,833</b>
SALES TAX	5.00%	\$2,611				
MATL MARKUP	-40.00%	(-\$20,890)				
LABOR MARKUP	-13.40%		(-\$3,298)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$33,946</b>	<b>\$21,311</b>	<b>\$0</b>	<b>\$0</b>	<b>\$55,257</b>
CONTINGENCY	10.00%					\$5,526
BOND	2.50%					\$1,381
PROFIT	10.00%					\$5,526
<b>JCB TOTAL</b>						<b>\$67,690</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO #: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

### EXTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7261  
AREA: ENTRANCE BLDG  
POWER SOURCE: 14  
DAYS PER WEEK: 5  
BUILDING VOLTAGE: 277

ELECTRIC COSTS:  
ENERGY CHARGE: \$0.0211 PER KWH  
DEMAND CHARGE: \$117/M PER KW

### EXISTING FIXTURE DATA

2 FOOT	2 LAMP U	90 WATT =	0 WATTS
4 FOOT	1 LAMP @ 132 WATT	=	0 WATTS
4 FOOT	2 LAMP @ 132 WATT	=	264 WATTS
4 FOOT	3 LAMP @ 144 WATT	=	432 WATTS
4 FOOT	4 LAMP @ 142 WATT	=	568 WATTS

### REPLACEMENT FIXTURE DATA

2 FOOT	0.2 LAMP U @ 50 WATT	=	0 WATTS
4 FOOT	0.1 LAMP @ 230 WATT	=	230 WATTS
4 FOOT	0.2 LAMP @ 230 WATT	=	460 WATTS
4 FOOT	0.3 LAMP @ 230 WATT	=	690 WATTS
4 FOOT	0.4 LAMP @ 230 WATT	=	920 WATTS
8 FOOT	0.2 LAMP @ 125 WATT	=	0 WATTS

NET ENERGY SAVINGS	32,367 kWh	NET DOLLAR SAVINGS	\$349/MR
NET ENERGY SAVINGS	30,518 kWh	NET DOLLAR SAVINGS	\$318/MR

PER KWH	\$0.0211
PER KW	\$117/M

PER KWH	\$0.0211
PER KW	\$117/M

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

19 AUGUST 1984

## INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING #: T243

ELECTRIC COSTS:	
ENERGY CHARGE	$\frac{50.0211}{311.78}$ PER KWH
DEMAND CHARGE	PER KW

REPLACEMENT COSTS:	
EXIT SIGNS	2
WATTAGE	16

INCANDESCENT EXIT SIGNS	PLACES, EXIT SIGNS	ECO ENERGY CONSUMPTION	NET DOLLAR SAVINGS
# EXIT SIGNS	# EXIT SIGNS	ECO DEMAND	\$4 NR
WATTAGE	WATTAGE	NET DOLLAR SAVINGS	\$10 NR
30	16	0.01 KW	
1.126 KW/YR			
0.04 KW			
1.126 KW/YR			
0.04 KW			

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING  
19 AUGUST 1994

BUILDING #: 7243  
AREA:  
AREA USE:  
HOURS/DAY 14  
DAYS/WEEK 5  
PEAK USE 1 (1 YES, 2 NO)  
BUILDING VOLTAGE 277

ELECTRIC COSTS:  
ENERGY CHARGE: \$0.0211 PER KWH  
DEMAND CHARGE: \$11.78 PER KW

REPLACEMENT FIXTURES:  
0 HPS @ 64 WATTS 0 WATTS  
0 MH @ 300 WATTS 0 WATTS  
120 MH @ 460 WATTS 55200 WATTS

ECO ENERGY CONSUMPTION:  
469.359 KWH 269.928 KWH  
1,650,416 MJ 723,341 MJ  
726.00 KW 55.20 KW

NET DEMAND SAVINGS \$10,432/YR  
NET DOLLAR SAVINGS \$16,101/YR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

### EXTERIOR LIGHTING REPLACEMENT

BUILDING #: 7243

AREA USE:  
HOURS/YR 4400

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.78 PER KW

EXISTING FIXTURES	WATTS =	WATTS =	WATTS =	WATTS =
9 INCAN. @ 100	900 WATTS	9 HPS @	414 WATTS	0 WATTS
1 QUARTZ @ 200	0 WATTS	0 HPS @	0 WATTS	0 WATTS
— MV @ 454	0 WATTS	0 HPS @	168 WATTS	—

BASELINE ENERGY CONSUMPTION 3,360 KWH  
14,200 MJ  
0.99 KW

ECO DEMAND

1,822 KWH  
6,559 MJ  
0.41 KW

ECO ENERGY CONSUMPTION 770W  
450 MJ

ECO DEMAND

NET ENERGY SAVINGS

7,888 MJ/YR

NET DOLLAR SAVINGS

\$45 MYR

27-Jul-94

## MeansData for LOTUS

Page

Estimate: Bldg. 7243 Date: 8 July 1994  
 Description: Hanger  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082119	DEMO, 2x2, 1x4 FLUOR FIXTURES					10.00	
Unit values	0.36	0.00	10.00	0.00	0.00	0.00	10.00
Totals	3.64	\$0	\$100	\$0	\$0	\$0	\$100
0207082121	DEMO, 2x4 FLUOR FIXTURES					85.00	
Unit values	0.49	0.00	13.35	0.00	0.00	0.00	13.35
Totals	41.23	\$0	\$1,135	\$0	\$0	\$0	\$1,135
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					11.00	
Unit values	0.26	0.00	7.10	0.00	0.00	0.00	7.10
Totals	2.84	\$0	\$78	\$0	\$0	\$0	\$78
0207082540	DEMO, HIGH BAY FIXTURES					120.00	
Unit values	1.00	0.00	27.50	0.00	0.00	0.00	27.50
Totals	120.00	\$0	\$3,300	\$0	\$0	\$0	\$3,300
U02 SITENCRK		168	\$0	4,613	\$0	\$0	\$4,613

27-Jul-94

## MeansData for Lotus

PAC

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S					(qty)	Ea.
Unit values	0.94	26.74	22.52	0.00	0.00	0.00	49.26
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S					(qty)	Ea.
Unit values	1.00	26.65	23.82	0.00	0.00	0.00	52.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661304289	EXTERIOR 25W HPS WALL PACK					9.00	EA
Unit values	1.00	75.00	27.50	0.00	0.00	0.00	102.50
Totals	9.00	\$675	\$248	\$0	\$0	\$0	\$923
1661304291	HIGH BAY, AL REFLECTOR 400W MH					120.00	EA
Unit values	3.48	295.00	95.50	0.00	0.00	0.00	390.50
Totals	417.36	\$35,400	\$11,460	\$0	\$0	\$0	\$46,660
1661307777	L.E.D. EXIT SIGN SINGLE FACE					2.00	EA
Unit values	1.00	50.00	27.50	0.00	0.00	0.00	77.50
Totals	2.00	\$100	\$55	\$0	\$0	\$0	\$150
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					(qty)	Ea.
Unit values	1.40	68.00	38.50	0.00	0.00	0.00	126.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					79.00	EA
Unit values	1.51	84.00	41.50	0.00	0.00	0.00	125.50
Totals	119.29	\$6,636	\$3,379	\$0	\$0	\$0	\$9,915
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.60	90.00	44.00	0.00	0.00	0.00	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.70	94.00	47.00	0.00	0.00	0.00	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					(qty)	EA
Unit values	1.14	73.00	31.50	0.00	0.00	0.00	104.50

PAGE 3-1

27-Jul-94

## MeansData for Lotus

Page

Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309909	SUR FLUOR 1X4' W 2 32W T8				0.00	EA	
Unit values	1.14	86.00	31.50	0.00	0.00		117.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR				10.00	EA	
Unit values	1.14	60.00	31.50	0.00	0.00		91.50
Totals	11.40	\$600	\$315	\$0	\$0	\$0	\$915
1661309911	SUR FLUOR 2X4' W 2 32W T8				6.00	EA	
Unit values	1.29	95.00	35.50	0.00	0.00		130.50
Totals	7.74	\$570	\$213	\$0	\$0	\$0	\$783
1661398041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY				(gcy)	EA	
Unit values	0.13	14.00	3.44	0.00	0.00		17.94
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0

27-JUL-94

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		567	\$43,981	\$15,570		\$0	\$69,551
ESTIMATE TOTAL		735	\$43,981	\$20,163		\$0	\$64,154
SALES TAX	5.00%		\$2,199				
MATL MARKUP	-40.00%		(\$17,592)				
LABOR MARKUP	-13.40%			(\$2,705)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY		\$28,588	\$17,478		\$0	\$0	\$46,066
CONTINGENCY	10.00%						\$4,607
BOND	2.50%						\$1,152
PROFIT	10.00%						\$4,637
JOB TOTAL							<b>\$56,431</b>

27-Jul-94

MeansData for Lotus

Page  
5

Estimate: Bidg. 7243 Date: 8 July 1994  
 Description: Ranger  
 Project: Lightning Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City Index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
C02 SITWORK	168	\$0	\$4,613	\$0	\$0	\$4,613
C16 ELECTRICAL	567	\$43,981	\$15,570	\$0	\$0	\$59,551
<b>TOTAL</b>	<b>735</b>	<b>\$43,981</b>	<b>\$20,183</b>	<b>\$0</b>	<b>\$0</b>	<b>\$64,164</b>
SALES TAX	5.00%	\$2,199				
MATL MARKUP	-10.00%	(\$17,592)				
LABOR MARKUP	-13.40%		(\$2,705)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>	<b>\$28,588</b>	<b>\$17,478</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$46,065</b>
CONTINGENCY	10.00%					\$4,607
BOND	2.50%					\$1,152
PROFIT	10.00%					\$4,607
<b>JOB TOTAL</b>						<b>\$56,431</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1991

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7205

ENTIRE BLDG

AREA: 14

100% DAY

5 DAYS/WEEK

BUILDING VOLTAGE 277

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.76 PER KW

### EXISTING FIXTURE DATA

2 FOOT	2 LAMP U	85 W/FIXT =	9 W	76
--------	----------	-------------	-----	----

4 FOOT	2 LAMP U	85 W/FIXT =	9 W	76
--------	----------	-------------	-----	----

6 FOOT	2 LAMP U	85 W/FIXT =	9 W	76
--------	----------	-------------	-----	----

8 FOOT	2 LAMP U	85 W/FIXT =	9 W	76
--------	----------	-------------	-----	----

10 FOOT	2 LAMP U	85 W/FIXT =	9 W	76
---------	----------	-------------	-----	----

12 FOOT	2 LAMP U	85 W/FIXT =	9 W	76
---------	----------	-------------	-----	----

14 FOOT	2 LAMP U	85 W/FIXT =	9 W	76
---------	----------	-------------	-----	----

### REPLACEMENT FIXTURE DATA

2 FOOT	0.2 LAMP U	58 W/FIXT =	0 W	0 WATTS
--------	------------	-------------	-----	---------

4 FOOT	0.2 LAMP U	58 W/FIXT =	0 W	0 WATTS
--------	------------	-------------	-----	---------

6 FOOT	0.2 LAMP U	58 W/FIXT =	0 W	0 WATTS
--------	------------	-------------	-----	---------

8 FOOT	0.2 LAMP U	58 W/FIXT =	0 W	0 WATTS
--------	------------	-------------	-----	---------

10 FOOT	0.2 LAMP U	58 W/FIXT =	0 W	0 WATTS
---------	------------	-------------	-----	---------

12 FOOT	0.2 LAMP U	58 W/FIXT =	0 W	0 WATTS
---------	------------	-------------	-----	---------

14 FOOT	0.2 LAMP U	58 W/FIXT =	0 W	0 WATTS
---------	------------	-------------	-----	---------

### BASELINE ENERGY CONSUMPTION

116,238	KWH/YR
---------	--------

34,015	KWH/YR
--------	--------

30,320	KW
--------	----

### ECO ENERGY CONSUMPTION

74,168	KWH/YR
--------	--------

27,343	KWH/YR
--------	--------

26,391	KW
--------	----

### NET DEMAND SAVINGS

\$1,323	MTR
---------	-----

\$2,045	MTR
---------	-----

\$2,445	MTR
---------	-----

### NET DOLLAR SAVINGS

122,024	MTR
---------	-----

118,411	MTR
---------	-----

118,411	MTR
---------	-----

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

13 AUGUST 1994

### INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7245	OFFICE	ELECTRIC COSTS: ENERGY CHARGE <u>\$0.0211</u> PER KWH DEMAND CHARGE <u>\$11.76</u> PER KW
AREA: AMP USE:	0	
HOURS/DAY	5	
DAYS/WEEK		
PEAK USE	1 (1=YES, 2=NO)	
BUILDING VOLTAGE	120	
EXISTING INCANDESCENTS		FLUORESCENT FIXTURE REPLACEMENT
2 LAMPS @ 750 WATTS = 1500 WATTS		1.2 LAMP @ 58 W/FIXT = 58 WATTS
BASELINE ENERGY CONSUMPTION	3,120 kWh	ECO ENERGY CONSUMPTION
BASELINE DEMAND	11,232 MJ	121 kWh
	1.59 kW	434 MJ
		0.06 kW
NET ENERGY SAVINGS	10,784 MJ/YR	NET DEMAND SAVINGS \$204/YR
NET ENERGY SAVINGS	12.23 MBTU/YR	NET DOLLAR SAVINGS \$267/YR

## FORT CAMPBELL LIGHTING SURVEY

ECO 4: INTERIOR/EXTERIOR LIGHTING  
13 AUGUST 1984

### INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING #: 7245

ELECTRIC COSTS:  
ENERGY CHARGE  $\frac{\$0.0211}{\text{PER KWH}}$   
DEMAND CHARGE  $\frac{\$11.78}{\text{PER KW}}$

INCANDESCENT EXIT SIGNS	FLUORESCENT EXIT SIGNS
EXIT SIGNS	# EXIT SIGNS
WATTAGE	11
WATTAGE	18

BASELINE ENERGY CONSUMPTION	ECO ENERGY CONSUMPTION
5,346 KWH/YR	1,724 KWH/YR
5.346 \$1.77/YR	1.724 \$0.59/YR
6.30 KW	6.30 KW
ECO DEMAND	ECO DEMAND

NET ENERGY SAVINGS	\$223/YR
NET ENERGY SAVINGS	\$254/YR
NET ENERGY SAVINGS	\$254/YR

REPLACEMENT FIXTURE  
# EXIT SIGNS

WATTAGE

PER KWH  
 $\frac{\$0.0211}{\$11.78}$  PER KW

NET DOLLAR SAVINGS

\$223/YR  
\$254/YR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

18 AUGUST 1994

BUILDING #: 7243  
AREA: 14500 SF  
DAYS/USE: 16  
HOURS/DAY: 5  
DAYS/WEEK: 5  
PEAK USE: (1-VES. 2-NO)

BUILDING VOLTAGE: 277

ELECTRIC COSTS.  
ENERGY CHARGE: \$0.0212 PER KWH  
DEMAND CHARGE: \$11.73 PER KW

EXISTING FIXTURES  
INCAN. 60 WATTS: 200 WATTS  
454 WATTS: 0 WATTS  
1075 WATTS: 0 WATTS  
75250 WATTS

BASELINE ENERGY CONSUMPTION

BASELINE DEMAND

REPLACEMENT FIXTURES		ECO ENERGY CONSUMPTION		NET DEMAND SAVINGS	
0 HPS @	0 WATTS	64 WATTS	0 WATTS	\$6,086 /YR	\$6,086 /YR
1 MH @	0 WATTS	300 WATTS	0 WATTS	\$3,392 /YR	\$3,392 /YR
70 MH @	400 WATTS	32200 WATTS	117,200 KWH		
		ECO DEMAND		421,942 MJ	
				32.26 KW	

272,810 KWH  
860,078 MJ  
75.25 KW

117,200 KWH  
421,942 MJ  
32.26 KW

NET DEMAND SAVINGS  
NET DOLLAR SAVINGS

27-Jul-94

## MeansData for Lotus

Page

Estimate: Bldg. 7245 Date: 8 July 1994  
 Description: Hangar  
 Project: Lighting Study Job Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City Index:

Line #	Description	Manhours	Natl	Labor	Equipment	Sub	Total
0207082121	DEMO, 2x4 FLUOR FIXTURES					397.00	
Unit values	0.49	0.00	13.35	0.00	0.00	\$0	13.35
Totals	192.55	\$0	\$9,300	\$0	\$0	\$0	\$5,300
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					13.00	
Unit values	0.26	0.00	7.10	0.00	0.00	\$0	7.10
Totals	3.35	\$0	\$92	\$0	\$0	\$0	\$92
0207082540	DEMO, HIGH BAY FIXTURES					70.00	
Unit values	1.00	0.00	27.50	0.00	0.00	\$0	27.50
Totals	70.00	\$0	\$1,925	\$0	\$0	\$0	\$1,925
U02 SITWORK		266	\$0	\$7,317	\$0	\$0	\$7,317

27-Jul-94

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 32W LAMP R S					92.00	Ea.
Unit values	0.94	26.74	22.52	0.00	0.00	\$0	49.26
Totals	66.57	\$2,460	\$2,171	\$0	\$0	\$0	\$4,631
1661302300	SUR FLUOR STRIP 4' W 2 32W LAMP R S					(qty)	Ea.
Unit values	1.00	22.65	23.82	0.00	0.00	\$0	52.47
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661304291	HIGH BAY. AL REFLECTOR 400W MH					70.00	Ea.
Unit values	3.48	295.00	95.50	0.00	0.00	\$0	390.50
Totals	243.46	\$20,650	\$6,695	\$0	\$0	\$0	\$27,335
1661307777	L.E.D. EXIT SIGN SINGLE FACE					11.00	Ea.
Unit values	1.00	50.00	27.50	0.00	0.00	\$0	77.50
Totals	11.00	\$550	\$303	\$0	\$0	\$0	\$853
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS					(qty)	Ea.
Unit values	1.40	88.00	38.50	0.00	0.00	\$0	126.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS					(qty)	Ea.
Unit values	1.51	84.00	41.50	0.00	0.00	\$0	125.50
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS					(qty)	Ea.
Unit values	1.60	90.00	44.00	0.00	0.00	\$0	134.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS					(qty)	Ea.
Unit values	1.70	94.00	47.00	0.00	0.00	\$0	141.00
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS					165.00	Ea.
Unit values	1.14	73.00	31.50	0.00	0.00	\$0	104.50
Totals	166.14	\$12,045	\$5,198	\$0	\$0	\$0	\$17,243
1661309909	SUR FLUOR 1X1' W 2 32W T6					(qty)	Ea.
Unit values	1.14	96.00	31.50	0.00	0.00	\$0	117.50

PAGE 3-23!

27-Jul-94

## MeansData for Lotus

P

Totals	0.00	\$0	\$0	\$0	\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8				
Unit values	TWO-PIECE REFLECTOR				
	1.14	60.00	31.50	0.00	122.00 EA
Totals	139.08	\$7,320	\$3,943	\$0	0.00 91. \$0 \$11,1
1661309912	SUR FLUOR 2X4' W 3 32W T8				
Unit values					19.00 EA
Totals	1.40	115.00	38.50	0.00	0.00 153. \$0 \$2,9
1661388041	COMP FLUOR LAMP, 18 W TWIN TUBE				
Unit values	GLOBE ASSEMBLY				(qty) EA
	0.13	14.50	3.44	0.00	0.00 17. \$0 \$0
Totals	0.00	\$0	\$0	\$0	

27-Jul-94

MeansData for Lotus

P

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		695	\$45,210	\$18,832		\$0	\$64,042
ESTIMATE TOTAL		661	\$45,210	\$26,149		\$0	\$71,359
SALES TAX	5.00%		\$2,261				
MATL MARKUP	-40.00%		(\$18,064)				
LABOR MARKUP	-13.40%			(63,504)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY		\$29,387	\$22,645			\$0	\$52,032
CONTINGENCY	10.00%						\$5,203
SCND	2.50%						\$1,301
PROFIT	10.00%						\$5,203
JOB TOTAL							\$63,736

27-Jul-94

MeansData for Lotus

Par

5

Estimate: Bldg. 7245 Date: 8 July 1394  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
J02 SITECRK	266	\$0	\$7,317	\$0	\$0	\$7,317
J16 ELECTRICAL	695	\$45,210	\$18,832	\$0	\$0	\$64,042
<b>TOTAL</b>	<b>961</b>	<b>\$45,210</b>	<b>\$26,149</b>	<b>\$0</b>	<b>\$0</b>	<b>\$71,359</b>
SALES TAX	5.00%	\$2,261				
MATL MARKUP	+40.00%	(\$18,084)				
LABOR MARKUP	+13.40%		(\$3,504)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>	<b>\$29,387</b>	<b>\$22,645</b>	<b>\$0</b>	<b>\$0</b>	<b>\$52,032</b>	
CONTINGENCY	10.00%					\$5,20
BOND	2.50%					\$1,30
PROFIT	10.00%					\$5,20
<b>JOB TOTAL</b>						<b>\$63,73</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO #: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

BUILDING #: 7249

ENTIRE BLDG

AREA USE:

HOURS/DAY

DAYSAWFFX

— 5 —

BUILDING VOLTAGE: 277

ELECTRIC COSTS:  
ENERGY CHARGE  
DEMAND CHARGE

\$0.0211 PER KWH  
\$11.76 PER KW

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

### EXISTING FIXTURE DATA

8 FOOT 2 LAMP U 36 WFLXT = 0 WATTS

4 FOOT 2 LAMP U 42 WFLXT = 364 WATTS

— 268 2 LAMP U 64 WFLXT = 2524 WATTS

— 92 3 LAMP U 128 WFLXT = 2364 WATTS

— 4 LAMP U 162 WFLXT = 0 WATTS

4 FOOT 2 LAMP U 160 WFLXT = 0 WATTS

— 92 1 LAMP U 42 WFLXT = 364 WATTS

— 268 2 LAMP U 64 WFLXT = 2524 WATTS

— 92 3 LAMP U 128 WFLXT = 2364 WATTS

— 4 LAMP U 162 WFLXT = 0 WATTS

8 FOOT 2 LAMP U 125 WFLXT = 125 WATTS

— 78.179 KWH/HR ECO ENERGY CONSERVATION

— 36.315 KWH/HR ECO DEMAND

— 30.26 KW ECO DEMAND

NET DEMAND SAVINGS \$1,325 NLR

NET DOLLAR SAVINGS \$2,045 NLR

### REPLACEMENT FIXTURE DATA

2 FOOT 0 2 LAMP U 0 WFLXT = 0 WATTS

4 FOOT 2 LAMP U 29 WFLXT = 29 WATTS

— 58 2 LAMP U 58 WFLXT = 16568 WATTS

— 19 3 LAMP U 87 WFLXT = 1653 WATTS

— 0 4 LAMP U 118 WFLXT = 0 WATTS

4 FOOT 2 LAMP U 29 WFLXT = 29 WATTS

— 58 2 LAMP U 58 WFLXT = 16568 WATTS

— 19 3 LAMP U 87 WFLXT = 1653 WATTS

— 0 4 LAMP U 118 WFLXT = 0 WATTS

8 FOOT 2 LAMP U 125 WFLXT = 125 WATTS

— 78.179 KWH/HR ECO ENERGY CONSERVATION

— 36.315 KWH/HR ECO DEMAND

— 30.26 KW ECO DEMAND

NET DEMAND SAVINGS \$1,325 NLR

NET DOLLAR SAVINGS \$2,045 NLR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: 7249	OFFICE	ELECTRIC COSTS:	PER KWH
LAMP USE:	8	ENERGY CHARGE \$0.0211	PER KWH
HOURS/DAY	5	DEMAND CHARG \$1178	PER KW
DAYSWEEK			
PEAK USE	1 (1-YES, 2-NO)		
EXISTING VOLTAG	120		
EXISTING INCANDESCENTS		FLUORESCENT FIXTURE REPLACEMENT	
2 LAMPS @ 150 WATTS = 300 WATTS	12 LAMP @ 58 WATTS = 696 WATTS	56 WATTS	
BASELINE ENERGY CONSUMPTION	3,120 KWH	ECO ENERGY CONSUMPTION	137 KWH
	11,232 MJ		434 MJ
BASELINE DEMAND	1.59 KW	ECO DEMAND	0.06 KW
NET ENERGY SAVINGS	10,718 MJ/MR	NET DEMAND SAVINGS	\$204/MR
NET ENERGY SAVINGS	10.23 MBTU/MR	NET DOLLAR SAVINGS	\$267/MR

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR/EXTERIOR LIGHTING

19 AUGUST 1994

INTERIOR LIGHTING: EXIT SIGN REPLACEMENT

BUILDING #:	7249	ELECTRIC COSTS: ENERGY CHARGE DEMAND CHARGE	\$0.0211 PER KWH \$1.178 PER KW
INCANDESCENT EXIT SIGNS # EXIT SIGNS	FLUORESCENT EXIT SIGNS # EXIT SIGNS	REPLACEMENT FIXTURE # EXIT SIGNS	11
WATTAGE	WATTAGE	WATTAGE	3
BASELINE ENERGY CONSUMPTION	1,724 KWH/MONTH	ECO ENERGY CONSUMPTION	263 KWH/MONTH
BASELINE DEMAND	6.26 KW	ECO DEMAND	1.06 KW
NET ENERGY SAVINGS	5,203 KWH/YR	NET DEMAND SAVINGS	\$23 YR
NET ENERGY SAVINGS	4.93 KBTU/YR	NET DOLLAR SAVINGS	\$54 YR

## FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

BUILDING #: 7249	HANGAR BAY
AREA:	
AREA USE:	14
OURSDAY	5
DAYSTEEK	1 (1-YES, 2-NO)
PEAK USE	
BUILDING - OUTAGE:	277

ELECTRIC COSTS	\$0.0711 PER KWH
ENERGY CHARGE	\$11.76 PER KW
DEMAND CHARGE	

EXISTING FIXTURES	REPLACEMENT FIXTURES
INCANDE @ 200 WATTS = 0 WATTS	0 WATTS @ 0 WATTS
LLOW @ 454 WATTS = 0 WATTS	0 WATTS @ 0 WATTS
75 BW @ 1075 WATTS = 75250 WATTS	75 MH @ 400 WATTS = 3200 WATTS
BASELINE ENERGY CONSUMPTION	
222,918 KWH	
905,076 MJ	
15.25 KW	
BASED LINE DEMAND	
ECO DEMAND	
117,218 KWH	
421,349 MJ	
32.20 KW	

NET ENERGY SAVINGS	36,696 KWH
NET ENERGY SAVINGS	534,677 MJ
NET DOLLAR SAVINGS	\$9,392 KWH

27-Jul-94

MeansData for Lotus

Pag.

Estimate: Bldg. 7249 Date: 6 July 1994  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City Index:

Line #	Description	Manhours	Natl	Labor	Equipment	Sub	Total
3207082121	DEMO, 2x4 FLUOR FIXTURES					397.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.35	
Totals	192.55	\$0	\$5,300	\$0	\$0	\$5,300	
3207082123	DEMO, INCAND FIXTURES / EXIT SIGNS					13.00	
Unit values	0.26	0.00	7.10	0.00	0.00	7.10	
Totals	3.35	\$0	\$92	\$0	\$0	\$92	
3207082540	DEMO, HIGH BAY FIXTURES					70.00	
Unit values	1.00	0.00	27.50	0.00	0.00	27.50	
Totals	70.00	\$0	\$1,925	\$0	\$0	\$1,925	
U02 SIDEWORK		265	\$0	\$7,317	\$0	\$0	\$7,317

27-Jul-94

## MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 32W LAMP R S					92.00	
Unit values	0.94	26.74	22.52	0.00	0.00	0.00	49.26
Totals	65.57	\$2,460	\$2,071	\$0	SC	\$4,531	
1661302300	SUR FLUOR STRIP 4' W 2 32W LAMP R S				(qty)	Ea.	
Unit values	1.00	28.65	23.82	0.00	0.00	0.00	52.67
Totals	0.00	SC	\$0	\$0	SC	\$0	
1661304291	HIGH BAY, AL REFLECTOR 400W MH				70.00	EA	
Unit values	3.48	295.00	95.50	0.00	0.00	0.00	390.50
Totals	243.46	\$20,650	\$6,685	\$0	SC	\$27,335	
1661307777	L.E.D. EXIT SIGN SINGLE FACE				11.00	EA	
Unit values	1.00	50.00	27.50	0.00	0.00	0.00	77.50
Totals	11.00	\$550	\$303	\$0	SC	\$0	\$853
1661309801	REC FLUOR TROFFER 3X2' W 2 31W T8-U ACRYLIC LENS				(qty)	EA	
Unit values	1.40	88.00	38.50	0.00	0.00	0.00	126.50
Totals	0.00	SC	\$0	\$0	SC	\$0	
1661309802	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS				(qty)	EA	
Unit values	1.51	84.00	41.50	0.00	0.00	0.00	125.50
Totals	0.00	SC	\$0	\$0	SC	\$0	
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS				(qty)	EA	
Unit values	1.60	90.00	44.00	0.00	0.00	0.00	134.00
Totals	0.00	SC	\$0	\$0	SC	\$0	
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS				(qty)	EA	
Unit values	1.70	94.00	47.00	0.00	0.00	0.00	141.00
Totals	0.00	SC	\$0	\$0	SC	\$0	
1661309807	REC FLUOR TROFFER 1X4' W 2 32W T8 ACRYLIC LENS				169.00	EA	
Unit values	1.14	73.00	31.50	0.00	0.00	0.00	104.50
Totals	188.10	\$12,045	\$3,198	\$0	SC	\$17,243	
1661309909	SUR FLUOR 1X4' W 2 32W T8				(qty)	EA	
Unit values	1.14	86.00	31.50	0.00	0.00	0.00	117.50

PAGE 3-24

27-Jul-94

## MeansData for Lotus

Page

		\$0	\$0	\$0	\$0	\$0
Totals	0.00	\$0	\$0	\$0	\$0	\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8 TWO-PIECE REFLECTOR					
Unit values	1.14	60.00	31.50	0.00	6.00	91.50
Totals	139.08	\$7,320	\$3,543	\$0	\$0	\$11,163
1661309912	SUR FLUOR 2X4' W 3 32W 8					
Unit values	1.40	115.00	38.50	0.00	6.00	153.50
Totals	26.40	\$2,185	\$792	\$0	\$0	\$2,977
1661366041	COMP FLUOR LAMP, 18 W TWIN TUBE GLOBE ASSEMBLY					
Unit values	0.13	14.50	3.44	0.00	6.00	17.94
Totals	0.00	\$0	\$0	\$0	\$0	\$0

27-JUL-94

MeansData for Lotus

Page 4

Line #	Description					
	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	596	\$45,210	\$18,832		SC	\$0 \$64,042
ESTIMATE TOTAL	961	\$45,210	\$26,149		SC	\$0 \$71,359
SALES TAX	5.00%	\$2,261				
MATL MARKUP	-40.00%	(\$18,064)				
LABOR MARKUP	-13.40%		(\$3,504)			
EQUIPT MARKUP	0.00%			SC		\$0
SUB MARKUP	0.00%				SC	\$0
TOTAL BEFORE CONTINGENCY	\$29,357	\$22,665			SC	\$0 \$52,032
CONTINGENCY	10.00%					\$5,203
BCND	2.50%					\$1,301
PRCFIT	10.00%					\$5,203
JOB TOTAL						\$63,739

27-Jul-94

MeansData for Lotus

Page

Estimatee: Bldg. 7249 Date: 8 July 1994  
 Description: Hangar  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City Index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITWORK	266	\$0	\$7,317	\$0	\$0	\$7,317
U16 ELECTRICAL	695	\$45,210	\$18,837	\$0	\$0	\$64,042
<b>TOTAL</b>	<b>961</b>	<b>\$45,210</b>	<b>\$26,149</b>	<b>\$0</b>	<b>\$0</b>	<b>\$71,359</b>
SALES TAX	5.00%	\$2,261				
MATL MARKUP	-40.00%	(\$18,084)				
LABOR MARKUP	-13.40%		(\$3,504)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY	\$29,387	\$22,645		\$0	\$0	\$52,032
CONTINGENCY	10.00%					\$5,203
BOND	2.50%					\$1,301
PROFIT	10.00%					\$5,203
<b>JOB TOTAL</b>						<b>\$63,739</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1984

## INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 7281  
BUILDING AREA: 10,000 SQ FT  
DAYS USE: 10 HOURS/DAY  
WEEKS PER WEEK: 5  
HOLDING VOLTAGE: 120

TESTING FIXTURE DATA

2 FOOT	4 FOOT	6 FOOT	8 FOOT
2 LAMP @ 95 WATT = 0 WATTS	0 LAMP @ 0 WATT = 0 WATTS	0 LAMP @ 0 WATT = 0 WATTS	0 LAMP @ 0 WATT = 0 WATTS
1 LAMP @ 45 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS
2 LAMP @ 90 WATT = 0 WATTS	0.2 LAMP @ 58 WATT = 0 WATTS	0.2 LAMP @ 58 WATT = 0 WATTS	0.2 LAMP @ 58 WATT = 0 WATTS
3 LAMP @ 144 WATT = 0 WATTS	0.3 LAMP @ 87 WATT = 0 WATTS	0.3 LAMP @ 87 WATT = 0 WATTS	0.3 LAMP @ 87 WATT = 0 WATTS
4 LAMP @ 180 WATT = 0 WATTS	0.4 LAMP @ 116 WATT = 0 WATTS	0.4 LAMP @ 116 WATT = 0 WATTS	0.4 LAMP @ 116 WATT = 0 WATTS

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.76 PER KW

## REPLACEMENT FIXTURE DATA

2 FOOT	4 FOOT	6 FOOT	8 FOOT
0.2 LAMP @ 95 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS
WIRELESS TOR 0.1 LAMP @ 29 WATT = 0 WATTS	WIRELESS TOR 0.1 LAMP @ 29 WATT = 0 WATTS	WIRELESS TOR 0.1 LAMP @ 29 WATT = 0 WATTS	WIRELESS TOR 0.1 LAMP @ 29 WATT = 0 WATTS
0.3 LAMP @ 87 WATT = 0 WATTS	0.2 LAMP @ 58 WATT = 0 WATTS	0.2 LAMP @ 58 WATT = 0 WATTS	0.2 LAMP @ 58 WATT = 0 WATTS
1.2 LAMP @ 116 WATT = 0 WATTS	0.4 LAMP @ 116 WATT = 0 WATTS	0.4 LAMP @ 116 WATT = 0 WATTS	0.4 LAMP @ 116 WATT = 0 WATTS

2 FOOT	4 FOOT	6 FOOT	8 FOOT
0.2 LAMP @ 95 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS	0.1 LAMP @ 29 WATT = 0 WATTS
ECO ENERGY CONSUMPTION 17,101 KWH/YR	ECO ENERGY CONSUMPTION 6,363 KWH/YR	ECO ENERGY CONSUMPTION 6,363 KWH/YR	ECO ENERGY CONSUMPTION 6,363 KWH/YR
DISCHARGE IN MARS 123.38 MARS/YR	DISCHARGE IN MARS 123.38 MARS/YR	DISCHARGE IN MARS 123.38 MARS/YR	DISCHARGE IN MARS 123.38 MARS/YR

NET ENERGY SAVINGS	NET ENERGY SAVINGS	NET ENERGY SAVINGS	NET ENERGY SAVINGS
199,173 MARS/YR	123.38 MARS/YR	123.38 MARS/YR	123.38 MARS/YR
NET DOLLAR SAVINGS \$1,305.5/YR	NET DOLLAR SAVINGS \$2,713.0/YR	NET DOLLAR SAVINGS \$2,713.0/YR	NET DOLLAR SAVINGS \$2,713.0/YR

## FORT CAMPBELL LIGHTING SURVEY

T-30 : ANNUAL REPORT OF THE LEHIGH VALLEY

19 AUGUST 1996

FORT CAMPBELL LIGHTING SURVEY	
REO 1: INTERIOR/EXTERIOR LIGHTING	
12 AUGUST 1994	
<b>INTERIOR LIGHTING: EXIT SIGN REPLACEMENT</b>	
BUILDING #: 7281	ELECTRIC COSTS: ENERGY CHARGE: \$0.0211 PER KW DEMAND CHARGE: \$1178 PER KW
INCANDESCENT EXIT SIGNS	FLUORESCENT EXIT SIGNS
WATTAGE	WATTAGE
REPLACEABLE ENERGY CONSUMPTION	ECO ENERGY CONSUMPTION
WATTS/HOUR	KWH/HR
KW/HOUR	KW/HOUR
PER HOUR DEMAND	PER HOUR DEMAND
NET ENERGY SAVINGS	NET DEMAND SAVINGS
NET ENERGY SAVINGS	NET DOLLAR SAVINGS

27-Jul-94

MeansData for Lotus

P8

Estimate: Bldg. 7281 Date: 8 July 1994  
 Description: Storage / Admin  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total				
		Manhours	Matl	Labor	Equipment	Sub
0207082121	DEMO, 2x4 FLOOR FIXTURES				116.00	
Unit values	0.49	0.00	13.35	0.00	0.00	13.35
Totals	.56.25	\$0	\$1,549	\$0	\$0	\$1,549
0207082123	DEMO, INCAND FIXTURES / EXIT SIGNS				5.00	
Unit values	0.26	0.00	7.10	0.00	0.00	7.10
Totals	1.29	\$0	\$36	\$0	\$0	\$36
J02 SITEWORK		58	\$0	\$1,585	\$0	\$1,585

Line #	Description	Manufc	Matl	Labor	Equipment	Sub	Total
1661302200	SUR FLUOR STRIP 4' W 1 40W LAMP R S						
Unit values	3.94	26.74	22.52	0.00		(qty) EA.	
Totals	0.00	\$0	\$0	\$0		0.00 \$0	49.
1661302300	SUR FLUOR STRIP 4' W 2 40W LAMP R S						
Unit values	3.00	26.65	23.62	0.00		(qty) EA.	
Totals	0.00	\$0	\$0	\$0		0.00 \$0	52.
1661307777	L.E.D. EXIT SIGN RETROFIT KIT SINGLE FACE						
Unit values	1.00	50.00	21.50	0.00		5.00 EA	
Totals	5.00	\$250	\$138	\$0		5.00 \$0	77.
1661309801	REC FLUOR TROFFER 2X2' W 2 31W T8-U ACRYLIC LENS						
Unit values	1.40	88.00	35.50	0.00		(qty) EA	
Totals	6.00	\$0	\$0	\$0		0.00 \$0	126.
1661309802	REC FLUOR TROFFER 2X4' W 1 32W T8 ACRYLIC LENS W REFLECTOR						
Unit values	1.51	84.00	41.50	0.00		4.00 EA	
Totals	6.04	\$336	\$166	\$0		6.00 \$0	125.
1661309803	REC FLUOR TROFFER 2X4' W 3 32W T8 ACRYLIC LENS						
Unit values	1.60	90.00	44.00	0.00		(qty) EA	
Totals	0.00	\$0	\$0	\$0		0.00 \$0	134.
1661309804	REC FLUOR TROFFER 2X4' W 4 32W T8 ACRYLIC LENS						
Unit values	1.70	94.00	47.00	0.00		2.00 EA	
Totals	0.00	\$0	\$0	\$0		2.00 \$0	141.
1661309805	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS W/ REFLECTOR						
Unit values	1.51	106.50	41.50	0.00		112.00 EA	
Totals	169.12	\$1,928	\$4,648	\$0		0.00 \$0	141.
1661309807	REC FLUOR TROFFER 2X4' W 2 32W T8 ACRYLIC LENS						
Unit values	1.14	70.00	31.50	0.00		(qty) EA	
Totals	0.00	\$0	\$0	\$0		0.00 \$0	124.
1661309909	SUR FLUOR 1X4' W 2 32W T8						
Unit values	1.14	86.00	32.50	0.00		(qty) EA	

27-Jul-94

## MeansData for Lotus

Page 3

	0.00	\$0	\$0	\$0	\$0	\$0	\$0
Totals	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8						
Unit values	TWO-PIECE REFLECTOR						
Totals	1.14	90.00	31.50	0.00	(qty)	EA	121.50
	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661388042	COMP FLUOR FIX, 2 13 W PL						
Unit values	WALL / CEILING MOUNT						
Totals	1.00	25.50	27.50	0.00	(qty)	EA	53.00
	0.00	\$0	\$0	\$0	\$0	\$0	\$0

27-Jul-94

MeansData for Lotus

Page

Line #	Description							
		Manhours	Matl	Labor	Equipment	Sub	Total	
U16 ELECTRICAL	161	\$12,514	\$4,952			\$0	\$0	\$17,466
ESTIMATE TOTAL	239	\$12,514	\$6,537			\$0	\$0	\$19,051
SALES TAX	5.00%	\$626						
MATL MARKUP	-40.00%	\$5,006						
LABOR MARKUP	-12.40%			(\$875)				
EQUIPT MARKUP	0.00%					\$0		
SC MARKUP	0.00%					\$0		
TOTAL BEFORE CONTINGENCY		\$8,134	\$5,661			\$0	\$0	\$13,795
CONTINGENCY	10.00%							\$1,360
BOND	2.50%							\$345
PROFIT	10.00%							\$1,380
JOB TOTAL								\$16,895

27-Jul-94

MeansData for Lotus

Page


Estimate: Bldg. 7281 Date: 8 July 1994  
 Description: Storage / Admin.  
 Project: Lighting Study Bld Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
CC2 SITWORK	58	\$0	\$1,585	\$0	\$0	\$1,585
ULF ELECTRICAL	181	\$12,514	\$4,952	\$0	\$0	\$17,466
<b>TOTAL</b>	<b>239</b>	<b>\$12,514</b>	<b>\$6,537</b>	<b>\$0</b>	<b>\$0</b>	<b>\$19,051</b>
SALES TAX	5.00%	\$626				
MATL MARKUP	-40.00%	(\$5,006)				
LABOR MARKUP	-13.40%		(\$876)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	0.00%					
TOTAL BEFORE CONTINGENC		\$8,134	\$5,661	\$0	\$0	\$13,795
CONTINGENCY	10.00%					\$1,380
BCND	2.50%					\$345
PRFIT	10.00%					\$1,380
<b>JOB TOTAL</b>						<b>\$16,899</b>

**MOTOROLA**

Des Plaines, Ill.



## HIGH PERFORMANCE ELECTRONIC BALLAST

FLUORESCENT 1, 2, 3 and 4 LAMP  
RAPID START

PAGE 3-25

Total Customer Satisfaction



**MOTOROLA**

Lighting Inc.

Total Customer Satisfaction

## CUSTOMER SUPPORT 1-800-MLI-0089

### HIGH PERFORMANCE FEATURES


Power Factor:	Greater than .95
Total Harmonic Distortion:	Less than 3%
THD Harmonic Distortion:	Less than 6%
Lamp Current Crest Factor:	Less than 1.5
Lamp Current Frequency:	Greater than 25 KHz
Lamp Configuration:	Series
Lamp Flicker:	Less than 2%, No VISIBLE
Sound Rating:	Class A
Projected Life:	20 years plus
Connector:	Poke-in wire tract for 18 gauge (solid wire)
Weight:	1.2 lbs
EMI:	Meets FCC Part 15, Subpart C

### CODES

UL Listed:	Class P
Transient Protection:	Meets ANSI C42.41 Cat. A (Formerly IEEE 507)

### WIRETRAC CONNECTOR

Our Unique Push-In  
CONNECTORS SIMPLIFY INSTALLATION  
AND SAVE TIME



### PART NUMBER DESCRIPTION

Part Number Explanation						
M	3	-	N	-	11	-
1	2	3	4	5	6	7
8	9	0	1	2	3	4
5	6	7	8	9	0	1

### QUALITY

Motorola's goal of acceptable quality is at Six Sigma or no more than 3.4 defects per million opportunities. Motorola Lighting Inc. designed its electronic ballast to meet the most rigorous performance standards at world class levels. This translates into a highly robust product that goes through extensive environmental stress testing to assure our customers of very low initial defect levels (less than 0.1%) and high reliability (greater than 300,000 hours Mean Time to Failure--MTTF).

The economic ballast life is 20 years when operated at 45°C ambient temperature. Operation at MLI's ballast at 50°C may decrease life expectancy by 25%.

Six Sigma Quality means "world class" in all that we do at Motorola Lighting Inc., which is part of our commitment to TOTAL CUSTOMER SATISFACTION.




# RAPID START BALLASTS

Lamp Type	Rated Lamp Watts	Lamp Length	Model No.	Line Voltage	Max Line Current	Typical Line Current	Type of Input Power (W.)	Min. Enclosed	Starting Temp. (F.)
<b>1 LAMP T8</b>									
F22T8	32	4	M1.RN.T8-LL-120	120	.31	.24	26	26	50°
F22T8	32	4	M1.RN.T8-LL-277	277	.13	.11	29	26	50°
F25T8	25	3	M1.RN.T8-LL-120	120	.24	.19	23	22	50°
F25T8	25	3	M1.RN.T8-LL-277	277	.10	.08	23	22	50°
F17T8	17	2	M2.RN.T8-LL-120	120	.17	.13	15	15	50°
F17T8	17	2	M2.RN.T8-LL-277	277	.07	.06	16	15	50°
<b>2 LAMP T8</b>									
F32T8	32	4	M2.RN.T8-LL-120	120	.63	.51	61	57	50°
F32T8	32	4	M2.RN.T8-LL-277	277	.24	.21	31	36	50°
F25T8	25	3	M2.RN.T8-LL-120	120	.42	.38	48	45	50°
F25T8	25	3	M2.RN.T8-LL-277	277	.18	.17	48	44	50°
F17T8	17	2	M2.RN.T8-LL-120	120	.27	.24	32	30	50°
F17T8	17	2	M2.RN.T8-LL-277	277	.12	.10	36	31	50°
<b>2 LAMP T12</b>									
F40T12	40	4	M2.RN.T12-LL-120	120	.84	.69	71	69	50°
F40T12	40	4	M2.RN.T12-LL-277	277	.37	.28	68	67	50°
F40T12	40	4	M2.RN.T12-LL-120	120	.34	.30	66	67	50°
F40T12	40	4	M2.RN.T12-LL-277	277	.13	.11	64	67	50°
F40T12	40	4	M2.RN.T12-LL-120	120	.34	.30	72	71	50°
F40T12	40	4	M2.RN.T12-LL-277	277	.17	.15	70	68	50°
F30T12	30	3	M2.RN.T12-LL-120	120	.48	.44	63	62	50°
F30T12	30	3	M2.RN.T12-LL-277	277	.21	.19	62	59	50°
F25T12	25	3	M2.RN.T12-LL-120	120	.46	.37	64	62	50°
F25T12	25	3	M2.RN.T12-LL-277	277	.19	.17	63	62	50°
<b>3 LAMP T8</b>									
F32T8	32	4	M3.RN.T8-LL-120	120	.78	.70	90	87	50°
F32T8	32	4	M3.RN.T8-LL-277	277	.33	.22	90	86	50°
F25T8	25	3	M3.RN.T8-LL-120	120	.61	.50	76	67	50°
F25T8	25	3	M3.RN.T8-LL-277	277	.26	.21	66	66	50°
F17T8	17	2	M3.RN.T8-LL-120	120	.31	.26	57	60	50°
F17T8	17	2	M3.RN.T8-LL-277	277	.16	.14	64	61	50°
<b>3 LAMP T12</b>									
F40T12	40	4	M3.RN.T12-LL-120	120	.87	.70	107	106	50°
F40T12	40	4	M3.RN.T12-LL-277	277	.43	.36	105	103	50°
F40T12	40	4	M3.RN.T12-LL-120	120	.83	.77	91	89	50°
F40T12	40	4	M3.RN.T12-LL-277	277	.41	.33	90	88	50°
F40T12	40	4	M3.RN.T12-LL-120	120	.99	.82	103	107	50°
F40T12	40	4	M3.RN.T12-LL-277	277	.43	.37	107	105	50°
F30T12	30	3	M3.RN.T12-LL-120	120	.76	.66	76	76	50°
F30T12	30	3	M3.RN.T12-LL-277	277	.37	.30	76	76	50°
F25T12	25	3	M3.RN.T12-LL-120	120	.71	.67	67	66	50°
F25T12	25	3	M3.RN.T12-LL-277	277	.33	.24	66	66	50°
<b>4 LAMP T8</b>									
F22T8	32	4	M4.RN.T8-LL-120	120	.98	.82	121	110	50°
F22T8	32	4	M4.RN.T8-LL-277	277	.44	.43	118	115	50°
F25T8	25	3	M4.RN.T8-LL-120	120	.87	.70	95	91	50°
F25T8	25	3	M4.RN.T8-LL-277	277	.43	.34	83	80	50°
F17T8	17	2	M4.RN.T8-LL-120	120	.93	.69	97	64	50°
F17T8	17	2	M4.RN.T8-LL-277	277	.42	.16	61	60	50°


DO NOT Operate the U Shaded Equivalent of the above lamps. Test Data from independent test lab available on request from factory.

# WIRING DIAGRAMS AND BALLAST DIMENSIONS


## WIRING DIAGRAMS




1 LAMP



3 LAMP






2 LAMP



4 LAMP

## BALLAST DIMENSIONS\*




One of the many products manufactured by Motorola Lighting Division for U.S.A.

 **MOTOROLA**  
Lighting Inc.


500 Sherman Parkway  
Burbank, California 91506  
Telephone 800-555-1234  
P.O. Box 10000, Burbank, California 91506  
Telephone 800-555-1234  
1000 Motor City Drive  
Detroit, Michigan 48226  
Telephone 800-555-1234  
Corporate Headquarters  
Corporate Telephone 312-592-3232

APRIL 1974



**SILVERLUX<sup>TM</sup>**  
**REFLECTORS**  
**CUT YOUR**  
**LIGHTING ENERGY**  
**COSTS IN HALF.**





Job 64  
spectra

Main T  
Break  
Ramp

# SILVERLUX FLUORESCENT REFLECTORS



- Cut energy costs in half or enhance light levels
- Pay for themselves in two years or less
- Install and maintain easily
- Warrantied for 5 years
- Available low-rate financing available
- Available from nationwide dealer network

For more information just call.


3M is a part of the Green Lights Program - a voluntary non-regulatory program organized by the Environmental Protection Agency (EPA). This program encourages companies to take advantage of new lighting technologies and technologies that benefit the environment. 3M is a proud member of the program because it participates as both a consumer of electrical lighting energy and as a developer of efficient lighting products. Silverlux reflectors demonstrate 3M's commitment to energy-efficient lighting technologies that reduce energy consumption and pollution while delivering the same or better lighting.



Cut costs. Not lighting.

Innovation working for you

3M Construction Markets  
3M Center Bldg. 229-45-09  
St. Paul, MN 55144-1000  
612-736-2388



Job 6429      Fiche 3      02/04/99      06:55AM  
operator: jn      machine: i-1000      100%      100%

Main Table DTICNEW MPT  
Break Table  
Ref. 1 F. 10 A Block 3717 Offset 61819

# EVENLITE LED EXIT Lights

EV SERIES

*The LED of the 21st Century*



*No Ifs, Ands or Buts.*

This is exactly how the EVENLITE 2000 appears! Perfectly even illumination is produced by indirect lighting, so that the LED's are invisible, with no hot spots. All this is provided in the slimmest sign on the market with integral charger and battery.

No competitor comes close to these combined specifications:

- Less than 3 watts total power per face
- Perfect light distribution across face
- Single face only 1 1/8" thick
- Double face only 2 1/4" thick
- Remote unit only 1/2" thick
- Multiple LED lamps with 20 year unconditional guarantee
- NICAD batteries with 5 year guaranteed
- Aluminum housing for light weight and strength
- Universal mount
- Baked enamel, vinyl clad or satin anodized finishes
- Polycarbonate faceplate

Patent Pending



SHELL SOURCE INCORPORATED  
420 37th Avenue, Gaithersburg, Maryland 20878  
Tel: 1410/827-8672 Fax: 1410/827-9637

PAGE 3-26.

## PIONEER

1011 Series

*Economy!*


### STANDARD FEATURES

- White translucent acrylic lens
- White enamel finished steel pan
- 120 volt class "P" ballast
- Lamp(s) included

### OPTIONS

- High power factor ballast.
- 277 volt ballast
- Theft proof screws

MODEL #	WATTAGE	L	D
PI-1011	100W, 250W	17"	8"
PI-1014	100W, 250W	18"	8"



## EXPLORER

1010 Series

*Low Profile!*


### STANDARD FEATURES

- White vandal resistant lexan lens
- Black lexan housing.
- 120 volt class "P" ballast
- White powder coated reflector.
- Lamp(s) included

### OPTIONS

- High power factor ballast.
- 277 volt ballast
- White lexan housing

MODEL #	WATTAGE	L	D
EP-1010	100W, 250W	11"	36"




UL List

## ECLIPSE

3012 Series

*Now!*



UL Listed

### STANDARD FEATURES

- White translucent acrylic lens
- White enamel finished steel pan
- 120 volt class "P" ballast.
- Lamp(s) included

### OPTIONS


- High power factor ballast.
- 277 volt ballast.
- Theft proof screws.

MODEL #	WATTAGE	L	D
EC-3012	100W, 250W	13"	14.25"
EC-3016	100W, 250W	15"	14.25"

## DISCOVERY

3011 Series

*Traditional Square!*



UL Listed

### STANDARD FEATURES

- White translucent acrylic lens
- White enamel finished steel pan.
- 120 volt class "P" ballast
- Lamp(s) included.

### OPTIONS


- High power factor ballast
- 277 volt ballast
- Theft proof screws

MODEL #	WATTAGE	L	D
DS-3011	100W, 250W	11"	11.5"
DS-3015	100W, 250W	13"	13.5"

## COSMO

1400 Series

*Low Profile!*



UL List


### STANDARD FEATURES

- White lexan lens.
- White sandal-proof lexan lens
- 120 volt class "P" ballast
- Lamp(s) included

### OPTIONS

- High power factor ballast
- 277 volt ballast

MODEL #	WATTAGE	L	D
CS-1400	100W, 250W	11"	11.5"



UL List

INCON INDUSTRIES



UL Listed

**ARMSTRONG**  
1802 Series  
*Vandal-Lite!*

## STANDARD FEATURES

- White heavy gauged lexan lens.
- Corrosion-proof lexan base.
- 120 volt class "P" ballast.
- Lamp(s) included.

## OPTIONS

- High power factor ballast.
- 277 volt ballast.

MODEL	WATTAGE	L	D
AR 1802	10W 22W 35W	10"	4.5"



UL Listed

**STRATUS**  
2011 Series  
*Low Profile Square!*

## STANDARD FEATURES

- White translucent acrylic lens.
- White enamel finished steel pan.
- 120 volt class "P" ballast.
- Lamp(s) included.

## OPTIONS

- High power factor ballast.
- 277 volt ballast.
- Theft proof screws.

MODEL	WATTAGE	L	D
ST 2011	10.32W 12.23W	11"	12.75"
ST 2014	23.23W 30.33W	14"	12.75"



UL Listed

**CENTURY**  
1010 Series  
*Vandal-Lite!*


## STANDARD FEATURES

- White extra strong lexan lens.
- White enamel finished steel pan.
- 120 volt class "P" ballast.
- Lamp(s) included.

## OPTIONS

- High power factor ballast.
- 277 volt ballast.
- Theft proof screws.

MODEL	WATTAGE	L	D
CE 1010	11.32W 13W	16.13"	4"



UL Listed

**NOVA**  
200 Series  
*Euro-Lite!*

## STANDARD FEATURES

- Opal polycarbonate diffuser.
- White corrosion-proof lexan base.
- White powder coated reflector.
- 120 volt class "P" ballast.
- Lamp(s) included.

## OPTIONS

- Black or white cage.
- Black lexan housing.
- Theft proof screws.

MODEL	WATTAGE	L	D
NY 200	10.13.23W	18"	5"



UL Listed

**HALO**  
333 Series  
*Economy!*

## STANDARD FEATURES

- Durable polycarbonate base.
- Available in white or black.
- 11.5" white G" acrylic globe.
- 120 volt class "P" ballast.
- Lamp included.

## OPTIONS

- Clear prismatic jar.
- White acrylic jar.
- HPF module.

MODEL	WATTAGE	L	D
HL 333	5.7 10.1.4	6.11"	6"
HL 333 Jar	5.7 "	7.75"	4"



UL Listed

**KENNEDY**  
0.30 Series  
*Vandal-Lite!*

## STANDARD FEATURES

- Brushed satin cast aluminum housing.
- Durable white lexan jar.
- 120 volt class "P" ballast.
- Lamp included.

## OPTIONS



- Clear prismatic jar
- G" round globe.
- High power factor ballast.
- Pull chain.

MODEL	WATTAGE	L	D
KD 0.30	5.7.9.11	11.5"	4"
KD 0.30	7.10.12.14.16.18.20.22.24.26.28.30.32.34.36.38.40.42.44.46.48.50.52.54.56.58.60.62.64.66.68.70.72.74.76.78.80.82.84.86.88.90.92.94.96.98.100.102.104.106.108.110.112.114.116.118.120.122.124.126.128.130.132.134.136.138.140.142.144.146.148.150.152.154.156.158.160.162.164.166.168.170.172.174.176.178.180.182.184.186.188.190.192.194.196.198.200.202.204.206.208.210.212.214.216.218.220.222.224.226.228.230.232.234.236.238.240.242.244.246.248.250.252.254.256.258.260.262.264.266.268.270.272.274.276.278.280.282.284.286.288.290.292.294.296.298.300.302.304.306.308.30.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140.152.154.156.150.162.164.166.160.172.174.176.170.182.184.186.180.192.194.196.190.202.204.206.200.212.214.216.210.222.224.226.220.232.234.236.230.242.244.246.240.252.254.256.250.262.264.266.260.272.274.276.270.282.284.286.280.292.294.296.290.20.22.24.26.28.20.32.34.36.38.30.42.44.46.48.40.52.54.56.58.50.62.64.66.68.60.72.74.76.78.70.82.84.86.80.92.94.96.90.102.104.106.108.100.112.114.116.118.110.122.124.126.128.120.132.134.136.130.142.144.146.140		

## LOWBAY

Low to medium wattage industrial luminaire.

Ideal for areas having restricted ceiling heights and wet locations.



# LOWBAY

Provides optimum efficiency at low mounting heights.

Lowbay offers energy-efficient solutions to a wide range of industrial and warehousing installation requirements. This industrial-grade HID luminaire provides both efficient distribution and exceptional brightness control for task lighting or in areas where low headroom is a problem. A choice of optical equipment allows Lowbay to meet a variety of spacing and performance requirements to satisfy even the toughest specification.

#### Features:

**Mounting** — Choice of a 1/2" NPT threaded pendant, balanced pendant or ceiling mounting. All mounting adapters have two hinges and four closure screws, thereby providing four-point compression on the gasket for a positive seal. In addition, the offset pendant hub ensures plumb mounting.

**Ballast housing** — Die cast copper-free aluminum low profile housing with an efficient heat sink design for cool operation and long ballast life. Hubbell's Lowbay is hinged for quick installation to mounting adapters allowing easy access to large splice compartment. Finished in durable grey Leetrocote™.

Low profile diecast copper-free aluminum housing.

Spring latches assure tight seal.

Acrylic or polycarbonate reflectors available.

**Optical Equipment** — Lowbay offers a choice of open or enclosed reflectors, acrylic or polycarbonate reflectors and reflector/refractor combinations.

1. Open Enclosed Reflector — High purity spun aluminum finished in Anodite®. Lens on the enclosed reflector is thermal shock and impact resistant for added protection.

2. Reflector/Refractor Combination — Reflector portion is high purity spun aluminum finished in white Leetrocote for low brightness and high reflectivity. Its refractor gives symmetrical (Type S) distribution and is available in either acrylic or polycarbonate.

3. Refractors — UV stabilized acrylic refractors are available for symmetrical (Type S) or asymmetrical (Type D) distribution. Also available in polycarbonate for vandal resistance.

Ceiling or pendant mounting provides four point positive seal.

Choice of optical assemblies.

4. Large Reflector/Refraction — Spun aluminum reflector has Anodite finish and polycarbonate refractor. Available in Type II or Type D distribution.

All optical assemblies except large reflector/refractor attach to the ballast housing by two positive spring latches. Large assembly has a fully threaded neck.

**Reliable, Long Life Ballast** — Class "H" insulated, -20°F starting (-40°F HPS) 60 Hz. high power factor ballast isolated from the optical chamber for optimum performance and long life. 50 Hz ballasts available, consult factory.

**Additional Features** — U.L. listed for wet locations and 40°C ambient operation.

## **SPECIFYING INFORMATION**

MOLISTRA (PGV) 1

Category Register									
Long Name Category	Class	Weight Grs./Lbs.	Volume Cubic In.	Weight Grs./Lbs.	Long Name Category	Receptacle Name Number	Capacity Grs./Lbs.	Capacity Receptacle Number	Weight Grs./Lbs.
<b>MERCURY ALLOYS</b>									
120	LBM-100C-L-00	170	17	LBM-100C-L-00	170	17	170	LBM-100C-L-00	170
170	LBM-100C-L-00	17	17	LBM-100C-L-00	17	17	17	LBM-100C-L-00	17
220	LBM-100C-L-00	10	17	LBM-100C-L-00	10	17	10	LBM-100C-L-00	10
<b>METAL HALIDE</b>									
170	-	-	-	LBM-170H-L-00	170	17	170	LBM-170H-L-00	170
220	-	-	-	LBM-220H-L-00	220	22	220	LBM-220H-L-00	220
<b>HIGH PRESSURE SODIUM</b>									
10	LBM-10H-L-00	10	10	LBM-10H-L-00	10	10	10	LBM-10H-L-00	10
100	LBM-100H-L-00	10	10	LBM-100H-L-00	100	10	100	LBM-100H-L-00	100
150	LBM-150H-L-00	15	15	LBM-150H-L-00	150	15	150	LBM-150H-L-00	150
200	LBM-200H-L-00	20	20	LBM-200H-L-00	200	20	200	LBM-200H-L-00	200
<b>HIGH PRESSURE BROMINE</b>									
70	LBM-70B-L-00	10	10	LBM-70B-L-00	10	10	10	LBM-70B-L-00	10
100	LBM-100B-L-00	10	10	LBM-100B-L-00	100	10	100	LBM-100B-L-00	100
150	LBM-150B-L-00	15	15	LBM-150B-L-00	150	15	150	LBM-150B-L-00	150

GOVERNMENT OF CANADA

STRUCTURAL - TYPE V					AEROMARINE TYPE I				
LNG CSC WHEEL	DRIVE ROTATOR	WEIGHT		PERCENTAGE REDUCTION	WEIGHT		DRIVE ROTATOR	WEIGHT	
		IN LB	IN KG		IN LB	IN KG		IN LB	IN KG
<b>MERCURY WHEEL</b>									
100	LNG-100C-LD	134	61	LNG-100C-LD	126	57	LNG-100C-LD	126	57
175	LNG-175C-LD	14	6	LNG-175C-LD	13	6	LNG-175C-LD	13	6
<b>METAL VALVE</b>									
175	LNG-175C-LD	37	17	LNG-175C-LD	37	17	LNG-175C-LD	37	17
<b>HIGH PRESSURE TOWER</b>									
70	LNG-100S-LD	10	6	LNG-100S-LD	10	6	LNG-100S-LD	10	6
100	LNG-100S-LD	10	6	LNG-100S-LD	10	6	LNG-100S-LD	10	6
175	LNG-175S-LD	19	9	LNG-175S-LD	17	8	LNG-175S-LD	17	8
<b>HIGH PRESSURE SECTION</b>									
70	LNG-100S-LD	10	6	LNG-100S-LD	10	6	LNG-100S-LD	10	6
100	LNG-100S-LD	10	6	LNG-100S-LD	10	6	LNG-100S-LD	10	6
175	LNG-175S-LD	19	9	LNG-175S-LD	17	8	LNG-175S-LD	17	8

1998 ELECTRONIC PRACTICE INDEX 4

STANDARD - TYPE V		ADDITIONAL - TYPE C	
Lots and Batches		Lots and Batches	
<b>MERCURY VAPOR</b>			
100	100-400-21-0	100	100
<b>HIGH PRESSURE VOLTM</b>			
100	100-300-21-0	100	100
<b>LOW PRESSURE VOLTM</b>			
100	100-300-21-0	100	100
100	100-400-21-0	100	100

\* L. ROBERT BROWN FROM SOUTHERN CALIFORNIA TO "B" IN CLOTHING REPORTS 3 FOR 4000 AND 9 TO QUAD "A" 22 300 240 277 AND 9 TO QUAD  
THE P.R.C. 277-4001  
REMOVED 12/10/1968  
REMOVED 12/10/1968  
REMOVED 12/10/1968

### **Dimensions**




Figure 1  
Biplots

## Sigum 2 Reflektor-Fernseh

१५

Figure 4 Page 3-26  
Large Appliance Rating  
S. 100-6000

## Lowbay Installation Instructions




- Install mounting adapter
  - As housing hangs on mounting adapter, complete electrical connection.



- Close and secure housing to mounting adapter



- beach lamp and beach scenes



## **OPTIONS**

The following letters require urgent and immediate use of the London Series  
form over to receive necessary form the letter by strong the stamping  
table across Order Courses Log.

SURFACE	DESCRIPTION
CUT	CORING AND HOOF - At 80° C (176° F) until the hoofs are softened and flexible.
CUT	CORING AND LOOP - At 90° C (194° F) until the hoofs are softened and flexible.
(P) (21)*	PLUG-HELMET HYDRO THERAPY - 100° C (212° F) for 2 to 3 hours hydrotherapy - 100° C (212° F) for 10 minutes to 20 minutes for softening flexible hoofs.
(P)	REFLECTIVE POLYCARBONATE - 2 mm covering each hoof. Several surfaces is required to correctly distribute and support tension for the hoof to be reinforced - 100° C (212° F).
(P)	QUARTZ STABILIZED SYSTEM - 100° C (212° F) for 10 to 12 hours allowing the formation of quartz crystal structures that are resistant to heat and cold.




- "Purusha" = विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र
- "Devi" = विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र विश्वामित्र

## ACCESSORIES

The following assessments are designed for the Learning Zones. They may be grouped together.

Category Description	Description
SL-1	Weld joints for relatively thin-walled structures and day
ROOD	Cold or warm-up by the same methods except better
LODGE	Cold, or warm-up by fire place

## PHOTOMETRIC DATA



## **Suggested Specifications**


**General**  
Lighting shall be 12,000L Lighting Dev. LED Series. Back of Number USA. 100W each & 1000W each.

**Mounting**  
Gauge housing that has the cold cathode fluorescent bulb mounted inside with built-in electrical connection to the control electronics are being used. The housing housing shall be designed to such a way that it can be mounted directly without any brackets or large space requirement.  
Gauge housing shall have two curved horns for permanent attachment of the temperature. The same & appropriate area of the housing shall stick to the control system and no adhesives.

Measuring accuracy must be to  $\pm 0.001$  mm. Accuracy that is to be used depends on the structure. Measuring devices must have the hinge arms and lead carriage support points as precisely located as possible for a precise test. Contact heat to high temperature, should be prevented.

Central African Republic: Humanitarian Crisis and the Impact on Children

U.S. and its Committee with actual laboratory processing & testing. You \_\_\_\_\_ requested Sampling done shall be \_\_\_\_\_ the procedure used.



## Wenning

# High-Bay Industrial Lighting

## ORDERING SEQUENCE

### CATALOG NUMBER

### VOLTAGE

### OPTIONS (Factory Installed)

TE 175M E17C  
 TE 175M E17M  
 TE 175M E17S  
 TE 175M E17W

120  
 210  
 240  
 277  
 400  
 707

SF Shipped Installed In Fixture  
 SF Single Fuse (120/277V); 16A TS  
 SF Double Fuse (200/240/410V) 40A TS  
 EC Emergency Circuit (240V not included)  
 BRST Backup Resistor System (Not included)  
 BRSTDY DRS Time Delay (1amp not included)

HA 65°C Ambient Operation  
 CR Corrosion Resistant Finish (not listed)  
 CRT Corrosion Resistant Finish (not listed)  
 TEF Teflon Coated Reflector  
 TOSI Three-Wire Outer Pin  
 TOSP Three-Wire Outer Pin Plug-in  
 PNP Pendant Base 90° up-in  
 LCP Loop Cord & Plug for 7PH & 2PH  
 LCSP\*\* Loop 3' Cord & 15A HEAVY Duty Plug  
 NCSP\*\* Head 3' Cord & 15A HEAVY Duty Plug  
 LRCA\*\* Loop 3' Cord & Female RCA Connector  
 KRCA\*\* Head 3' Cord & Male RCA Connector  
 LUCP Loop Cord and Plug for LPN1  
 LUCPSP LUCP w/3 amp Fuse (120/240V) 16A TS  
 LUCPOP LUCP w/Double Fuse (240V) 16A TS  
 UCP Universal Cable & Plug w/SPK  
 UCPSP UCP w/Single Fuse (240V) 16A TS  
 UCPDP UCP w/Double Fuse (240V) 16A TS  
 TR Remote Base  
 TRC22\*\* TR w/Fire Wire Cable  
 WL Wet Location UL Listed  
 C73T Covering C73 Pattern Temperature Controller  
 SSS Stainless Steel Screens  
 SLR Stainless Steel Long Range  
 UP JP Lamp  
 CF Chokeless Fitter

### Shipped Separately \*

HKMP Fixture Mount - Male  
 HKMF Grommeted Fixture Mount - Male  
 LPMP Fixture Loop - Male  
 LPMPG Grommeted Fixture Loop - Male  
 TPMP Threaded Power Head  
 PPM Power Head  
 UPN1 Universal Power Nipple  
 UPN1\*\* UPN w/1600w Adapter Plate  
 UPN2 UPN w/Wiring Block  
 UPN3 Lamp Adapter Plate & Wiring Block  
 WG Wave Guard/Nutrium Reflector  
 LS Louver Glass  
 OCT Cylinder Shade  
 DSO Silver Shade  
 DMX Multigrid Shade

BSTR	MM
E17C	10
E17M	14
E17S	16
E17W	20

Weight 228.6 lbs/103kg

### NOTES


- \* May be ordered as options with S, 10, 15, 20, 240V
- \* Volt-Tap Switch (\*20,240,277V)
- \* Output lamp voltage not to exceed ballast voltage rating
- \* May be ordered as accessories. MUST list individual accessories separately in ordering information
- \* 36 cable to connector can be remote bases
- \* 20 amp standard 480V
- \* Day/night distributor
- \* Corrosion Resistant
- \* Not available w/ 20A TS

For Complete Description & Application Information See Options & Accessories Sheet OIA

### Fixture Type

# TE

METAL HALIDE  
175W  
12' to 20' Mounting



### SPECIFICATIONS

**HOUSING** - Rugged, lightweight, die-cast aluminum with dark bronze polyester powder finish. Electrical components are appressed horizontally and heat-sinked to the housing for cooler operation.

**BALLAST** - High power factor 4-wire autotransformer, 110° insulation system

**OPTICS** - One piece totally enclosed gasketed Arc Tek® spun aluminum reflector combines high efficiency with a tensioned shielding angle for high performance optical control. Exclusive fluting design minimizes arc tube voltage rise. Gasketed clear tempered glass lens inhibits the entrance of ambient contaminants.

**INSTALLATION** - Pendant spacing base threaded "for 3/4" conduit (standard). Complete line of mounting options and accessories available.

**LISTING** - UL 1572 listed for damp location and -30°C to 55°C ambient operation. UL wet location label option available.

**SOCKET** - Pendant - vertically oriented mogul base socket with copper alloy metal plated screw shell and center contact. UL listed 1500W - CCCV

 **LITHONIA**  
**HI-TEK**  
INDUSTRIAL OUTDOOR LIGHTING  
• DESIGN BY LITHONIA •

## PHOTOMETRIC DATA

The charts below present the most useful data from specific photometric tests of the specific light sources and distribution patterns shown. For complete results of any combination shown, or other requirements, contact your HI-TEK-LITHONIA representative.

**TE 175M E17C**

Item No. 11604

Lamp 175 watt Metal Halide Lamp 12,000 lumens  
Measured according to mounting height ratio 1.0

### COMPONENTS OF UTILIZATION

	100%	10%	1%
100% Utilization	100	10	1
10% Utilization	100	10	1
1% Utilization	100	10	1
Total Utilization	100	10	1
100% Utilization	100	10	1
10% Utilization	100	10	1
1% Utilization	100	10	1
Total Utilization	100	10	1

### DISTRIBUTION DATA



**TE 175M E17S**

Item No. 11605

Lamp 175 watt Metal Halide Lamp 12,000 lumens  
Measured according to mounting height ratio 1.0

### COMPONENTS OF UTILIZATION

	100%	10%	1%
100% Utilization	100	10	1
10% Utilization	100	10	1
1% Utilization	100	10	1
Total Utilization	100	10	1
100% Utilization	100	10	1
10% Utilization	100	10	1
1% Utilization	100	10	1
Total Utilization	100	10	1

### DISTRIBUTION DATA



**TE 175M E17M**

Item No. 11606

Lamp 175 watt Metal Halide Lamp 12,000 lumens  
Measured according to mounting height ratio 1.0

### COMPONENTS OF UTILIZATION

	100%	10%	1%
100% Utilization	100	10	1
10% Utilization	100	10	1
1% Utilization	100	10	1
Total Utilization	100	10	1
100% Utilization	100	10	1
10% Utilization	100	10	1
1% Utilization	100	10	1
Total Utilization	100	10	1

### DISTRIBUTION DATA



**TE 175M E17W**

Item No. 11607

Lamp 175 watt Metal Halide Lamp 12,000 lumens  
Measured according to mounting height ratio 1.0

### COMPONENTS OF UTILIZATION

	100%	10%	1%
100% Utilization	100	10	1
10% Utilization	100	10	1
1% Utilization	100	10	1
Total Utilization	100	10	1
100% Utilization	100	10	1
10% Utilization	100	10	1
1% Utilization	100	10	1
Total Utilization	100	10	1

### DISTRIBUTION DATA



## ELECTRICAL CHARACTERISTICS

Current Rating	Input Power	Efficiency	Power Factor	Wattage	Wattage	Wattage
120	110-120	70				
170	200	60-70	70			
210	240	50-60	100			
260	277	40-50	150	210	260	310
300	312	30	180	240	300	360

Tested to IEC 60068-2-27 and MIL-STD-883C methods under standard laboratory procedures. All test conditions are for 100% utilization. Standard laboratory test conditions are 100% utilization, 120° ambient temperature, and no load. Actual lamp performance may vary due to differences in mounting height, fixture design, and other factors. Consult factory for details.

 **LITHONIA**  
**HI-TEK**

INDUSTRIAL & COMMERCIAL LIGHTING

P.O. BOX 50, 10000 N. Cicero Avenue, Skokie, IL 60077 • 847/675-3100

PAGE 3-270

3-1977-2-84-18

# High-Bay Industrial Lighting

## ORDERING SEQUENCE

CATALOG NUMBER      VOLTAGE      OPTIONS (Factory Installed)

<input checked="" type="checkbox"/> TE 250M E17C	C 120	Shipped Installed in Fixture
<input checked="" type="checkbox"/> TE 250M E17M	C 208	<input checked="" type="checkbox"/> SF Single Fuse 120/277V 1A or 15A
<input checked="" type="checkbox"/> TE 250M E17S	O 260	<input checked="" type="checkbox"/> DF Double Fuse 120/240/277V 1A or 15A
<input checked="" type="checkbox"/> TE 250M E17W	G 277	<input checked="" type="checkbox"/> EC Emergency Cutout (Bulb not included)
	C 480	<input checked="" type="checkbox"/> CRS <sup>1</sup> Current Resistive System (Bulb not included)
	C 78V	<input checked="" type="checkbox"/> CRSTD <sup>2</sup> CRS Time Delay Lamp (not included)
	C 110V	<input checked="" type="checkbox"/> HA 65°C Ambient Operation
	C ER	<input checked="" type="checkbox"/> CER Concen. Pendant Finish (converter)
	C CRT	<input checked="" type="checkbox"/> CRT Concen. Pendant Finish (reflector)
	C TEF	<input checked="" type="checkbox"/> TEF Teflon Coated Reflector
	C TDB <sup>3</sup>	<input checked="" type="checkbox"/> TDB <sup>3</sup> Teflon Coated Base
	C TCBP	<input checked="" type="checkbox"/> TCBP Third Wire Cable Box Hinged
	C PBM	<input checked="" type="checkbox"/> PBM Porcelain Base Plug-in
	C LCPP	<input checked="" type="checkbox"/> LCOP <sup>4</sup> Loop Core & Plug for 1PH & 3PH
	C LC3P <sup>5</sup>	<input checked="" type="checkbox"/> LC3P <sup>5</sup> Loop 3 Core & 1SA HEMI <sup>6</sup> (w/o) Loop Plug
	C MCOP <sup>7</sup>	<input checked="" type="checkbox"/> MCOP <sup>7</sup> Knob, 3 Core & 1SA HEMI <sup>6</sup> (w/o) Loop Plug
	C LRCAT <sup>8</sup>	<input checked="" type="checkbox"/> LRCAT <sup>8</sup> Loop 3 Core & Reloc. RCA Connector
	C MRCAV <sup>9</sup>	<input checked="" type="checkbox"/> MRCAV <sup>9</sup> Metal, 3 Core & Reloc. RCA Connector
	C LUPM	<input checked="" type="checkbox"/> LUPM Loop Core and Plug for UPMI
	C LUCPSP	<input checked="" type="checkbox"/> LUCPSP Loop w/Single Fuse (leads bare) 1A or 15A
	C LUCPDP	<input checked="" type="checkbox"/> LUCPDP Loop w/Double Fuse (leads bare) 1A or 15A
	C UCP	<input checked="" type="checkbox"/> UCP Universal Core & Plug for UPM
	C UCPSP	<input checked="" type="checkbox"/> UCPSP UCP w/Single Fuse (leads bare) 1A or 15A
	C UCPDP	<input checked="" type="checkbox"/> UCPDP UCP w/Double Fuse (leads bare) 1A or 15A
	C TH	<input checked="" type="checkbox"/> TH Remote Switch
	C TRCP <sup>10</sup>	<input checked="" type="checkbox"/> TRCP <sup>10</sup> TR w/Pro-Wire Cable
	C WL	<input checked="" type="checkbox"/> WL Wet Location UL Listed
	C CT3T <sup>11</sup>	<input checked="" type="checkbox"/> CT3T Corning CT3 Pattern Tempered Glass Lens
	C SSS	<input checked="" type="checkbox"/> SSS Stainless Steel Screen
	C SLR	<input checked="" type="checkbox"/> SLR Stainless Steel Lens Rings
	C UP	<input checked="" type="checkbox"/> UP Lamp
	C CP	<input checked="" type="checkbox"/> CP Chandelier Fitter

### Shipped Separately<sup>12</sup>

<input checked="" type="checkbox"/> HEM <sup>13</sup>	Fixture Neck - Male
<input checked="" type="checkbox"/> HEMO <sup>14</sup>	Grounded Fixture Neck - Male
<input checked="" type="checkbox"/> LPN <sup>15</sup>	Fixture Lens - Male
<input checked="" type="checkbox"/> LPNG <sup>16</sup>	Grounded Fixture Lens - Male
<input checked="" type="checkbox"/> TPW <sup>17</sup>	Third-Wire Tower Neck
<input checked="" type="checkbox"/> PPMP	Pendant Power Supply
<input checked="" type="checkbox"/> UPM <sup>18</sup>	Universal Power Supply
<input checked="" type="checkbox"/> UPMI <sup>19</sup>	UPM w/Protect Adapter - Pulse
<input checked="" type="checkbox"/> UPMZ <sup>20</sup>	UPM Warning Buzz
<input checked="" type="checkbox"/> UPMZ <sup>21</sup>	UPM w/Protect Adapter - Pulse & W/Buzz & Buzz
<input checked="" type="checkbox"/> WB	Wet Glass/Aluminum Reflector
<input checked="" type="checkbox"/> LS	Lowest Glass <sup>22</sup>
<input checked="" type="checkbox"/> DCY	Synthetic Shade
<input checked="" type="checkbox"/> DSG	Silicate Shade
<input checked="" type="checkbox"/> DMX	Mercury Glass

### ACCESSORIES (Item #s in parentheses)

ITEM #	DESCRIPTION
HEP	Fixture Neck Adapter
LPP	Fixture Lens - Female
SSK	Screw Cover Kit
TMB	Tower Mounting Bar (comes w/ fixture)


- NOTES:
- <sup>1</sup> May also be ordered with 5, 10, 15° or 20° optics.
- <sup>2</sup> Multi-Tap Ballast (120/208/240/277V)
- <sup>3</sup> Cover frame transports intact in excess of 2000 watt rating.
- <sup>4</sup> May be ordered as accessory. "UPL" see Industrial Accessories Sales "O"
- <sup>5</sup> Ordering information
- <sup>6</sup> 10° cable to center terminal on remote switch
- <sup>7</sup> 20 amp standard 483V
- <sup>8</sup> May change existing or construct factory
- <sup>9</sup> Not available w/LC or CT
- <sup>10</sup> Complete Description & Application Information, See Options & Accessories Sheet Q-A

Fixture Type:

TE

### METAL HALIDE

250W ENCL. 120/277V  
15° to 20° H.D. - A2



### SPECIFICATIONS

**HOUSING** - Rugged, lightweight, die-cast aluminum with clear bronze polyester powder finish. Electrical components are opposed horizontally and heat-sinked to housing for cooler operation.

**BALLAST** - High power factor. Constant voltage autotransformer. 180°C Class H insulation system.

**OPTICS** - One piece totally enclosed arc gasketed Acro Tek II spun aluminum, anodized reflector combines high efficiency with extended shattering angle for high performance optical control. Gasketed clear tempered glass lens shield is the entrance of ambient contaminants.

**INSTALLATION** - Pendant option (threaded for 3/4" cord) (standard). Complete line of mounting options and accessories available.

**LISTING** - UL 1572 listed for same location 0°F - 30°C to 55°C ambient operation. UL wet location label option available.

**SOCKET** - Porcelain, vertically oriented mogul base socket with copper alloy nickel plated screw shell and center contact. UL listed: 120W - 600V

 **LITHONIA**  
**HI-TEK**  
INDUSTRIAL OUTDOOR LIGHTING  
A Division of Lithonia Lighting

## PHOTOMETRIC DATA

The charts below provide the most useful data from specific photometric tests of the specific light sources and distribution patterns shown. For complete analysis of any combination shown, or other requirements, contact your MITSUBISHI representative.

TE 250M E17A										MAP 310 West March 1945 Series 10 000 Sections 1:63,360 according to existing height lines 1:2									
1st Edition 1st 1945																			
COMPONENTS OF UTILIZATION										DISTRIBUTION DATA									
C	LAND USE									POPULATION									
	%	Acres	%	Acres	%	Acres	%	Acres	%	Population	%	Urban	%	Rural	%	Total	%		
1	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100			
2																			
3																			
4																			
5																			
6																			
7																			
8																			
9																			
10																			
CIVILIAN DATA										CIVILIAN DATA									
Land										Population									
11	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100		
12																			
13																			
14																			
15																			
16																			
17																			
18																			
19																			
20																			

## ELECTRICAL CHARACTERISTICS

	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Oct-10-02	2000-01	2000-02	2000-03	2000-04	2000-05	2000-06	2000-07	2000-08	2000-09	2000-10	2000-11	2000-12
Oct-10-02	2001-01	2001-02	2001-03	2001-04	2001-05	2001-06	2001-07	2001-08	2001-09	2001-10	2001-11	2001-12
Oct-10-02	2002-01	2002-02	2002-03	2002-04	2002-05	2002-06	2002-07	2002-08	2002-09	2002-10	2002-11	2002-12
Oct-10-02	2003-01	2003-02	2003-03	2003-04	2003-05	2003-06	2003-07	2003-08	2003-09	2003-10	2003-11	2003-12
Oct-10-02	2004-01	2004-02	2004-03	2004-04	2004-05	2004-06	2004-07	2004-08	2004-09	2004-10	2004-11	2004-12
Oct-10-02	2005-01	2005-02	2005-03	2005-04	2005-05	2005-06	2005-07	2005-08	2005-09	2005-10	2005-11	2005-12
Oct-10-02	2006-01	2006-02	2006-03	2006-04	2006-05	2006-06	2006-07	2006-08	2006-09	2006-10	2006-11	2006-12
Oct-10-02	2007-01	2007-02	2007-03	2007-04	2007-05	2007-06	2007-07	2007-08	2007-09	2007-10	2007-11	2007-12
Oct-10-02	2008-01	2008-02	2008-03	2008-04	2008-05	2008-06	2008-07	2008-08	2008-09	2008-10	2008-11	2008-12
Oct-10-02	2009-01	2009-02	2009-03	2009-04	2009-05	2009-06	2009-07	2009-08	2009-09	2009-10	2009-11	2009-12
Oct-10-02	2010-01	2010-02	2010-03	2010-04	2010-05	2010-06	2010-07	2010-08	2010-09	2010-10	2010-11	2010-12
Oct-10-02	2011-01	2011-02	2011-03	2011-04	2011-05	2011-06	2011-07	2011-08	2011-09	2011-10	2011-11	2011-12

Следует отметить, что в последние годы в Китае возникла тенденция к снижению производительности труда, что связано с тем, что в стране наблюдается перенаселение и высокий уровень инфляции.



Digitized by srujanika@gmail.com

Digitized by srujanika@gmail.com

[View all posts](#)

• 5 300


## **High-Bay Industrial Lighting ORDERING SEQUENCE**

Firsts Page

CATALOG NUMBER	VOLTAGE	OPTIONS (FACSIMILE TRAILER)
-	-	-
-	-	-

C TE 400M C23N	C 128	3-wire lead-in in fixture
C TE 400M E22G	D 208	D SF Single Fuse (120 277v, n.o. 18)
D TE 400M E17M	D 212	C OF Double Fuse (208 240v, n.o. 16)
C TE 400M E17S	C 277	C IC Emergency Circuit Lamp not selected
D TE 400AM E17W	D 482	C OFS <sup>1</sup> Diverge Reserve System Lamp not selected
	C 174	D OFSTD <sup>2</sup> OFS Time Delay Lamp not selected

५० अप्रैल  
६० जून१९४८  
७० अप्रैल  
८० सितंबर  
९० अप्रैल



Q3: R	SDM
634	2.8
820	1.0
874	1.6
278	1.6
874	1.9

ପ୍ରକାଶକ ପତ୍ର ନିମ୍ନଲିଖିତ  
ପତ୍ର ପାଇଁ

3088

Ein Computer beschreibt die Arbeitstechnik  
vergleichbar mit dem Computer der Arbeitswelt

Shipped Installed in Fixture	
□ SF	Single Fuse (120 277v, 15A TS)
□ DF	Double Fuse (220 240v & 120v, 15A TS)
□ EC	Emergency Circuit Lamp Kit included
□ GRSI	Quartz Recessed System Lamp Kit included
□ GRSTDY	GRS Time Delay Lamp Kit included
□ HA	100% Anti-ent Operator
□ CR	Corrosion Resistant fixture (specifiers)
□ CRT	Corrosion Resistant Lamp (specifiers)
□ TEF	Telescopic Recessed Operator
□ TOSI	"T" - Style Switch Box
□ TOSBP	Tall "T" Style Switch Box Plug-in
□ PSSP	Portrait Box Plug-in
□ LCPF	Lock Core & Plug-in "PM" & "PP"
□ LCSP**	Lock 3 Core & 15A NEMA 7-20R Power Plug
□ MCSP**	Master 3 Core & 15A NEMA 5-20R Power Plug
□ LRCG**	Lock 3 Core & Power RCA Connector
□ HRCG**	Master 3 Core & Power RCA Connector
□ LUCP	Lock Core & Plug Port "SPB1"
□ SUCEPSP	LUCP w/Single Fuse (120v) 15A TS
□ SUCEPDP	LUCP w/Double Fuse (220v) 15A TS
□ UCP	Universal Core & Plug for UPL
□ UCSP	UCP w/Single Fuse (120v) 15A TS
□ UCDP	UCP w/Double Fuse (220v) 15A TS
□ TA	Remote Bypass
□ TADP**	TA w/15A Single Core
□ WR	Kits, Options U, Latch
□ ESYT	Corning 270 Watt Tempered Glass, .993
□ ESS	Scintex Smart Screen
□ CLR	Clearview Smart Screen Angle
□ LP	UL Listed
□ CP	Corrosion Proof

Digitized by srujanika@gmail.com


Q	W.MP	Black Rose - Male
Q	LEADER	Groomed Rose - Male - V20
Q	LPM	Purple Rose - M30
Q	LPMS	Groomed Purple Rose - MPM
Q	TRP	Red Rose - Male
Q	PPP	Pink Rose - P30
Q	WRP	Washed Rose - W30
Q	WPST	White Washed Rose - W30
Q	WPSTP	White Washed Rose - P30
Q	WPSTY	WP30 White Rose
Q	WPSTYI	WP30 White Rose - P30 S. Long Stem
Q	WT	White Groomed Rose
Q	LG	Large Rose
Q	CGY	Coral Rose
Q	GRG	Green Rose
Q	BRZ	Brown Rose

ISBN 978-88-11-88035-3

CM 04	00000000
MEPC	00000000 - 000000
CPP	00000000 - 000000
ICE	00000000
TRI	00000000 - 000000

**TE**

**METAL HALIDE  
400W ENCLOSED  
20' to 30' Mounting**



## SPECIFICATIONS

**HOUSING** • Rugged, lightweight die-cast aluminum with dark blue polyester powder coat. Electrical components are designed heat-shielding and real estate is left for mounting for greater insulation.

**BALLAST • HIGH POWER FACTOR Constant  
voltage autotransformer 100% class H  
insulation system**

**OPTICS** - One of the 2013's highlights and pastelites are the 11mm ultra-wide lenses. It features 17 elements in 11 groups, including two aspherical lenses, and a maximum aperture of f/2.8. The high performance optical formula has been optimized for improved sharpness and the influence of ambient light.

**INSTALLATION** - Please refer to instructions for 3 1/4" corner island. Consists of 16 mounting screws and 12 corner base plates.

avg. -30°C to +5°C ambient operation. UL wet location and option available.

SOCKET - Portuguese version by CIRIACO P. M. V.  
DATE SCANNED 19-03-2008 FILED 02-03-2008  
SCANNED BY LANCEMENT CORRECT BY LIL HAD  
090017 650V







## PHOTOMETRIC DATA

The chart below provides the most useful data from specific photometric tests of the specific light source and distribution patterns shown. For complete results of any combination (lens or other requirements) contact your HI-TEK LITHONIA representative.

TE 1000M E22C

1000 watt incandescent lamp over 110,000 lumens  
lens factor no. 1.000

COEFFICIENTS OF UTILIZATION

DISTRIBUTION DATA

	100	200	300	400	500	600	700	800	900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400	2500	2600	2700	2800	2900	3000	3100	3200	3300	3400	3500	3600	3700	3800	3900	4000	4100	4200	4300	4400	4500	4600	4700	4800	4900	5000	5100	5200	5300	5400	5500	5600	5700	5800	5900	6000	6100	6200	6300	6400	6500	6600	6700	6800	6900	7000	7100	7200	7300	7400	7500	7600	7700	7800	7900	8000	8100	8200	8300	8400	8500	8600	8700	8800	8900	9000	9100	9200	9300	9400	9500	9600	9700	9800	9900	10000	10100	10200	10300	10400	10500	10600	10700	10800	10900	11000	11100	11200	11300	11400	11500	11600	11700	11800	11900	12000	12100	12200	12300	12400	12500	12600	12700	12800	12900	13000	13100	13200	13300	13400	13500	13600	13700	13800	13900	14000	14100	14200	14300	14400	14500	14600	14700	14800	14900	15000	15100	15200	15300	15400	15500	15600	15700	15800	15900	16000	16100	16200	16300	16400	16500	16600	16700	16800	16900	17000	17100	17200	17300	17400	17500	17600	17700	17800	17900	18000	18100	18200	18300	18400	18500	18600	18700	18800	18900	19000	19100	19200	19300	19400	19500	19600	19700	19800	19900	20000	20100	20200	20300	20400	20500	20600	20700	20800	20900	21000	21100	21200	21300	21400	21500	21600	21700	21800	21900	22000	22100	22200	22300	22400	22500	22600	22700	22800	22900	23000	23100	23200	23300	23400	23500	23600	23700	23800	23900	24000	24100	24200	24300	24400	24500	24600	24700	24800	24900	25000	25100	25200	25300	25400	25500	25600	25700	25800	25900	26000	26100	26200	26300	26400	26500	26600	26700	26800	26900	27000	27100	27200	27300	27400	27500	27600	27700	27800	27900	28000	28100	28200	28300	28400	28500	28600	28700	28800	28900	29000	29100	29200	29300	29400	29500	29600	29700	29800	29900	30000	30100	30200	30300	30400	30500	30600	30700	30800	30900	31000	31100	31200	31300	31400	31500	31600	31700	31800	31900	32000	32100	32200	32300	32400	32500	32600	32700	32800	32900	33000	33100	33200	33300	33400	33500	33600	33700	33800	33900	34000	34100	34200	34300	34400	34500	34600	34700	34800	34900	35000	35100	35200	35300	35400	35500	35600	35700	35800	35900	36000	36100	36200	36300	36400	36500	36600	36700	36800	36900	37000	37100	37200	37300	37400	37500	37600	37700	37800	37900	38000	38100	38200	38300	38400	38500	38600	38700	38800	38900	39000	39100	39200	39300	39400	39500	39600	39700	39800	39900	40000	40100	40200	40300	40400	40500	40600	40700	40800	40900	41000	41100	41200	41300	41400	41500	41600	41700	41800	41900	42000	42100	42200	42300	42400	42500	42600	42700	42800	42900	43000	43100	43200	43300	43400	43500	43600	43700	43800	43900	44000	44100	44200	44300	44400	44500	44600	44700	44800	44900	45000	45100	45200	45300	45400	45500	45600	45700	45800	45900	46000	46100	46200	46300	46400	46500	46600	46700	46800	46900	47000	47100	47200	47300	47400	47500	47600	47700	47800	47900	48000	48100	48200	48300	48400	48500	48600	48700	48800	48900	49000	49100	49200	49300	49400	49500	49600	49700	49800	49900	50000	50100	50200	50300	50400	50500	50600	50700	50800	50900	51000	51100	51200	51300	51400	51500	51600	51700	51800	51900	52000	52100	52200	52300	52400	52500	52600	52700	52800	52900	53000	53100	53200	53300	53400	53500	53600	53700	53800	53900	54000	54100	54200	54300	54400	54500	54600	54700	54800	54900	55000	55100	55200	55300	55400	55500	55600	55700	55800	55900	56000	56100	56200	56300	56400	56500	56600	56700	56800	56900	57000	57100	57200	57300	57400	57500	57600	57700	57800	57900	58000	58100	58200	58300	58400	58500	58600	58700	58800	58900	59000	59100	59200	59300	59400	59500	59600	59700	59800	59900	60000	60100	60200	60300	60400	60500	60600	60700	60800	60900	61000	61100	61200	61300	61400	61500	61600	61700	61800	61900	62000	62100	62200	62300	62400	62500	62600	62700	62800	62900	63000	63100	63200	63300	63400	63500	63600	63700	63800	63900	64000	64100	64200	64300	64400	64500	64600	64700	64800	64900	65000	65100	65200	65300	65400	65500	65600	65700	65800	65900	66000	66100	66200	66300	66400	66500	66600	66700	66800	66900	67000	67100	67200	67300	67400	67500	67600	67700	67800	67900	68000	68100	68200	68300	68400	68500	68600	68700	68800	68900	69000	69100	69200	69300	69400	69500	69600	69700	69800	69900	70000	70100	70200	70300	70400	70500	70600	70700	70800	70900	71000	71100	71200	71300	71400	71500	71600	71700	71800	71900	72000	72100	72200	72300	72400	72500	72600	72700	72800	72900	73000	73100	73200	73300	73400	73500	73600	73700	73800	73900	74000	74100	74200	74300	74400	74500	74600	74700	74800	74900	75000	75100	75200	75300	75400	75500	75600	75700	75800	75900	76000	76100	76200	76300	76400	76500	76600	76700	76800	76900	77000	77100	77200	77300	77400	77500	77600	77700	77800	77900	78000	78100	78200	78300	78400	78500	78600	78700	78800	78900	79000	79100	79200	79300	79400	79500	79600	79700	79800	79900	80000	80100	80200	80300	80400	80500	80600	80700	80800	80900	81000	81100	81200	81300	81400	81500	81600	81700	81800	81900	82000	82100	82200	82300	82400	82500	82600	82700	82800	82900	83000	83100	83200	83300	83400	83500	83600	83700	83800	83900	84000	84100	84200	84300	84400	84500	84600	84700	84800	84900	85000	85100	85200	85300	85400	85500	85600	85700	85800	85900	86000	86100	86200	86300	86400	86500	86600	86700	86800	86900	87000	87100	87200	87300	87400	87500	87600	87700	87800	87900	88000	88100	88200	88300	88400	88500	88600	88700	88800	88900	89000	89100	89200	89300	89400	89500	89600	89700	89800	89900	90000	90100	90200	90300	90400	90500	90600	90700	90800	90900	91000	91100	91200	91300	91400	91500	91600	91700	91800	91900	92000	92100	92200	92300	92400	92500	92600	92700	92800	92900	93000	93100	93200	93300	93400	93500	93600	93700	93800	93900	94000	94100	94200	94300	94400	94500	94600	94700	94800


## High-Bay Industrial Lighting

### ORDERING SEQUENCE

CATALOG NUMBER	VOLTAGE	OPTIONS (If Safety Installed)
TE 150S E17C	120V	Shipped Installed In Fixture

TE 150S E17M	208	SF Single Fuse (120,000mA) No 'B'
TE 150S E17S	240	DF Double Fuse (220,240,480V) No 'B'
TE 150S E17W	277	EC Emergency Circuit Lamp (not included)
	480	DRS <sup>1</sup> Smart Reserve System (lamps not included)
	575	DRS Time Delay (lamps not included)
	NA	ESIC Ambient Operator
	CR	Corrosion Resistant Lamp (not included)
	CRP	Corrosion Resistant Lamp Holder
	TRP	Temp Control Sensor
	TOP	Thermal Cut-off
	TOPP	Temp Wire Cut-off for Plug-in
	PP	Per cent Box Plug-in
	LCPP	Lead Core & Plug for 28W & PNP
	LCSP <sup>2</sup>	Lead 3 Core & 15A NEMA Type 2 Lead Plug
	RCSP <sup>3</sup>	Lead 3 Core & 15A NEMA Type 2 Lead Plug
	LRCA <sup>4</sup>	Lead 3 Core & Female RCA Connector
	MRCA <sup>5</sup>	Lead 3 Core & Male RCA Connector
	LUCP	Lead Core & PNP (for LPM)
	LUCPSP	LUCP working fuse (lead core) No 'B'
	LUCPDP	LUCP working fuse (lead core) No 'B'
	UPL	Universal Plug & Plug for JPN
	UCPSP	JPN working fuse (lead core)
	ULCPD	JPN working fuse (lead core)
	TR	Remote Control
	TRCP <sup>6</sup>	IR Remote Control
	WL	Wire Locator Kit
	LCTP	Color 222 Pattern Tempered Glass Lens
	SSS	Stainless Steel Screws
	SLR	Stainless Steel Lens Rings
	UP	Up Light
	CP	Spotcast <sup>7</sup> (not)
	MRE	Magnetic Remote Receiver
	CWA	Conduit: Wirsing 20mm diameter

1. Conductor  
2. Megger  
3. IP65  
4. Water-tight



DIAM	SH. MM
E17C	10
E17M	13
E17S	16
E17W	19.5

Height: 20.25" / 514mm

#### NOTES:

1. Hazardous locations up to T5

2. See ratings

3. UL-Listed (2000 CEC 277)

4. 2000 watt megger (not included)

5. IP65 rating

6. May be ordered as Emergency. MUST

SEE ACCESSORIES IN SECTION FOR

ordering information

7. Spotcast is currently not available

1. 1000W 80-90%

2. 1000W 80-90%

3. Standard 2000W 80-90%

4. Standard 2000W 80-90%

5. Standard 2000W 80-90%

6. Standard 2000W 80-90%

7. Standard 2000W 80-90%

8. Standard 2000W 80-90%

9. Standard 2000W 80-90%

10. Standard 2000W 80-90%

11. Standard 2000W 80-90%

12. Standard 2000W 80-90%

13. Standard 2000W 80-90%

14. Standard 2000W 80-90%

15. Standard 2000W 80-90%

16. Standard 2000W 80-90%

17. Standard 2000W 80-90%

18. Standard 2000W 80-90%

19. Standard 2000W 80-90%

20. Standard 2000W 80-90%

21. Standard 2000W 80-90%

22. Standard 2000W 80-90%

23. Standard 2000W 80-90%

24. Standard 2000W 80-90%

25. Standard 2000W 80-90%

26. Standard 2000W 80-90%

27. Standard 2000W 80-90%

28. Standard 2000W 80-90%

29. Standard 2000W 80-90%

30. Standard 2000W 80-90%

31. Standard 2000W 80-90%

32. Standard 2000W 80-90%

33. Standard 2000W 80-90%

34. Standard 2000W 80-90%

35. Standard 2000W 80-90%

36. Standard 2000W 80-90%

37. Standard 2000W 80-90%

38. Standard 2000W 80-90%

39. Standard 2000W 80-90%

40. Standard 2000W 80-90%

41. Standard 2000W 80-90%

42. Standard 2000W 80-90%

43. Standard 2000W 80-90%

44. Standard 2000W 80-90%

45. Standard 2000W 80-90%

46. Standard 2000W 80-90%

47. Standard 2000W 80-90%

48. Standard 2000W 80-90%

49. Standard 2000W 80-90%

50. Standard 2000W 80-90%

51. Standard 2000W 80-90%

52. Standard 2000W 80-90%

53. Standard 2000W 80-90%

54. Standard 2000W 80-90%

55. Standard 2000W 80-90%

56. Standard 2000W 80-90%

57. Standard 2000W 80-90%

58. Standard 2000W 80-90%

59. Standard 2000W 80-90%

60. Standard 2000W 80-90%

61. Standard 2000W 80-90%

62. Standard 2000W 80-90%

63. Standard 2000W 80-90%

64. Standard 2000W 80-90%

65. Standard 2000W 80-90%

66. Standard 2000W 80-90%

67. Standard 2000W 80-90%

68. Standard 2000W 80-90%

69. Standard 2000W 80-90%

70. Standard 2000W 80-90%

71. Standard 2000W 80-90%

72. Standard 2000W 80-90%

73. Standard 2000W 80-90%

74. Standard 2000W 80-90%

75. Standard 2000W 80-90%

76. Standard 2000W 80-90%

77. Standard 2000W 80-90%

78. Standard 2000W 80-90%

79. Standard 2000W 80-90%

80. Standard 2000W 80-90%

81. Standard 2000W 80-90%

82. Standard 2000W 80-90%

83. Standard 2000W 80-90%

84. Standard 2000W 80-90%

85. Standard 2000W 80-90%

86. Standard 2000W 80-90%

87. Standard 2000W 80-90%

88. Standard 2000W 80-90%

89. Standard 2000W 80-90%

90. Standard 2000W 80-90%

91. Standard 2000W 80-90%

92. Standard 2000W 80-90%

93. Standard 2000W 80-90%

94. Standard 2000W 80-90%

95. Standard 2000W 80-90%

96. Standard 2000W 80-90%

97. Standard 2000W 80-90%

98. Standard 2000W 80-90%

99. Standard 2000W 80-90%

100. Standard 2000W 80-90%

101. Standard 2000W 80-90%

102. Standard 2000W 80-90%

103. Standard 2000W 80-90%

104. Standard 2000W 80-90%

105. Standard 2000W 80-90%

106. Standard 2000W 80-90%

107. Standard 2000W 80-90%

108. Standard 2000W 80-90%

109. Standard 2000W 80-90%

110. Standard 2000W 80-90%

111. Standard 2000W 80-90%

112. Standard 2000W 80-90%

113. Standard 2000W 80-90%

114. Standard 2000W 80-90%

115. Standard 2000W 80-90%

116. Standard 2000W 80-90%

117. Standard 2000W 80-90%

118. Standard 2000W 80-90%

119. Standard 2000W 80-90%

120. Standard 2000W 80-90%

121. Standard 2000W 80-90%

122. Standard 2000W 80-90%

123. Standard 2000W 80-90%

124. Standard 2000W 80-90%

125. Standard 2000W 80-90%

126. Standard 2000W 80-90%

127. Standard 2000W 80-90%

128. Standard 2000W 80-90%



## High-Ray Industrial Lighting


### ORDERING SEQUENCE

CATALOG NUMBER      VOLTAGE      OPTIONS (factory installed)

--	--	--

- TE 200S E17N      120      Shipped Installed In Fixture
- TE 200S E17C      208      • SF      Single Fuse (120-277V) inc 75
- TE 200S E17M      240      • DF      Double Fuse (208-240-480V) inc 75
- TE 200S E17S      277      • EC      Emergency Cutout (amps not included)
- TE 200S E17W      480      • ODS      Guard Protection System (amps not included)
- TE 200S E17W      707      • ODS-TD      ODS Time Delay (amps not included)
- • Narrow
- • Concentrating
- • Medium
- • Standard
- • Wide

• • Narrow  
• • Concentrating  
• • Medium  
• • Standard  
• • Wide



DISTR	SAHN
E17N	1.79
E17C	1.17
E17M	1.37
E17S	1.34
E17W	1.63

WEIGHT: 22.05 lbs/10kg.

#### NOTES:

- Lamp also be ordered w/ 5', 10', 15' cord lengths
- Must be shipped (120-220-240-277V)
- Quartz lamp requires 100% reflector  
100% damage insured
- May be ordered as accessory MLE-57  
see Industrial Accessories Sp. Cat. for  
ordering information
- 15' cable to connect fixture to  
reflectors supplied
- UL listed standard 480V
- May change structures  
as necessary
- Not available w/ 480V


Fixture Type:

**TE**

### HIGH PRESSURE SODIUM

### 200W ENCLOSED

15' to 20' Mounting



#### SPECIFICATIONS

**HOUSING** - Rugged, lightweight, die-cast aluminum with dark bronze polyester powder finish. Electrical components are secured horizontally and heat-sinked to ballast housing for cooler operation.

**BALLAST** - High power factor constant wattage autotransformer. 180° class K silicon system.

**OPTICS** - One piece totally enclosed ar登isked Arc-Tek® spun aluminum, ar reflector combines high efficiency with tensioned shielding angle for high output, optical control. Exclusive tubing design minimizes arc tube vibration and guards clear tempered glass lens against the entrance of ambient contaminants.

**INSTALLATION** - Permanent splice box (for 3/4" conduit (standard)). Complete mounting options and accessories available.

**LISTING** - UL 1572 listed for camp loc and -30°C to 55°C ambient operation. location listing option available.

**SOCKET** - Porcelain, vertically oriented base socket with copper shay metal screw shell and center contact UL has "SOYH-GOOLY"

#### ACCESSORIES (This model)

(order by separate line item)


SAHN	Baseplate
MLE	Fixture Mount - Female
LPP	Fixture Latch - Female



**LITHONIA**  
**HI-TEK**  
INDUSTRIAL OUTDOOR LIGHTING SYSTEMS, INC.

## PHOTOMETRIC DATA

The charts below present the most useful data from specific photometric tests of the specific light sources and distribution patterns shown. For other results of any combination shown, or other requirements, contact your LITHONIA representative.



INDUSTRIAL OUTDOOR LIGHTING

300-1300W HPS/MH PAR30/40/50/60/80/100/120/150/200/250/300

PAGE 3-21

## High-Bay Industrial Lighting

### ORDERING SEQUENCE

CATALOG NUMBER	VOLTAGE	OPTIONS (factory installed)

- TE 250 S E17N       120      Shipped assembled in fixture
- TE 250 S E17C       208      Single Fuse (120/277V) no TR
- TE 250 S E17M       240      Double Fuse (208/240/400V) no TR
- TE 250 S E17S       277      Emergency Circuit (fuses not included)
- TE 250 S E17W       400      Dual Reserve System (fuses not included)
- TE 250 S E17T       717      GRS Time Delay (fuses not included)
- MA      65°C Ambient Operation
- CR      Corrosion Resistant Finish (optional)
- CAT      European Resistant Finish (option)
- TEF      Teflon Finished Reflector
- TDD      Thru-Wire Ductel Box
- TDPB      Thru-Wire Ductel Box Plug-in
- PDPB      Pendant Box Plug-in
- LCPP      Loop Cord & Plug for TRW & PPM
- LCPTP      Loop: 3' Cord & 1/2A NEMA-T-Male Plug  
Hook: 3' Cord & 1/2A NEMA-T-Male Plug
- LACA      Loop: 3' Cord & Male RCA Connector
- HACA      Hook: 3' Cord & Male RCA Connector
- LUCP      Loop Cord and Plug for UPW
- LUCPSF      LUCP w/Single Fuse (dead front) no TR
- LUCPDW      LUCP w/Double Fuse (dead front) no TR
- VCP      Universal Cable & Plug for UPW
- UCSP      UCP w/Single Fuse (dead front)
- UCPDW      UCP w/Double Fuse (dead front)
- TR      Remote Baseplate
- TRCPST      TR w/Pre-Wired Cables
- WL      Wet Location UL Listed
- CTGP      Casting 273 Panora Tempered Glass Lens
- SSX      Stainless Steel Screws
- SLR      Standard Sure-Lens Rings
- UP      UP Light
- CP      Charcoal Filter
- MARB      Magnetic Proprietary Ballast

#### Shipped Separately \*

- HEP      Fixture Head - Male
- HEMP      Grounded Fixture Head - Male
- LPK      Fixture Lamp - Male
- LPKG      Grounded Fixture Lamp - Male
- TRWP      Thru-Wire Power - Male
- PPM      Pendant Power Head
- UPW      Universal Power Module
- UPKII      UPW Adapter Plate
- UPKIII      UPW Mounting Base
- UPKIV      UPW without Adapter Plate & Mounting Base
- WG      Wire Guard/Aluminum Reflector
- LG      Louver Guard
- CBT      Cylinder Guard
- SBR      Sconce Guard
- HSG      Hexagonal Guard

#### ACCESSORIES (Field Installed)

(Input to separate part number)

- | Cat No. | Description           |
|---------|-----------------------|
| HEP     | Fixture Head - Female |
| LPP     | Fixture Lamp - Female |
| CPW     | Power Cables          |

WEIGHT 250LBS/110kg.

#### NOTES:

- \* May also be ordered with 5', 10', 15', 20' or 25' cord.
  - \* Input: 120/208/240/400V 242/277V
  - \* Output: 100% coverage over 10' radius  
at 100 wattage rating
  - \* May be ordered as accessory. MUST  
see Industrial Accessories Sheet for  
ordering information.
  - \* 15' cable to connect fixture to  
remote ballast
  - \* 20' and 25' cable 400V
  - \* May change distribution  
Cord or 'G' socket.
  - \* Not available in WL option
- For complete description & application

Fixture Type

TE

HIGH PRESSURE SODIUM  
250W ENCLOSED  
18' to 25' Mounting



#### SPECIFICATIONS

**HOUSING** • Rugged, lightweight die-cast aluminum with dark bronze polyester powder finish. Electrical components are opposed horizontally and heat-sinked to ballast housing for cooler operation.

**BALLAST** • High power factor. Constant voltage autotransformer. 100% class K insulation system.

**OPTICS** • One piece totally enclosed and gasketed Arc-Tet II spun alum. lamp, smooth reflector combines high efficiency with extended shielding angle for high performance optical control. Exclusive fluting design minimizes arc tube voltage rise. Gasketed clear tempered glass lens protects the entrance of ambient contaminants.

**INSTALLATION** • Pendant: splice box threads for 3/4" conductors (standard). Complete line of mounting options and accessories available.

**LISTING** • UL 1572 listed for damp location and -30°C to 55°C ambient operation. UL wet location listed option available.

**ROCKET** • Porcelain vertically oriented no base socket with copper alloy socket plates. Screw shell and center contact. UL listed 1500W - 500V.

  
**LITHONIA**  
**HI-TEK**  
INDUSTRIAL INDUSTRIAL LIGHTING  
• Systems • Structures • Controls

## PHOTOMETRIC DATA

The charts below provide the most useful data from specific photometric tests of the spot height source and distribution patterns shown. For complete results of any combination shown or other requirements, contact your MELTEK ILLUMINATING representative.

## ELECTRICAL CHARACTERISTICS



Digitized by srujanika@gmail.com


[View all posts by admin](#) | [View all posts in category](#)

## High-Bay Industrial Lighting ORDERING SEQUENCE

### CATALOG NUMBER      VOLTAGE      OPTIONS (Factory Installed)

<input checked="" type="checkbox"/> TE 400S E22W	<input checked="" type="checkbox"/> 120	Shipped Installed in Fixture
<input type="checkbox"/> TE 400S E22C	<input type="checkbox"/> 240	<input type="checkbox"/> SF Single Fuse (120,240,277V); n/a T8
<input type="checkbox"/> TE 400S E17M	<input type="checkbox"/> 240	<input type="checkbox"/> DF Double Fuse (230,240,480V); n/a T8
<input type="checkbox"/> TE 400S E17S	<input type="checkbox"/> 277	<input type="checkbox"/> EC Emergency Circuit (name not included)
<input type="checkbox"/> TE 400S E17W	<input type="checkbox"/> 480	<input type="checkbox"/> ORS <sup>1</sup> Quartz Reflector System (lamps not included)
	<input type="checkbox"/> TIP	<input type="checkbox"/> QRS <sup>1</sup> Quartz Reflector System (lamps not included)

S = Narrow  
C = Concentrating  
M = Medium  
S = Spread  
W = Widespread



DIA IN.	SHN
E22W	0.8
E22C	1.1
E17M	1.25
E17S	1.5
E17W	1.9

Weight E22: 67 lbs/19 kg  
E17: 39.5 lbs/18 kg

#### NOTES:


- May also be ordered with 3', 12', 15', 20' cord.
- Multi-Tap Ballast (120,240,277V).
- Quartz lamp voltage not to exceed 300W wattage rating.
- May be ordered as accessory. MUST SEE INDUSTRIAL ACCESSORIES SHEET FOR ORDERING INFORMATION.
- 38' cable is connected to fixture to remote ballast.
- 20 amp standard 480V
- No change ballast or  
control factory
- Not UL listed or CSA

For complete description & application information, see Options & Accessories Sheet I-O-A.

Fixture T-800.

# TE

## HIGH PRESSURE SODIUM 400W ENCLOSED 20' to 30' Mounting



#### SPECIFICATIONS

**HOUSING** - Rugged, lightweight, die-cast aluminum with cast bronze polyester powder finish. Electrical components are deposited horizontally and heat-sunk to fixture housing for cooler operation.

**BALLAST** - High power factor Constant voltage autotransformer, 180° class H insulation system.

**OPTICS** - One piece totally enclosed and gasketed arc Tek II spun aluminum. 2000 hr reflector combines high efficiency with extended shielding angle for high performance optical control. Exclusive flaring design minimizes arc tube voltage rise. Gasketed cast tempered glass lens inhibits the entrance of ambient contaminants.

**INSTALLATION** - Pendant splice box (thread for 3/4" conduit (standard)). Complete line of mounting hardware and accessories available.






**LIGHTING** - UL 1572 listed for damp location and -20°C to 55°C ambient operation. UL 1 location label option available.

**SOCKET** - Porcelain, vertically oriented single socket with center alloy nickel plated screw shell and center contact. UL listed 150CW - 600V.

 **LITHONIA  
HI-TEK**  
INDUSTRIAL SURFACE 100-400  
120-240-480V 50-60Hz

## PHOTOMETRIC DATA

The charts below provide the most useful data from specific photometric tests of the specific light source and distribution patterns shown. For complete results of any combination shown, or other requirements, contact your LITHONIA representative.



WATTAGE CAPACITY	AMPERES	VOLTS	AMPS	VOLTS	AMPS	VOLTS
100	2.95	120	100	120	85	120
200	5.90	120	100	120	170	120
300	8.85	120	100	120	250	120
400	11.80	120	100	120	325	120

Based on 100 and 200 watt lamps under standard laboratory conditions. Actual operating times will differ due to different ambient temperatures and design load considerations. Dimensions and performance at the operating voltages based on the mean center wavelength value and are subject to change.

LITHONIA  
HI-TEK  
INDUSTRIAL OUTDOOR LIGHTING  
2000 South 44th Street • Milwaukee, WI 53211 • 414-784-3628  
800-343-2384 • FAX: 414-784-3624

NRG®-300 Series

# PERIMALUX

Hubbell Lighting's PERIMALUX® Series is the ultimate in low wattage wall mount luminaires. It combines aesthetics and functional lighting in a compact, energy-efficient luminaire designed for today's marketplace.

With an all polycarbonate housing and lens assembly, the Perimalux lighting fixture provides beauty and vandal resistance for safety and security lighting. Its unique optical design provides excellent uniform illumination at mounting heights of 6 - 12 feet with a spacing-to-mounting height ratio of 6 : 10 : 1 when utilizing a 50 or 70 watt high pressure sodium lamp, and a 4 : 10 : 1 ratio when using a 26-watt fluorescent lamp. This luminaire is the ideal energy efficient answer for both new construction or retrofitting incandescent luminaires. For areas where an instant-on fixture is required for only short burning hours, the Perimalux luminaire is once again the answer with lamp wattages up to 60 watt incandescent.

The Perimalux series is available with your choice of either bronze polycarbonate or woodgrain finish. The woodgrain finish is a state-of-the-art process which allows the user a more decorative approach.

Additionally, Hubbell Lighting's Perimalux series provides the first of its kind fluorescent cold weather starting with the new 26 watt Quad lamp. This luminaire is ideal for areas requiring high lighting levels with an instant-on cool white fluorescent source.

#### Features:

**Housing** — One-piece, injection molded bronze polycarbonate permanent casting with knurled thumbs. Two point mounting prevents luminaire rotation.

**Reflector** — Internal reflector is vacuum metallized aluminum with a white protective coating which provides a minimum of 85% reflectivity and 80% specularity. Seventy-watt HPS model features a white Lektronolex finish for low brightness and excellent uniformity.

**Reflector** — UV stabilized ultraviolet polycarbonate provides low brightness and high spacing-to-mounting height (8:10:6, 6:10:1 for 50 and 70 watt HPS, 4:10:1 for 26 watt fluorescent). This unique design摒ounces the light 180° sideways while directing the light 13° below horizontal for reduced glare.

**Lamp** — 425 factory related 8.17 clear medium base E26. Fluorescent includes Quad lamps.

**Ballast** — HPS Cans "H" ratings: power factor reader, 40°F starting 60 Hz. Quad Fluorescent: 4:10:89 form factor reader, 20°F to 30°F starting.



**Vandal Resistant Set Screw** — Reflector and reflector arms from 1970's.

**Woodgrain Finish** — Woodgrain finish is available on selected units. Simulated wood finish is specifically bonded to the housing unit using the most current high technology processes.

**Other Features** — UL listed available for wet locations. Easily converts over standard four inch, 10-1/2" junction box accessibility surface conduit mounting box. Optional photocell and weather gasketing. 500' for indoor or outdoor applications.

## Ordering Information

Catalog Number	Watts	Voltages	Power Type	Watts	Watts
<b>HIGH PRESSURE SODIUM</b>					
HPS-301*	70	120	Resist. HPS	3	100
HPS-304*	50	120	Resist. HPS	6	120
<b>FLUORESCENT</b>					
HPS-360-4**	36	120	4-WLAC HPS	3.6	115
<b>INCANDESCENT</b>					
HPS-360	50 Watts	120	-	22	10

\*Voltage factor: 1.05-1.17. See VOLTAGE FACTOR.  
\*\*Includes fixture.

## Options

The following fixtures, which will fit one of the HPS-300 series, may be ordered by adding suffix:

Suffix	Description
-PC	Enclosed Burner Type (22 volt)
-AC	Decatron timer

Options 300 or 360 Series  
Options 300 or 360 Series

## Accessory

For the full-size unit HPS-100 Series. Order separately.

Catalog Number	Description	Watts
HPS-83	Cast aluminum fixture contains mounting base with four 1/2" bases plus one three stage dimmer, AC has a bronze leather strap	2 1/2
		1
		1


## Operating Characteristics

Catalog Number	Input Watts*	Input Volts	Input Amperes		Power Factor
			Starting	Operating	
HPS-301	60	120	1.82	1.18	0.62
HPS-360-4	36	120	1.04	0.70	0.66
HPS-360	50	120	0.98	0.60	0.63


\*Input Watts = Input Volts x Operating Amps x Power Factor

## Dimensions

### Parabolic (Optional)\*



Fluorescent



# LUMASQUARE® I

## NRG™-400 SERIES

- Compact, Energy-Efficient Luminaire
- Aesthetic Appearance
- Safety, Security, Architectural Lighting

Hubbell's Lumasquare® luminaire is a compact canopy ceiling mount fixture designed for new construction or retrofitting at 8-12 foot mounting heights. Available in 50w HPS, 26w fluorescent, or incandescent. Lumasquare I is ideal for indoor or outdoor applications such as lobbies, stairways, hallways, corridors, walkways and underpasses.

Housing — One-piece injection molded opaque polycarbonate. Permanent color with textured finish.

Reflector — Unique prismatic polycarbonate provides low brightness and uniform distribution.


Reflector — HPS, one-piece hydroformed aluminum with ANODALE® finish for optimum performance. Reflector eliminates glare by shielding the arc tube from normal viewing angles. Fluorescent and incandescent aluminum with white EKTRACOTE® finish.

Lamp — HPS: clear 50w medium base lamp is furnished. Fluorescent: two twin tube lamps are furnished. Incandescent requires two T-10, 40w (maximum) lamps (not included).




Ballast — HPS: 120 volt NPF® or HPF reactor, or 277 volt HPF reactor/autotransformer combination. 40w starting 60 Hz. Fluorescent: two 120 volt, or two 277 volt preheat NPF reactor 60 Hz (30 ms. available contact factory).

Performance — IES Type I "short cut" distribution.

Additional Features — concealed latching; tamper-resistant set screws available. Quick and easy to "size" two point mounting. UL 1570, 1571 and 1572 listed suitable for damp locations.



### DIMENSIONS



Lighting

PAGE 3-287

## WIRING INFORMATION

Op. Amp Number	Watts	Voltage	Bursts	Weight	Watts	Weight
	Watts	Volts		lbs.	Watts	lbs.
<b>HIGH PRESSURE SODIUM</b>						
NRC-401	50	125	None	1	50	1
FLUORESCENT						
NRC-406-2	26	125	Periodic	1	3	0.3
INCANDESCENT						
NRC-406	85 (max)	125	-	1	6	0.3

**OPTIONS** The following factory applied options are available. Order with the fixture by adding the appropriate suffix:

Option	Description
-277	277 volt transformer HPS or Fluorescent
-310	High power factor circuit for HPS

## ACCESSORIES

Field installation with NRC-400 Series. Order separately.

Catalog Number	Description	Weight
		lbs.
3-310-3	1" cast aluminum flange adapter for surface mount mounting with two mounting holes. Four 1" mounting holes are also slugs	1
NRC-4-TR	"TOTAL" luminaire fixture 17-1/2" width and 5" height	6


\*TOTAL is a registered trademark of Testron, Inc.

### Footcandle Array Diagram

#### NRC-401, 50 Watt High Pressure Sodium

Footcandle Array Based On:

- 10' Mounting Height
- 12' Sealing Distance
- No Reflector




### Footcandle Array Diagram

#### NRC-406-2, 26 Watt Fluorescent

Footcandle Array Based On:

- 10' Mounting Height
- no Reflector



## Suggested Specification

Luminaire shall be Hubbell Lighting Division Luminaire I Series, catalog number NRC \_\_\_\_\_ for use with a \_\_\_\_\_ wall \_\_\_\_\_ luminaire.

### MECANICAL

The housing shall be one-piece injection molded sturdy polycarbonate with a recessed base. The primary intent shall be one-piece, injection molded, thermoplastic housing type polycarbonate. The fixture shall have reflector and two double-headed threaded posts held firmly in place to facilitate mounting. The HPS fixture shall be supplied with a standard mounting bracket. The fluorescent and incandescent fixture shall be supplied complete in white luminaire with 125° reflector. The HPS lamp shall be mounted and the reflector so formed the arc will be 10' long from top to bottom. Luminaire shall be luminaire with a 10' HPS medium base lamp of 52 ft. 10" or 60" incandescent lamps. Luminaire NPS: 10" W x 13" D x 13" H overall dimensions.

### ELECTRICAL

The NRC-401-10-10-HPS fixture shall be supplied with 125' 14/3 AWG lighting cord, 60 Hz, 120 VAC. Luminaire shall be supplied with fixture to fixture connection.

Dimensions: 1 short fixture 27" x 10" x 13" fixture 10" x 13" x 13"



Hubbell Lighting Division, 2000 Electric St., Charlottesville, Virginia 22903 • 1-800-382-1111 • FAX: 1-800-382-1126 • Telex: 921-673  
 Hubbell Canada, Inc., 873 Brock Road & Box 100, Pickering, Ontario, L1V 2J3 • FAX: 416-339-1139 • FAX: 416-339-1139 • Telex: 66-367111  
 Harvey Hubbell, Ltd., Port Credit, Mississauga, Ontario, Canada L4X 1P6 • 1-800-382-1126 • FAX: 1-800-382-1126

©1989 Hubbell, Inc.

Printed in USA

## 4 PROJECT II: LIGHTING CONTROLS AT AIRFIELD

5154 SEAP LIGHTING ENERGY STAR FT Campbell KY

This section contains the Project Development Brochures and the DD 1391 Forms for Project II, Lighting Controls at Airfield. Following the DD 1391 Forms is a project summary table, the life cycle cost analysis for the project, and the calculations and cost estimates for each building included in the report. Please note the total cost for the project of \$60,078. The project does not meet the \$300,000 cut off for ECIP funding. However, the project has a very good SIR of 5.21 and a simple payback of 2.29 years. The project should be an excellent candidate for FEMP funding and was therefore not grouped in with a larger project with poorer economic results. Below is a detailed index of the information included in this section.

PDBs	4-2
DD 1391 Forms	4-18
Table 4-1: Project Summary - Lighting Controls at Airfield	26
LCCA for Total Project	4-27
 <u>Building</u>	 <u>Page</u>
7152	4-28
7154	4-33
7156	4-33
7205	4-43
7208	4-48
7210	4-53
7214	4-58
7218	4-63
7243	4-68
7245	4-73
7249	5-78
7262	4-83
7264	4-88
7268	4-93
7272	4-94
 Catalog Cut Sheets	 4-103

# **facility**

LIGHTING CONTROLS AT CAMPBELL ARMY AIRFIELD  
Fort Campbell, Kentucky

## **project coordinator for using service**

Arlin Wright

**functional requirements summary, PDB-1**

4-2

DA FORM 5020-1, 7-62

TM 5-300-3 A-7

**OBJECTIVE:**


The objective of this project is to install daylight sensing on/off photocell controls in hangars at Campbell Army Airfield. The installation of these controls will reduce energy consumption and life cycle operating costs for the buildings at the Airfield in accordance with the Army Energy Resources Management Plan (ERMP) and Executive Order 12759.

**functional requirements summary, PDB-1**

4-3

DA FORM 5020-2-A, Feb 82

TM 5-830-3 A-6



facilities requirements sketch, PDB- 1/2

DA FORM 6022-R, Feb 82

TAB S-600-3 A-21

4-4

TM 3-800-3

APPENDIX C  
DOCUMENTATION CHECKLIST

C-1  
4-5

## A. SPECIAL CONSIDERATIONS

	ITEM			
	R	Y	C	I
A-1	R			
A-2	Y			
A-3				
A-4	R			
A-5	NR			
A-6	R			
A-7	NR			
A-8				
A-9	NR			
A-10	NR			
A-11	R			
A-12	Y			
	R			
Other Federal Considerations (List and number items)				
1. See Appendix A				
<b>REQUIRED OR NOT REQUIRED</b> = Not relevant or no information to be furnished. Enter "R" if item is relevant and is required for this project. Enter "NR" if item is relevant and is not required for this project.				
<b>TO BE DETERMINED</b> = Information needed but not currently available. Enter code for information source.				
<b>COMMENT ATTACHED</b> = Significant information summarized or detailed in source.				
<b>DOCUMENT ATTACHED</b> = Significant information is in an attached document which is detailed.				
<b>* BY WHOM ISSUED AND WHAT APPROVALS TAKEN</b>				
A = DPAE B = Living Service C = Construction Service D = Designer E = Other (Check Comments Attached for additional)				

## documentation checklist

DA FORM 5023-A.R, FEB 82

TM 5-800-3 C-8

## B. SITE DEVELOPMENT

### ITEM

ITEM	DESCRIPTION	TYPE	SIZE	SIZE	SIZE
		1	2	3	4
8-1	Communication with the District Office in performing site development plan review				
8-2	Preparation, submission, and/or approval of noo				
(A)	General Site Plan				
(B)	Annotated General Site Plan				
(C)	Sketch Site Plan				
(D)	Facilities Requirements Sketch				
8-3	Preparation of				
(A)	Site Survey				
(B)	Support Information				
8-4	Approval by Department of Defense Explosive Safety Board (DDESB) for Safety Site Plan				
	OTHER SITE DEVELOPMENT CONSIDERATIONS (LIST AND NUMBER ITEMS)				
	1. See Project Development Brochure, PDS-1/2				

REQUIRED OR NOT REQUIRED - Not relevant or no information to form-maintain. Enter "NR" if item is relevant but it is required for the project. Enter "R" if item is relevant and is not required for the project.

TO BE DETERMINED - Information needed but not currently probable. Enter code for information source.

COMMENT ATTACHED - Significant information summarized or explained and attached.

DOCUMENT ATTACHED - Significant information is in an existing document maintained elsewhere.

\*BY whom (check and initial appropriate action)

- A - DPAE
- B - Utility Service
- C - Construction Service
- D - Designer
- E - Other (Check comments attached and initial)

## documentation checklist

4-7

DA FORM 5023-B-R, Feb 62

TAB 5-800-3 C-7

## C. ARCHITECTURAL & STRUCTURAL

17

C-1	Recognition with local routing programs and requirements
C-2	Evaluation of existing facilities (including degree of utilization)
C-3	Algorithm for removal and relocation of existing unusable facilities
C-4	Evaluation of off-base community facilities
C-5	Storage and maintenance facilities (including number and types)
C-6	Coordination negotiations medical and dental facilities with European Comptroller
C-7	Coordination of liaison facilities with USAF
C-8	Coordination on traffic control and navigation signs with USACC
C-9	Totalization of types and numbers of aircraft
C-10	Evaluation of laboratories, research and development, and technical maintenance facilities
C-11	Coordination changes with Chief of Chaplains
C-12	Review local service facilities by USATSA
C-13	Automatic data processing system of equipment acquisition costs and via other ADP and/or communication channels not correlated with existing terminals
C-14	Coordination on postal facilities with U.S. Postal Service Response Director
C-15	Boundary and city zoning activities coordination with AS21661
C-16	Tenant facilities coordination with installation where sites
C-17	Facilities for air warfare ie explosives, toxic chemicals, or ammunition review by DD288 Item 8(a) and Item 8(d)
C-18	Analysis of deficiencies
C-19	Consideration of alternatives
C-20	Determination whether structures will become physically handicapped or destroyed during
C-21	Air base drawings for structures or additions
C-22	Availability of Standard Design or site acceptable designs
Other Architecture & Structural Sheet and Number Items:	
1.	See Supplemental Data Detailed Project Justification Paragraphs D3.
2.	See Supplemental Data Detailed Project Justification Paragraph D4.

Number of Non-Playing Personnel	Rate Determination	Current Allowing	Temporary Allowing
NR	D	-	-
NF		-	-
NS		-	-
NR		-	-
R	D	-	1
R	D	-	2
NR		-	-
R	C	-	-
NR		-	-

**REQUISITED OR ADVICE REQUIRED** - List required or no information to be furnished. Entry "R" is item of relevance and is required for this subject.  
Entry "NR" is item of relevance and is not required for this subject.

**TO BE DETERMINED** - Information needed but not currently available.  
Enter code for information source

**COMMENT ATTACHED** - Significant information summarizing an attached document.

**DOCUMENT ATTACHED** - Significant information is in an attached document.

G = General  
 C = Customer  
 S = Service  
 E = Employee  
 L = Other (Cross Company Attending and  
 visiting)

## **documentation checklist**

DA FORM 5023-C.R., FEB 62

TNI S-880-3 C-9

## D. MECHANICAL, ELECTRICAL & UTILITY SYSTEMS

ITEM		R equired	D etermined	C ommented	D ocument Attached
D-1	Fuel configuration and cost comparison analysis				
D-2	Energy requirements approved by DRA:				
D-3	Conformance with DOD Energy Regulation requirements				
D-4	Evaluation of existing and/or proposed utility systems				
Other Mechanical and Utility Systems (List one number item)					
1. See Special Requirements, Paragraph 3 (SRF-3)					

**REQUIRED OR NOT REQUIRED** = Not relevant or no information is committal. Enter "R" if item is relevant and it required for the project.  
Enter "NR" if item is immaterial and is not required for the project.

**TO BE DETERMINED** = Information known but not currently definitive.  
Enter code for information source.

**COMMENT ATTACHED** = Significant information summarized or explained  
and attached.

**DOCUMENT ATTACHED** = Significant information is in or entries document  
and attached.

**BY WHOM** (Check and initial appropriate items)

- A - DRA
- B - Using Service
- C - Construction Service
- D - Designer
- E - Other (Check Comments Attached and  
initial)

## documentation checklist

DA FORM 5020-10-1, Feb 82

b-9

TM 5-300-3 C-11

## E. ENVIRONMENTAL CONSIDERATIONS

ITEM		Y E R 1 9 8 7	Y E R 2 9 8 8	Y E R 3 9 8 9	Y E R 4 9 9 0
E-1	Environmental impact statement				
E-2	EIA conclusions require Environmental Impact Statement				
E-3	Determination of health environmental or related hazards. Assessment is determined evidence of an known environmental or related hazard may be required from whom ever been Pickering Group 105 CICIC, the Office of the Surgeon General and DASG-MCH (Army Environmental Hygiene Agency).				
E-4	Air/water Pollution permit; registration with agency and compliance with standards at Federal, state and local level				
E-5	Corrective measures associated with Environmental Impact Statements or management-related activities and evaluate				
Other environmental considerations listed on other items					
1. See Supplemental Data Detailed Project Justification or Paragraph 59.					

**REQUIRED OR NOT REQUIRED** - Are required items indicated in the column below. Enter "Y" if item is required and "N" if optional. Enter "NA" if item is not applicable and is not required for this contract.

TO BE DETERMINED - Information needed but not currently available  
Information for informed decision

COMMENT ATTACHED TO BUDGETARY INFORMATION SUBMITTED AT CANDIDATE

**THE CHURCH.**

DOCUMENT ATTACHED - Significant information or in existing files

APPROPRIATE EXPENSES

• BY KARINA. CANAL DE LOS MISTERIOS

**A = BIAE**  
**B = Legal Services**  
**C = Construction Services**  
**D = Design**  
**E = Other IChECC Comms**

# documentation checklist

DA FORM 5G-2-E.R. FEB 82

4-10

TMI 3-8100-3 C-13

TM S-800-3

**APPENDIX D  
TECHNICAL DATA CHECKLIST**

8-1  
4-11

## A. SPECIAL CONSIDERATIONS

"EN"

A.1	Section A.1A: Description of unusual or nonstandard equipment in material class 1 and non-classified equipment.
A.2	Construction drawing requirements.
A.3	Functional support equipment (mechanical, electrical, structural) and security of built-in equipment in design and justification.
A.4	Other equipment and furniture (DEPA, CMA) and costs.
A.5	Special studies and tests (radiation analysis, compatibility testing, new technology testing, etc.)
A.7	Type of shelter: "Temporary temporary semi-permanent."
A.8	Government equipment requirements, procurement time availability, and special handling and storage requirements. Plans used for procurement.
	Other special considerations (list one number items)

TO TYPE CODE	• S E C H O D E	• T R U M P R E P E	• T R U M P R E P E
NE			
E			
N1			
N2			
N3			
NP			
ND			
NE			

REQUIRED OR NOT REQUIRED = Not relevant or no information to LOM  
Required. Enter "R". Item is relevant and is required for this project.  
Enter "NR" if item is relevant and is not required for this project.  
TO BE DETERMINED = Information needed but not currently available  
Enter code for information source.

COMMENT ATTACHED = Significant information summarized or explained  
and attached.

DOCUMENT ATTACHED = Significant information is in an existing DA  
form which is attached.

REMARKS (Check one letter for each line item)

A - DEAE  
B - Using Existing  
C - Construction Source  
D - Designer  
E - Other (Check Common Attached and  
Report)

## technical data checklist

4-12

DA FORM 5024-A.R., Feb 82

TM 5-8100-3 D-3

## B. SITE DEVELOPMENT

ITEV	
8-1	Construction restrictions or guidelines pertaining to site access and preferred construction routes
(A)	
(B)	Airfield clearance, explosive storage, working hours, safety, etc.
(C)	Facilities and/or functions or adjoining areas (structures, materials, impact)
8-2	Real estate actions (acquisition, disposal, lease, right-of-way)
8-3	Demolition/relocation restrictions (total)
(A)	Social considerations due to explosives, radioactivity, chemical contamination, asbestos, amosite and toxic gases
(B)	Restrictions on disposal of demolished/relocated material including hazardous waste
8-4	Pavement types and requirements (including traffic surveys and MTMC coordination)
8-5	Landscape considerations
(A)	Protection of existing vegetation
(B)	Soil/soil topsoil
	Other Site Development (List and number items)

Planning or Not Required	To Site	Site Development	Comments Attached	Comments Attached
R	A			
R	A			
A	A			
NR				
R	A			
NR				

REQUIRED OR NOT REQUIRED - Enter relevant or no information to column  
numbers. Enter "R" if item is relevant and is required for the project.  
Enter "NR" if item is irrelevant and is not required for this project.

TO BE DETERMINED - Information needed but not currently available.  
Enter code for information source.

COMMENT ATTACHED - Significant information summarized or detailed  
in attached document.

DOCUMENT ATTACHED - Significant information is in an existing docu-  
ment which is attached.

ITEV NUMBER (Chart and Input Identification Codes)

- A - DVAE
- B - Using Barriers
- C - Construction Barriers
- D - Demolition
- E - Other (Cross Comments Attached and  
explain)

## technical data checklist

4-13

DA FORM 5024-5-R, Feb 82

TAB S-HU-1 D-7

## C. ARCHITECTURAL & STRUCTURAL

ITEM		R	D	NR	Y	T	U
C-1	Vibration-producing equipment requiring isolation						
C-2	Zone(s) and other design load criteria (typhoon, hurricane, earthquake loads, high or low load potential)						
C-3	Protective shelter evaluation and resistant design criteria (conventional/nuclear, steel and reinforced, chemical/biological)						
C-4	Unique foundation requirements (soil, piling, caisson, pile foundations, mat, special treatment, permeable areas, soft bearing)						
C-5	Designation and strength of areas to be accommodated						
C-6	Requirements and data for special design features						
C-7	Unusual floor and roof loads (steel, equipment)						
C-8	Security features (perimeter, revised interior security areas)						
	Other - Architecture & Structural (list one number items)						

REQUIRED OR NOT REQUIRED = Not relevant or no information to comment. Enter "R" if item is relevant and is required for this project. Enter "NR" if item is relevant and is not required for this project.

TO BE DETERMINED = Information needed but not currently available. Enter "D" for information desired.

COMMENT ATTACHED = Significant information summarized or explained in attached document.

DOCUMENT ATTACHED = Significant information is in an attached document.

\* BY WHICH SOURCE AND WHAT INFORMATION REFERRED

- A = DPAE
- B = Using Services
- C = Construction Services
- D = Design
- E = Other (Check each. All others are blank)

## technical data checklist

DA FORM 5024-C.R., Feb 82

4-14

TN 3-5024-3 2-8

## D. MECHANICAL, ELECTRICAL & UTILITY SYSTEMS

D-1	
D-1	Special mechanical requirements or environmental conditions during design phase.
D-2	Special data storage methods and best handling techniques.
D-3	Maintainable configurations (accessibility) of equipment components with existing equipment.
D-4	Piping availability, generic system type and characteristics (existing and/or existing inc. commercial and/or test).
D-5	Heating-availability, generic system type and characteristics (existing and/or existing).
D-6	Ventilating, air conditioning/temperature regulation - generic system type and characteristics (existing and/or existing).
D-7	Electrical/mechanical generic system type and characteristics incl. artificial lighting, communication, etc. (existing and/or existing).
D-8	Water supply/waste treatment availability, generic system type and characteristics (existing and/or existing).
D-9	Energy requirement (fuel conversion required over density, types of fuel, etc.)
D-10	Solar energy production
Other Mechanical & Utility Systems List and number items:	

Type of Information	By whom?	Comments	Date
NR			
NR			
R	C		
NR	D		
SE			
R	D		
NR			
HR			
S	D		
NR			

**REQUIRED OR NOT REQUIRED** = Not required or no information to communicate. Enter "NR". If item is required and is required for the subject later "NR" is seen as irrelevant and is not required for this project.

**TC TO BE DETERMINED** = Information needed but not currently available. Enter code for information source.

**COMMENT ATTACHED** = Significant information summarized or contained in comment.

**DOCUMENT ATTACHED** = Significant information is attached and explained.

\* BY WHICH? (check one or more appropriate entries)

- A = DPAE
- B = Using Service
- C = Construction Service
- D = Computer
- E = Other - Enter Comments Attached and explain

## technical data checklist

2-15

DA FORM 5C24-D-R, FEB 82

T31 S-100-3 0-11

## E. ENVIRONMENTAL CONSIDERATIONS

ITEM		NR.	To Be Determined	Comment Attached	Document Attached
8-1	Waste water treatment, off duty site, one solid waste disposal or waste Other Environmental Considerations (list one numbered item)				

**REQUIRED OR NOT REQUIRED** = Not required or no information is committable. Enter "R" if item is relevant and is required for this project. Enter "NR" if item is irrelevant and it not required for this project.

**TO BE DETERMINED** = Information known but not sufficiently verifiable from local information sources.

**COMMENT ATTACHED** = Significant information communicated or explained via drawing.

**DOCUMENT ATTACHED** = Significant information is in an existing document which is sufficient.

**BY WHOM** (Enter last name and first initial)

- A - Design
- B - Using beams
- C - Construction Service
- D - Design
- E - Other (Leave Comments Attached and explain)

**technical data checklist**

4-16

DA FORM 5024-8-R, Feb 82

TM 5-300-3 D-12

## F. FIRE PROTECTION

ITEM	N.D.	GENERAL REQUIREMENT	STRUCTURAL SUPPORT	WALLS AND CEILINGS	ROOFING
		•	•	•	•
8.1 Other fire protection systems or features, detection and suppression equipment required, etc. Other Fire Protection Considerations (List and number items)					

REQUIRED OR NOT REQUIRED = Not relevant or no information is applicable. Enter "N/A" if item is relevant and is required for the DAF FORM "DA FORM 5" it would be relevant and is not required for this project.

TO BE DETERMINED = Information needed but not currently available. Enter code for information source.

COMMENT ATTACHED = Significant information summarized or explained in document.

DOCUMENT ATTACHED = Significant information is in existing document. Enter code for information source.

\* BY WHO OR (Check one or more appropriate letters)

- A - DOD
- B - Using Services
- C - Construction Services
- D - Designer
- E - Owner (Check Comments Attached and explain)

## technical data checklist

DA FORM 5026-F.R, Feb 62

4-11

TM 5-800-3 0-15

1 COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA			2 DATE 23 September
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky		4 PROJECT TITLE Lighting Controls at Airfield		
5 PROGRAM ELEMENT	6 CATEGORY CODE	7 PROJ. ECT NUMBER ECIP #2	8 PROJECT COST (USD) \$60.08	
9 COST ESTIMATES				
ITEM	UM	QUANTITY	UNIT COST	CO NO
Primary Facility				
Daylight Sensing On/Off Protocol Controls	L01	1	51.77	
Subtotal				
Contingency (10%)				
Total Contract Cost				
Supervision, Inspection and Overhead (5%)				
Total Request				
10. DESCRIPTION OF PROPOSED CONSTRUCTION				
<p>The existing interior lighting is a combination of mercury vapor, metal halide, and high pressure sodium fixtures. The proposed project will install daylight sensing on/off photocell controls on these fixtures. Implementation of this project will save 669,468 MJ/yr of electrical energy. The first year cost savings is \$26,209, the Savings to Investment Ratio (SIR) is 5.21, and the simple payback is 2.29 years.</p>				
11. REQUIREMENT				
<p><b>Project:</b> The proposed project installs daylight sensing on/off photocell controls on the fixtures in the big areas of buildings 7152, 7154, 7156, 7206, 7208, 7210, 7214, 7216, 7243, 7245, 7249, 7262, 7264, 7266, 7272.</p> <p><b>Requirement:</b> The project is required to reduce the energy consumption of lighting and to comply with the Energy Resources Management Plan (ERMP) and Executive Order 12759. The proposed project will reduce annual energy consumption by 669,468 MJ/yr and annual energy cost by \$26,209.</p> <p><b>Current Situation:</b> The existing fixtures in the above listed buildings have no controls to allow energy savings other than manual switches. The lights are not being switched off during peak daylight hours.</p>				

1 COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA	2 DATE 23 September
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky		
4 PROJECT TITLE LIGHTING CONTROLS AT AIRFIELD	5 PROJECT NUMBER ECIP #2	

Impact if not provided: If the proposed project is not funded, a reduction of 669,466 MJ/yr cannot be achieved and excessive amounts of energy will continue to be used. There will be no contribution to energy reduction goals established for United States Army facilities by Army Headquarters.

Cc one: USA  
Commanding

ESTIMATED CONSTRUCTION START	September 1995	IN
ESTIMATED MIDPOINT OF CONSTRUCTION	April 1996	IN
ESTIMATED CONSTRUCTION COMPLETION	November 1996	IN

#### DETAILED JUSTIFICATIONS

##### D1. GENERAL

The proposed project encompasses the installation of daylight sensing on/off photocell controls in the areas of buildings 7152, 7154, 7156, 7208, 7208, 7210, 7214, 7218, 7243, 7245, 7248, 7262, 7264, 7268, 7272. The project will decrease the energy consumption of the lighting systems by taking advantage of available daylight while maintaining required light levels.

##### D2. ACCOMMODATIONS NOW IN USE:

The existing lighting systems are comprised of high intensity discharge fixtures with manual on/off controls.

##### D3. ANALYSIS OF DEFICIENCY:

Currently, the above hangars are using manual switches to control the lighting systems in high bay areas. The purpose of this project is to install automatic daylight sensing photocell controllers which will take advantage of free daylighting available. The current deficiency results in large amounts of energy usage during periods when artificial lighting is not necessary to maintain adequate light levels.

1. COMMISSION	FY 19 84 MILITARY CONSTRUCTION PROJECT DATA	3. DATE
ARMY		23 September 8

2. INSTALLATION AND LOCATION  
Fort Campbell, Kentucky

4. PROJECT TITLE  
LIGHTING CONTROLS AT AIRFIELD

5. PROJECT NUMBER  
ECIP #2

**D4. CONSIDERATION OF ALTERNATIVES:**

The only alternatives to the proposed project are to install more sophisticated automatic control system. These systems would cost significantly more while providing minimal additional energy savings. The proj would have a lower SIR.

**D5. CRITERIA FOR PROPOSED PROJECT:**

The proposed project will conform with all applicable federal and United States Army Regulations.

**D6. PROGRAM FOR RELATED EQUIPMENT:**

No equipment funded from appropriations other than MCA are required.

**D7. DISPOSAL OF PRESENT ASSETS:**

There is no material to be disposed.

**D8. SURVIVAL FACILITIES:**

The proposed project is not suitable for inclusion of protective shelters.

**D9. SUMMARY OF ENVIRONMENTAL CONSEQUENCES:**

The proposed project has been analyzed and will not adversely impact the environment. Energy savings resulting from the project will conserve natural resources.

**D10. EVALUATION OF FLOOD HAZARDS AND ENCROACHMENT ON WETLANDS:**

It has been determined that these facilities are not located in a flood plain and they do not encroach wetlands.

**D11. ECONOMIC JUSTIFICATION:**

The proposed project qualifies under ECIP Guidelines in AR-415-15. SIR for the project is 5.21 with a payback of 2.29 years.

See Economic Analysis, SAP-1

1 COMPONENT ARMY	2 DATE 23 September 94
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky	
4 PROJECT TITLE LIGHTING CONTROLS AT AIRFIELD	5 PROJ. ECT NUMBER ECIP #2

D12. UTILITY AND COMMUNICATION SUPPORT.

- A. No related utility support projects are programmed. Adequate utilities are available to support project.
- B. No telecommunication support is required.

D13. PROTECTION OF HISTORIC PLACES AND ARCHEOLOGICAL SITES:

The project involves the installation of controls in existing buildings. Review procedures have been implemented for this project in accordance with 36 CFR 800. The review has established that there will be no effect.

D14. PROJECT DEVELOPMENT BROCHURE (PART 1):

A Project Development Brochure was prepared on 23 September 94 and is attached as a part of programming documentation.

D15. ENERGY REQUIREMENTS:

The proposed project will reduce present energy consumption by 669,466 MJ/yr at the cost savings of \$26. per year. See Energy Requirements Appraisal (ERA) in Special Requirements, Paragraph 3 (SRP-3).

D16. PROVISION FOR THE HANDICAPPED:

No provisions for the handicapped will be made since the scope of the project is in no way applicable designing for the handicapped.

D17. REAL PROPERTY MAINTENANCE ACTIVITY (RPTA) ANALYSIS:

- A. Physical impact: No new structures will be added. Controls will be connected to existing light fixtures.

1 COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA	2 DATE 23 September 94
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky		
4 PROJECT TITLE LIGHTING CONTROLS AT AIRFIELD	5 PROJECT NUMBER ECIP #2	

B. Operations and Maintenance (O&M) Impact:

YEAR	O&M
	NET CHANGE (\$000)
1994	0
1995	0
1996	0

C. Backlog of Maintenance and Repair (BMAR) Impact:

There will be no net change in the number of fixtures or in fixture life expectancy. There will be no effect on BMAR.

D18. COMMERCIAL ACTIVITIES:

The proposed project is not a "New Start Expansion" as defined by DA Circular 235-1. The project has been reviewed in light of the requirements of commercial and industrial facilities. It has been determined that whereas the project does not affect commercial facilities, the requirements of DA Circular 235-1 does not apply.

1 COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA			2 DATE 23 September 84																																										
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky																																														
4 PROJECT TITLE LIGHTING CONTROLS AT AIRFIELD		5 PROJECT NUMBER ECIP #2																																												
<p><b>Life Cycle Cost Analysis</b>          Project Title: Lighting Controls at Airfield          Fiscal Year: 1994          Analysis Date 09/23/94          Economic Life: Fifteen (.5) Years</p>																																														
<p><b>1 INVESTMENT</b></p> <table> <tbody> <tr> <td>A CONSTRUCTION COST</td> <td>54 818</td> </tr> <tr> <td>B SICH</td> <td>2 731</td> </tr> <tr> <td>C DESIGN COST</td> <td>2 731</td> </tr> <tr> <td>D ENERGY CREDIT CALC</td> <td>-0-</td> </tr> <tr> <td>E SALVAGE VALUE</td> <td>-0-</td> </tr> <tr> <td>F TOTAL INVESTMENT</td> <td>\$80,078</td> </tr> </tbody> </table>					A CONSTRUCTION COST	54 818	B SICH	2 731	C DESIGN COST	2 731	D ENERGY CREDIT CALC	-0-	E SALVAGE VALUE	-0-	F TOTAL INVESTMENT	\$80,078																														
A CONSTRUCTION COST	54 818																																													
B SICH	2 731																																													
C DESIGN COST	2 731																																													
D ENERGY CREDIT CALC	-0-																																													
E SALVAGE VALUE	-0-																																													
F TOTAL INVESTMENT	\$80,078																																													
<p><b>2 ENERGY SAVINGS</b>          ANALYSIS DATE ANNUAL SAVINGS, UNIT COST &amp; DISCOUNTED SAVINGS</p> <table> <thead> <tr> <th>FUEL</th> <th>C. Y<sup>T</sup> \$A<sup>Y</sup> (1)</th> <th>SAVINGS MBW/YR(2)</th> <th>ANNUAL S AVINGS(3)</th> <th>DISCOUNT FACTOR(4)</th> <th>DISCOUNTED SAVINGS(5)</th> </tr> </thead> <tbody> <tr> <td>A. ELECT</td> <td>6.18</td> <td>634</td> <td>3,821</td> <td>12.43</td> <td>48,738</td> </tr> <tr> <td>B. DIST</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>C. RESID</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>D. NG</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>E. DEMAND</td> <td></td> <td></td> <td>22,288</td> <td>11.83</td> <td>264,113</td> </tr> <tr> <td>F. TOTAL</td> <td></td> <td>634</td> <td>26,309</td> <td></td> <td>312,851</td> </tr> </tbody> </table>					FUEL	C. Y <sup>T</sup> \$A <sup>Y</sup> (1)	SAVINGS MBW/YR(2)	ANNUAL S AVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)	A. ELECT	6.18	634	3,821	12.43	48,738	B. DIST						C. RESID						D. NG						E. DEMAND			22,288	11.83	264,113	F. TOTAL		634	26,309		312,851
FUEL	C. Y <sup>T</sup> \$A <sup>Y</sup> (1)	SAVINGS MBW/YR(2)	ANNUAL S AVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)																																									
A. ELECT	6.18	634	3,821	12.43	48,738																																									
B. DIST																																														
C. RESID																																														
D. NG																																														
E. DEMAND			22,288	11.83	264,113																																									
F. TOTAL		634	26,309		312,851																																									
<p><b>3. NON-ENERGY SAVINGS</b></p> <table> <tbody> <tr> <td>A ANNUAL RECURRING (1)DISCOUNT FACTOR (2)DISCOUNTED SAVINGS</td> <td>11.85</td> <td>\$0</td> </tr> <tr> <td>B NON-RECURRING SAVINGS</td> <td></td> <td>\$0</td> </tr> <tr> <td>ITEM</td> <td>SAVINGS (1) YEAR OF COST(-X1) OCCURRENCE (2) FACTOR</td> <td>DISCOUNTED SAVINGS(-) COST (-X4)</td> </tr> <tr> <td>a. Replace interior</td> <td></td> <td></td> </tr> <tr> <td>b. Replace Exterior</td> <td></td> <td></td> </tr> <tr> <td>c.</td> <td></td> <td></td> </tr> <tr> <td>d. Total</td> <td></td> <td></td> </tr> <tr> <td>C. TOTAL NON ENERGY DISCOUNTED SAVINGS (1)/COST(-)</td> <td></td> <td></td> </tr> </tbody> </table>					A ANNUAL RECURRING (1)DISCOUNT FACTOR (2)DISCOUNTED SAVINGS	11.85	\$0	B NON-RECURRING SAVINGS		\$0	ITEM	SAVINGS (1) YEAR OF COST(-X1) OCCURRENCE (2) FACTOR	DISCOUNTED SAVINGS(-) COST (-X4)	a. Replace interior			b. Replace Exterior			c.			d. Total			C. TOTAL NON ENERGY DISCOUNTED SAVINGS (1)/COST(-)																				
A ANNUAL RECURRING (1)DISCOUNT FACTOR (2)DISCOUNTED SAVINGS	11.85	\$0																																												
B NON-RECURRING SAVINGS		\$0																																												
ITEM	SAVINGS (1) YEAR OF COST(-X1) OCCURRENCE (2) FACTOR	DISCOUNTED SAVINGS(-) COST (-X4)																																												
a. Replace interior																																														
b. Replace Exterior																																														
c.																																														
d. Total																																														
C. TOTAL NON ENERGY DISCOUNTED SAVINGS (1)/COST(-)																																														

1. COMPONENT ARMY	FY 19 84 MILITARY CONSTRUCTION PROJECT DATA	2. DATE 23 September 84
3. INSTALLATION AND LOCATION Fort Campbell, Kentucky		
4. PROJECT TITLE LIGHTING CONTROLS AT AIRFIELD	5. PROJECT NUMBER ECIP #2	

SPECIAL REQUIREMENTS PARAGRAPH 1 (SRP-1) (continued)

4. FIRST YEAR DOLLAR SAVINGS	\$ 28.20
5. SIMPLE PAYBACK PERIOD	2.29 Year
6. TOTAL NET DISCOUNTED SAVINGS	\$312.85
7. DISCOUNTED SAVINGS RATIO	.52

1. COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA	2. DATE 23 September 9
3. INSTALLATION AND LOCATION Fort Campbell, Kentucky		
4. PROJECT TITLE LIGHTING CONTROLS AT AIRFIELD	5. PROJECT NUMBER ECIP #2	

**SPECIAL REQUIREMENTS PARAGRAPH 3 (SRP-3):**

**Energy Requirements Appraisal (ERA)**

1. Project Description: Install daylight sensing photocell controls on the existing fixtures in the base areas of the airfield hangars.
2. Estimated Energy Consumption: The lighting systems are currently controlled by manual switches. The existing systems consume 4,973,174 MJ/yr of energy. Installing the daylight sensing controls will result in 669,466 MJ/yr of electrical energy savings, a thirteen (13%) reduction in current energy consumption.
3. Energy Sources: No new energy sources are required for the proposed project. The use of solar energy for this project is impractical.
4. Energy Use Impacts: The proposed project will substantially reduce the consumption of electricity for lighting. The burden on the existing base distribution system will be lessened.
5. Energy Conservation: The proposed project will reduce annual energy consumption by 669,411 MJ/Yr with annual energy cost savings of \$26,209. The project complies with Army Resource Management Plan (ERMP) and Executive Order 12759.
6. Energy Alternatives: The proposed project represents the greatest possible reduction in energy consumption thirteen percent (13%), while maintaining appropriate light levels. The current levels do not exceed the levels recommended by ASHRAE.
7. Energy Effects: The proposed project provides positive environmental effects. It reduces current energy consumption by thirteen percent (13%), effectively reducing the consumption of non-renewable fuel sources. The degrading of environmental standards would not make more efficient energy sources available.
8. Basis of Approval: Total energy requirements and alternative fuel sources have been considered and included in this appraisal or discarded as applicable.

**TABLE 4.1  
PROJECT SUMMARY: AIRFIELD CONTROLS**

LIFE CYCLE COST ANALYSIS SUMMARY  
 ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) STUDY: ECO2AAFT  
 INSTALLATION & LOCATION: FORT CAMPBELL REGION NOS. 4 CENSUS: 3 LCCID 1.08C  
 PROJECT NO. & TITLE: ECO2AAFT LIGHTING CONTROLS - AIRFIELD TOTAL  
 FISCAL YEAR 94 DISCRETE PORTION NAME: LIGHTING  
 ANALYSIS DATE: 09-14-94 ECONOMIC LIFE 15 YEARS PREPARED BY: J. HOLLENSEN

1. INVESTMENT  
 A. CONSTRUCTION COST \$ 54616.  
 B. SIGH \$ 2731.  
 C. DESIGN COST \$ 2731.  
 D. TOTAL COST (1A+1B+1C) \$ 60078.  
 E. SALVAGE VALUE OF EXISTING EQUIPMENT \$ 0.  
 F. PUBLIC UTILITY COMPANY REBATE \$ 0.  
 G. TOTAL INVESTMENT (1D - 1E - 1F) \$ 60078.

2. ENERGY SAVINGS (-) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL S AVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 6.18	634.	\$ 3921.	12.43	\$ 48738.
B. DIST	\$ .00	0.	\$ 0.	13.56	\$ 0.
C. RESID	\$ .00	0.	\$ 0.	14.09	\$ 0.
D. NAT G	\$ .00	0.	\$ 0.	15.86	\$ 0.
E. COAL	\$ .00	0.	\$ 0.	13.61	\$ 0.
F. LPG	\$ .00	0.	\$ 0.	12.64	\$ 0.
M. DEMAND SAVINGS			\$ 22288	11.85	\$ 264113.
N. TOTAL		634.	\$ 26209.		\$ 312851.

3. NON ENERGY SAVINGS(-) / COST(-)

A. ANNUAL RECURRING (+/-)

(1) DISCOUNT FACTOR (TABLE A) 11.85 \$ 0.  
 (2) DISCOUNTED SAVING/COST (3A X 3A1) \$ 0.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) (1)	COST(-) (2)	YR OC	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+) / COST(-)(4)
------	-------------------	----------------	----------	------------------------	--

d. TOTAL \$ 0. \$ 0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(-)/COST(-) (3A2+3Bd4) \$ 0.

4. FIRST YEAR DOLLAR SAVINGS 2N3+3A-(3Bd1/(YRS ECONOMIC LIFE)) \$ 2620.

5. SIMPLE PAYBACK PERIOD (1G/4) 2.39 YRS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 312851

7. SAVINGS TO INVESTMENT RATIO (SIR) = (6 / 1G) = 5.21  
 (IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 15.09 %

# FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS

19 AUGUST 1984

DAYLIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: 7152  
AREA: HANGAR BAY


ELECTRIC COSTS  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.79 PER KW

LIGHTING CONTROLLED: 11 KW  
(AFTER ANY PROPOSED RETROFITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT IMAGE		REVISED USAGE:		ECO ENERGY CONSUMPTION	
DAY	NIGHT	DAY	NIGHT	WEEKLY	YEARLY
DAYWEEK	5	DAY	5	WEKS/WK	45
WEEKS/YR	12	WEEKS/YR	6	DEMAND (KWH/HR)	6
DEMAND (KWH)	12				
BASELINE ENERGY CONSUMPTION	22,913 KWH			ECO ENERGY CONSUMPTION	10,742 KWH
	82,128 MJ				71,673 MJ
BASELINE DEMAND	\$1,569			ECO DEMAND	\$1,034
NET ENERGY SAVINGS	11,964 KWH/YR			NET DEMAND SAVINGS	\$617 /YR
NET ENERGY SAVINGS	10,454 MJ/YR			NET DOLLAR SAVINGS	\$582 /YR

# PHOTOCELL CONTROL LAYOUT

## Building 7152



### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
— A	Photocell; Letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7152 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE #18-4C						
Unit values	1.23	15.40	34.00	0.00	0.00	49.40	
Totals	12.31	\$154	\$340	\$0	\$0		\$494
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES						
Unit values	2.00	137.00	55.00	0.00	0.00	192.00	
Totals	6.00	\$411	\$165	\$0	\$0		\$376
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE						
Unit values	1.00	290.00	27.50	0.00	0.00	317.50	
Totals	4.00	\$1,160	\$110	\$0	\$0		\$1,270
1611870101	LOW VOLTAGE TRANS 115V-24V						
Unit values	0.67	64.00	18.39	0.00	0.00	82.35	
Totals	0.67	\$64	\$18	\$0	\$0		\$82
1611870102	SWITCHING RELAYS						
Unit values	0.30	11.30	13.75	0.00	0.00	25.05	
Totals	4.00	\$90	\$110	\$0	\$0		\$200
1611950101	1/2" EMT						
Unit values	0.05	0.38	1.29	0.00	0.00	1.67	
Totals	15.98	\$129	\$438	\$0	\$0		\$568
U13 ELECTRICAL		43	\$2,008	\$1,187	\$0	\$0	\$3,190

20-JUL-94

MeansData for Lotus

Page 2

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL		43	\$2,008	\$1,182		\$0	\$3,180
SALES TAX	5.00%		\$100				
MATL MARKUP	-30.00%		(\$602)				
LABOR MARKUP	-13.40%			(\$158)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENC			\$1,506	\$1,024		\$0	\$2,530
CONTINGENCY	10.00%						\$253
BOND	2.50%						\$63
PROFIT	10.00%						\$253
JOB TOTAL							\$3,099

20-Jul-94

MeansData for Lotus

Page 3

Estimate: Bldg. 7152 Date: 20 July 1994  
Description: Flightline Facility  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	43	\$2,008	\$1,182	\$0	\$0	\$3,19
TOTAL	43	\$2,008	\$1,182	\$0	\$0	\$3,19
SALES TAX	5.00%	\$100				
MATL MARKUP	-30.00%	(\$602)				
LABOR MARKUP	-13.40%		(\$138)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENC		\$2,506	\$1,024	\$0	\$0	\$2,53
CONTINGENCY	10.00%					\$25
BOND	2.50%					\$6
PROFIT	10.00%					\$25
<b>JOB TOTAL</b>						<b>\$3,09</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS  
19 AUGUST 1994

## DAYLIGHTING CONTROLS IN HIGH BAY AREAS


BUILDING #: 7154  
AREA: HANGAR BAY

ELECTRIC COSTS.  
ENERGY CHARGE \$0.0291 PER KW-HR  
DEMAND CHARGE \$1.76 PER KW

LIGHTING CONTROLLED: 11 KW (AFTER ANY PROPOSED RETROFIT(S))  
(SEE ATTACHED SHEET FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT USAGE	REUSED USAGE
WEEKDAY	8
DAY/MONTH	5
WEEKS/YR	45
DEMAND (MONTH)	6
BASELINE ENERGY CONSUMPTION	19,742 KW-HR
	71,973 MJ
	\$1,934
NET ENERGY SAVINGS	\$517/MR
NET ENERGY SAVINGS	\$582/MR

**PHOTOCELL CONTROL LAYOUT**  
**Building 7154**



**LEGEND**

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
□ Ⓛ	Photocell; Letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Page

1

Estimate: Bldg. 7154 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total				
		Manhours	Matl	Labor	Equipment	Sub
1611350023	LOW VOLTAGE WIRE #18-4C				10.00 CLF	
Unit values	1.23	15.40	34.00	0.00	0.00	49.40
Totals	12.31	\$184	\$340	\$0	\$0	\$494
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES				3.00 EA	
Unit values	2.00	137.00	55.00	0.00	0.00	192.00
Totals	6.00	\$411	\$165	\$0	\$0	\$576
1611850101	PHOTO SWITCH SC-500 FC ADJUSTABLE				4.00 EA	
Unit values	1.00	290.00	27.50	0.00	0.00	317.50
Totals	4.00	\$1,160	\$110	\$0	\$0	\$1,270
1611870101	LOW VOLTAGE TRANS 115V-24V				1.00 EA	
Unit values	0.67	6.00	18.35	0.00	0.00	82.35
Totals	0.67		\$18	\$0	\$0	\$82.35
1611870102	SWITCHING RELA.				6.00 EA	
Unit values	0.50	11.30	13.75	0.00	0.00	25.00
Totals	4.00	\$90	\$110	\$0	\$0	\$200
1611950101	1/2" EMT				340.00 LF	
Unit values	0.05	0.36	1.29	0.00	0.00	1.6
Totals	13.98	\$129	\$439	\$0	\$0	\$561
U16 ELECTRICAL	43	\$2,008	\$1,182	\$0	\$0	\$3,190

1 20-Jul-94 MeansData for Lotus Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL		43	\$2,008	\$1,182		\$0	\$3,190
SALES TAX	5.00%		\$100				
MATL MARKUP	-36.00%		(\$602)				
LABOR MARKUP	-13.40%			(\$158)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENC			\$1,506	\$1,024		\$0	\$2,530
CONTINGENCY	10.00%						\$253
BOND	2.50%						\$63
PROFIT	10.00%						\$253
JOB TOTAL							\$3,099

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7154 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	43	\$2,008	\$1,182	\$0	\$0	\$3,190
<b>TOTAL</b>	<b>43</b>	<b>\$2,008</b>	<b>\$1,182</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,190</b>
SALES TAX	5.00%	\$100				
MATL MARKUP	-30.00%	(\$602)				
LABOR MARKUP	-13.40%		(\$158)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENC						
CONTINGENCY	10.00%	\$1,506	\$1,024	\$0	\$0	\$2,530
BOND	2.50%					\$253
PROFIT	10.00%					\$63
<b>JOB TOTAL</b>						<b>\$3,099</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: DAYLIGHTING CONTROLS

11 AUGUST 1994

### DAYLIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: 7158  
AREA: HANGAR DAY

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.76 PER KWH

LIGHTING CONTROLLED: 11 KWH (AFTER ANY PROPOSED RETROFITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

#### CURRENT USAGE

MONDAY 5  
DAY/WEEK 52  
WEEKS/YR 12  
DEMAND (MONTH) 12

#### BASELINE ENERGY CONSUMPTION

8,323 KWH  
\$2,384 M  
\$1,368


#### BASELINE DEMAND

ECO ENERGY CONSUMPTION  
22,210 KWH  
\$4,957 M  
\$3,494

NET DEMAND SAVINGS  
\$517 M/YR  
NET DOLLAR SAVINGS  
\$530 M/YR

## PHOTOCELL CONTROL LAYOUT

Building 7156



### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
Ⓐ A	Photocell; Letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7156 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total				
1611350023	LOW VOLTAGE WIRE #18-4C					
Unit values	1.23	15.40	34.00	0.00	0.00	49.40
Totals	12.31	\$154	\$340	\$0	\$0	\$494
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES					
Unit values	2.09	137.00	55.00	0.00	0.00	192.00
Totals	6.00	\$411	\$165	\$0	\$0	\$576
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE					
Unit values	1.00	290.00	27.50	0.00	0.00	317.50
Totals	4.00	\$1,160	\$110	\$0	\$0	\$1,270
1611870101	LOW VOLTAGE TRANS 115V-24V					
Unit values	0.67	64.00	18.35	0.00	0.00	82.35
Totals	0.67	\$64	\$18	\$0	\$0	\$82
1611870102	SWITCHING RELAY					
Unit values	0.50	11.30	13.75	0.00	0.00	25.05
Totals	4.00	\$90	\$110	\$0	\$0	\$200
1611950101	1/2" EMT					
Unit values	0.05	0.38	1.29	0.00	0.00	1.37
Totals	13.98	\$129	\$439	\$0	\$0	\$568
U15 ELECTRICAL	43	\$2,003	\$1,182	\$0	\$0	\$3,180

20-Jul-94

MeansData for Lotus

Page

## Line # Description

	Manhours	Matl	Labor	Equipment	Sub	Total
--	----------	------	-------	-----------	-----	-------

ESTIMATE TOTAL	43	\$2,008	\$1,182	\$0	\$0	\$3,190
SALES TAX	5.00%	\$100				
MATL MARKUP	-30.00%	(-\$602)				
LABOR MARKUP	-13.40%		(-\$158)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$1,506	\$1,024	\$0	\$0	\$2,530
CONTINGENCY	10.00%					\$253
BOND	2.50%					\$63
PROFIT	10.00%					\$252
JOB TOTAL						\$3,099

20-Jul-94

MeansData for Lotus

Page 3

Estimate: Bldg. 7156 Date: 20 July 1994  
Description: Flightline Facility  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	43	\$2,008	\$1,182	\$0	\$0	\$3,190
TOTAL	43	\$2,008	\$1,182	\$0	\$0	\$3,190
SALES TAX	5.00%	\$100				
MATL MARKUP	-30.00%	(\$602)				
LABOR MARKUP	-13.40%		(\$158)			
EQUIPT MARKUP	0.00%			\$0.		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENC		\$1,506	\$1,024	\$0	\$0	\$2,530
CONTINGENCY	10.00%					\$253
BOND	2.50%					\$63
PROFIT	10.00%					\$253
JOB TOTAL						\$3,099

# FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS  
19 AUGUST 1984

DAYLIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: 7208  
AREA: HANGAR BAY

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.72 PER KW

LIGHTING CONTROLLED: 16 KW {AFTER ANY PROPOSED RETROFITS}  
(SEE ATTACHED SPREADSHEET FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT USAGE  
MONDAY 10  
DAY/WEEK 5  
WEEK/MONTH 52  
DEMAND MONTHS 12

BASELINE ENERGY CONSUMPTION  
16.584 KWH  
112.556 MJ

REVISED USAGE:  
FRIDAY 10  
DAY/WEEK 5  
WEEK/MONTH 45  
DEMAND (MONTH) 8

ECO ENERGY CONSUMPTION  
11.187 KWH  
155.371 MJ


BASELINE DEMAND  
52.713  
ECO DEMAND  
51.809

NET DEMAND SAVINGS  
\$904 /M

NET DOLLAR SAVINGS  
\$1,048 /M

# PHOTOCELL CONTROL LAYOUT

## Building 7206



### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
→ A	Photocell; Letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7206 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description	Manhours Matl Labor Equipment Sub Total				
		Mnhours	Matl	Labor	Equipment	Sub
1611350023	LOW VOLTAGE WIRE #38				5.00 CLF	
Unit values	1.23	15.40	34.00	0.00	0.00	49.40
Totals	6.16	\$77	\$170	\$0	\$0	\$247
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES				2.00 EA	
Unit values	2.00	137.00	55.00	0.00	0.00	192.00
Totals	4.00	\$274	\$110	\$0	\$0	\$384
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE				2.00 EA	
Unit values	1.00	290.00	27.30	0.00	0.00	317.50
Totals	2.00	\$580	\$55	\$0	\$0	\$675
1611870101	LOW VOLTAGE TRANS 115V-24V				1.00 EA	
Unit values	0.67	64.00	12.35	0.00	0.00	82.35
Totals	0.67	\$64	\$18	\$0	\$0	\$82
1611870102	SWITCHING RELAYS				4.00 EA	
Unit values	0.50	11.00	13.75	0.00	0.00	25.05
Totals	2.00	\$45	\$55	\$0	\$0	\$100
1611950101	1/2" EMT				340.00 LF	
Unit values	0.05	0.38	1.29	0.00	0.00	1.67
Totals	15.98	\$129	\$439	\$0	\$0	\$568
U16 ELECTRICAL	3:	\$1,169	\$247	\$0	\$0	\$2,016

20-Jul-94

MeansData for Lotus

Pa

2

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL	J1	\$1,189	\$847	\$0	\$0	\$0	\$2,01
SALES TAX	5.00%	\$58					
MATL MARKUP	-30.00%	(\$351)					
LABOR MARKUP	-13.40%		(\$113)				
EQUIPT MARKUP	0.00%			\$0			
SUB MARKUP	0.00%				\$0		
TOTAL BEFORE CONTINGENCY		\$877	\$734	\$0	\$0	\$0	\$1,61
CONTINGENCY	10.00%						\$16
BOND	2.50%						\$4
PROFIT	10.00%						\$21
JOB TOTAL							\$1,97

20-Jul-94

## MeansData for Lotus

Estimate: Bldg. 7206 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	31	\$1,169	\$847	\$0	\$0	\$2,0
<b>TOTAL</b>	<b>31</b>	<b>\$1,169</b>	<b>\$847</b>	<b>\$0</b>	<b>\$0</b>	<b>\$2,0</b>
SALES TAX	5.00%	\$58				
MATL MARKUP	-30.00%	(\$351)				
LABOR MARKUP	-13.40%		(\$113)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$877	\$734	\$0	\$0	\$1,1
CONTINGENCY	10.00%					\$
BOND	2.50%					\$
PROFIT	10.00%					\$
<b>JOB TOTAL</b>						<b>\$1,1</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: Lighting Control  
12 AUGUST 1984

DAYLIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: 7208  
AREA: HANGAR BAY


ELECTRIC COSTS:  
ENERGY CHARGES .20/KWH  
DEMAND CHARGES .311.75/KW

LIGHTING CONTROLLER: 44 KW (AFTER ANY PROPOSED RETROFIT(S))  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT USAGE		REVISED USAGE:		NET ENERGY CONSUMPTION	
HOLIDAY	<u>10</u>	HOLIDAY	<u>10</u>	<u>50,360</u> KWH	
DAY/EEK	<u>5</u>	DAY/EEK	<u>5</u>	<u>257,695</u> KWH	
WEEKDAY	<u>45</u>	WEEKDAY	<u>45</u>		
DEMAND (PROM)	<u>8</u>	DEMAND (PROM)	<u>8</u>		
BASELINE ENERGY CONSUMPTION	<u>714,213</u> KWH	ECO DEMAND	<u>24,762</u>		
	<u>413,330</u> KWH				
	<u>26,342</u>				
NET ENERGY SAVINGS	<u>56,942</u> KWH	NET DEMAND SAVINGS	<u>\$2,081</u> NR		
		NET DOLLAR SAVINGS	<u>\$2,457</u> NR		

## PHOTOCELL CONTROL LAYOUT

Building 7208



### LEGEND

Symbol	Description
(empty circle)	Light; Controlled by Manual Switch Only
(empty circle with letter A)	Light; Letter Inside Designates Controlling Photocell
(rectangle with letter A)	Photocell; Letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7208 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE #13-4C						
Unit values	1.23	15.40	34.00	0.00	14.00 CLF		
Totals	17.23	\$216	\$476	\$0	0.00	49.40	
					\$0	\$692	
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES						
Unit values	2.00	137.00	55.00	0.00	6.00 EA		
Totals	12.00	\$822	\$330	\$0	0.00	192.00	
					\$0	\$1,152	
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE						
Unit values	1.00	290.00	22.50	0.00	4.00 EA		
Totals	4.00	\$1,160	\$110	\$0	0.00	317.50	
					\$0	\$1,270	
1611870101	LOW VOLTAGE TRANS 115V-24V						
Unit values	0.67	64.00	18.35	0.00	1.00 EA		
Totals	0.67	\$64	\$18	\$0	0.00	82.30	
					\$0	\$82	
1611870102	SWITCHING RELAYS						
Unit values	0.50	11.30	13.75	0.00	8.00 EA		
Totals	4.00	\$90	\$110	\$0	0.00	25.00	
					\$0	\$201	
1611950101	1/2" EMT						
Unit values	0.05	0.38	1.29	0.00	500.00 LF		
Totals	23.30	\$190	\$645	\$0	0.00	1.60	
					\$0	\$83	
U16 ELECTRICAL	62	\$2,542	\$1,689	\$0	\$0	\$4,23	

20-Jul-94

MeansData for Lotus

Page

## Line # Description

	Manhours	Matl	Labor	Equipment	Sub	Total
--	----------	------	-------	-----------	-----	-------

ESTIMATE TOTAL	62	\$2,542	\$1,689	\$0	\$0	\$4,23.
SALES TAX	5.00%	\$127				
MATL MARKUP	-30.00%	(\$763)				
LABOR MARKUP	-13.40%		(\$226)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$1,907	\$1,463	\$0	\$0	\$3,36
CONTINGENCY	10.00%					\$33
BOND	2.50%					\$8
PROFIT	10.00%					\$33
JOB TOTAL						\$4,12

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7208 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
J16 ELECTRICAL	62	\$2,542	\$1,689	\$0	\$0	\$4,231
<b>TOTAL</b>	<b>62</b>	<b>\$2,542</b>	<b>\$1,689</b>	<b>\$0</b>	<b>\$0</b>	<b>\$4,231</b>
SALES TAX	5.00%	\$127				
MATL MARKUP	-30.00%	(-\$763)				
LABOR MARKUP	-13.40%		(-\$226)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	0.00%					
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$1,907</b>	<b>\$1,463</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,369</b>
CONTINGENCY	10.00%					\$337
BOND	2.50%					\$84
PROFIT	10.00%					\$337
<b>JOB TOTAL</b>						<b>\$4,127</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS

19 AUGUST 1984

### DAYLIGHTING CONTROLS IN HANGAR BAY AREAS

BUILDING #: 7210  
AREA: HANGAR BAY

ELECTRIC COSTS:  
ENERGY CHARGE \$0.0291 PER KWH  
DEMAND CHARGE \$11.72 PER KW

LIGHTING CONTROLLED: 12 KW (AFTER ANY PROPOSED RETROFITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

#### REVISED USAGE:

CURRENT USAGE		
HOLIDAY	14	
DAY/WEEK	5	
WEEKS/YR	52	
DEMAND (MWH)	12	
BASELINE ENERGY CONSUMPTION	61,680 KWH	
	150.12H R/H	
	81,624	
BASELINE DEMAND		


ECO ENERGY CONSUMPTION	36,325 KWH	
	130.01H R/H	
	81,084	
ECO DEMAND		

NET ENERGY SAVINGS	\$542 /YR
NET ENERGY SAVINGS	\$661 /YR

NET DEMAND SAVINGS	20,286 KWH/YR
NET DOLLAR SAVINGS	19.23 MCHTR/YR

## PHOTOCELL CONTROL LAYOUT

### Building 7210



#### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
Ⓑ A	Photocell; Letter Designates which Photocell

20-JUL-94

MeansData for Lotus

Page 1

Estimate: Bldg. 7210 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total					
		Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE #18-4C				10.00 CLF		
Unit values	1.21	15.40	34.00	0.00	0.00	49.40	
Totals	12.31	\$154	\$340	\$0	\$0	\$494	
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES				4.00 EA		
Unit values	2.00	137.00	55.00	0.00	0.00	192.00	
Totals	3.00	\$548	\$220	\$0	\$0	\$768	
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE				4.00 EA		
Unit values	1.00	290.00	27.50	0.00	0.00	317.50	
Totals	4.00	\$1,160	\$310	\$0	\$0	\$1,270	
1611870101	LOW VOLTAGE TRANS 115V-24V				1.00 EA		
Unit values	0.67	64.00	16.35	0.00	0.00	\$82.35	
Totals	0.67	\$64	\$18	\$0	\$0	\$82	
1611870102	SWITCHING RELAYS				8.00 EA		
Unit values	0.50	11.30	31.75	0.00	0.00	25.05	
Totals	4.00	\$90	\$110	\$0	\$0	\$200	
1611950101	1/2" EMT				360.00 LF		
Unit values	0.05	0.38	1.29	0.00	0.00	1.67	
Totals	16.92	\$137	\$464	\$0	\$0	\$601	
U16 ELECTRICAL	46	\$2,153	\$1,262	\$0	\$0	\$3,415	

PAGE

20-Jul-94

MeansData for Lotus

Page

## Line # Description

~~Marhours Matl Labor Equipment Sub Total~~

ESTIMATE TOTAL	46	\$2,153	\$1,262	\$0	\$0	\$3,415
SALES TAX	5.00%	\$108				
MATL MARKUP	-30.00%	(-\$646)				
LABOR MARKUP	-13.40%		(\$169)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENC		\$1,615	\$1,093	\$0	\$0	\$2,708
CONTINGENCY	10.00%					\$271
BOND	2.50%					\$68
PROFIT	10.00%					\$271
JOB TOTAL						\$3,317

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7210 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	46	\$2,153	\$1,262	\$0	\$0	\$3,415
<b>TOTAL</b>	<b>46</b>	<b>\$2,153</b>	<b>\$1,262</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,415</b>
SALES TAX	5.00%	\$108				
MATL. MARKUP	-30.00%	(5646)				
LABOR MARKUP	-13.40%		(\$169)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$1,615	\$1,093	\$0	\$0	\$2,708
CONTINGENCY	10.00%					\$271
BOND	2.50%					\$68
PROFIT	10.00%					\$271
<b>JOB TOTAL</b>						<b>\$3,317</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS

15 AUGUST 1984

### DAYLIGHTING CONTROLS IN HIGH BAY AREAS

LOC. SWING #:  
NAME: HANGAR BAY


ELECTRIC COSTS:  
ENERGY CHARG \$0.0211 PER KWH  
DEMAND CHARG \$11.78 PER KW

CONTROLS CONTROLLED: 44 BULB FASTER AND PROPOSED RETROFIT(S)  
(SEE ATTACHED SECTION FOR THE DESCRIPTION OF CONTRL. SEQUENCE)

CURRENT USAGE	REVISED USAGE:	NET ENERGY CONSERVATION	NET DEMAND REDUCTION	NET DOLLAR SAVINGS
14 HOLIDAY	14			\$12,981 /yr
5 DAY/NIGHT	5			\$24,774 /yr
45 WEEKEND	45			\$4,162 /yr
8 DEMAND MONTHS	8			
BASELINE ENERGY CONSERVATION	14.728 kWh			
BASIS FOR REDUCTION	\$75,873 /yr			
NET ENERGY SAVINGS	\$7,442			
NET ENERGY SAVINGS	\$7,442			
75.4% SAVINGS				
75.4% SAVINGS				

# PHOTOCELL CONTROL LAYOUT

Building 7214



## LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
Ⓑ A	Photocell; Letter Designates which Photocell

20-Jul-94

## MeansData for Lotus

Estimate: Bldg. 7214 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE #18-4C					14.00 CLF	
Unit values	1.23	15.40	34.00	0.00	0.00	\$0	42
Totals	17.23	\$216	\$476	\$0	\$0	\$0	\$.
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES					6.00 EA	
Unit values	2.00	137.00	55.00	0.00	0.00	\$0	197
Totals	12.00	\$622	\$330	\$0	\$0	\$0	\$1,
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE					4.00 EA	
Unit values	1.00	290.00	27.50	0.00	0.00	\$0	317
Totals	4.00	\$1,160	\$110	\$0	\$0	\$0	\$1,
1611870101	LOW VOLTAGE TRANS 115V-24V					1.00 EA	
Unit values	0.67	64.00	18.35	0.00	0.00	\$0	82
Totals	0.67	\$64	\$18	\$0	\$0	\$0	\$.
1611870102	SWITCHING RELAYS					8.00 EA	
Unit values	0.50	11.30	13.75	0.00	0.00	\$0	25
Totals	4.00	\$90	\$110	\$0	\$0	\$0	\$.
1611950101	1/2" EMT					360.00 LF	
Unit values	0.05	0.38	1.29	0.00	0.00	\$0	1
Totals	23.50	\$190	\$645	\$0	\$0	\$0	\$.
U16 ELECTRICAL		82	\$2,542	\$1,689	\$1	\$0	\$4,

20-JUL-94

## MeansData for Lotus

ge 20-Jul-94 MeansData for Lotus Pe

Estimate: Bldg. 7214 Date: 20 July 1994  
Description: Flightline Facility  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City indx:

SUMMARY

	Menhours	Matl	Labor	Equipment	Sub	Total
W16 ELECTRICAL	62	\$2,542	\$1,689	\$0	\$0	\$4,2
TOTAL	62	\$2,542	\$1,689	\$0	\$0	\$4,2
SALES TAX	5.00%	\$127				
MATL MARKUP	-30.00%	(-\$763)				
LABOR MARKUP	-13.40%		(-\$226)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$1,907	\$1,463	\$0	\$0	\$3,3
CONTINGENCY	10.00%					\$3
BOND	2.50%					\$
PROFIT	10.00%					\$3
JOB TOTAL						\$4,1

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS

19 AUGUST 1984

### DAYLIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: 7218  
AREA: HANGAR BAY


ELECTRIC COSTS:  
ENERGY CHARG 90.0211 PER KWH  
DEMAND CHARG \$11.70 PER KW

# CONTROLLED: 44 KW (AFTER ANY PROPOSED RETROFITS)  
(TACKED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT USAGE		WEEKEND USAGE		ECO ENERGY CONSUMPTION	
DAY	WEEK	DAY	WEEK	DAY	WEEK
MONDAY	5	TUESDAY	5	MONDAY	14
TUESDAY	5	WEDNESDAY	5	TUESDAY	14
WEEKS/YR	52	WEEKS/YR	52	WEEKS/YR	52
DEMAND (ACM)	12	DEMAND (ACM)	8	DEMAND (ACM)	8
BASELINE ENERGY CONSUMPTION	18,172 kWh	BASELINE ENERGY CONSUMPTION	18,172 kWh	ECO DEMAND	13,765 kWh
	879,673 MJ		879,673 MJ		590,776 MJ
BASELINE DEMAND	30,242				24,162
NET ENERGY SAVINGS	77,333 MJ/NR				
NET ENERGY SAVINGS	72,633 MJ/NR				
NET ENERGY SAVINGS	\$2,081 NR				
NET ENERGY SAVINGS	\$2,537 NR				

# PHOTOCELL CONTROL LAYOUT

## Building 7218



### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
→ A	Photocell; Letter Designates which Photocell

30-JUL-94

MeansData for Lotus

Pac

Estimate: Bldg. 7218 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE 116-4C					14.00 CLF	
Unit values	1.23	15.40	34.00	0.00	0.00	\$0	49.41
Totals	17.23	\$216	\$476	\$0	\$0	\$0	\$69
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES					6.00 EA	
Unit values	2.00	37.00	55.00	0.00	0.00	\$0	192.0
Totals	12.00	\$822	\$330	\$0	\$0	\$0	\$1,15
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE					4.00 EA	
Unit values	1.00	290.00	27.30	0.00	0.00	\$0	317.5
Totals	4.00	\$1,160	\$110	\$0	\$0	\$0	\$1,27
1611870101	LOW VOLTAGE TRANS 115V-24V					1.00 EA	
Unit values	0.67	64.00	18.35	0.00	0.00	\$0	82.3
Totals	0.67	\$64	\$18	\$0	\$0	\$0	\$82
1611870102	SWITCHING RELAYS					8.00 EA	
Unit values	0.50	11.30	13.75	0.00	0.00	\$0	23.0
Totals	4.00	\$90	\$110	\$0	\$0	\$0	\$20
1611950101	1/2" EMT					500.00 LF	
Unit values	0.05	0.38	1.29	0.00	0.00	\$0	1.6
Totals	21.50	\$190	\$645	\$0	\$0	\$0	\$83
U16 ELECTRICAL		62	\$2,542	\$1,689	\$0	\$0	\$4,23

20-Jul-94

MeansData for Lotus

Page  
2

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL		62	\$2,542	\$1,689		\$0	\$0 \$4,23
SALES TAX	5.00%		\$127				
MATL MARKUP	-30.00%		(-\$763)				
LABOR MARKUP	-13.40%			(-\$226)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENC			\$1,907	\$1,463		\$0	\$0 \$3,36
CONTINGENCY	10.00%						\$33
BOND	2.50%						\$8
PROFIT	10.00%						\$33
JOB TOTAL							\$4,12

20-Jul-94

MeansData for Lotus

Par

Estimate: Bldg. 7218 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	62	\$2,542	\$1,689	\$0	\$0	\$4,23
<b>TOTAL</b>	<b>62</b>	<b>\$2,542</b>	<b>\$1,689</b>	<b>\$0</b>	<b>\$0</b>	<b>\$4,23</b>
SALES TAX	5.00%	\$127				
NATL MARKUP	-30.00%	(-\$763)				
LABOR MARKUP	-13.40%		(-\$226)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENC</b>		<b>\$1,937</b>	<b>\$1,463</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,36</b>
CONTINGENCY	10.00%					\$33
BOND	2.50%					\$8
PROFIT	10.00%					\$33
<b>JOB TOTAL</b>						<b>\$4,12</b>

## FORT CARSON LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS  
19 AUGUST 1984

### DAYLIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: 7243  
AREA: TENGAR BAY

ELECTRIC COSTS:  
ENERGY CHARG \$0.0211 PER KWH  
DEMAND CHARG \$11.76 PER KW


LOCATION CONTROLLED: 20 KWH (AFTER ANY PROPOSED RETROFITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT USAGE	WEEKDAY	HOLIDAY	NET ENERGY CONSUMPTION	NET DEMAND
DAY	14	5	144 - 100W	\$11.76
WEEK	5	5	300 - 100W	\$11.76
YEARLY	52	45	16,640 - 100W	\$11.76
Demand Growth	12	8		
BASELINE ENERGY CONSUMPTION			312,880 MJ	
BASELINE DEMAND			\$2,697	
NET ENERGY SAVINGS	40,938 MJ/W	\$1,391 HR		
NET DOLLAR SAVINGS	40,141 BUDGET	\$1,386 HR		
NET ENERGY SAVINGS				

PAC

## PHOTOCELL CONTROL LAYOUT

### Building 7243



#### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch On/Off
Ⓐ	Light; Letter inside Designates Controlling Photocell
Ⓑ A	Photocell; Letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Pg

Estimate: Bldg. 7243 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total					
		Manhours	Matl	Labor	Equipment	Sub	Total
1611330023	LOW VOLTAGE WIRE #18-4C				6.00 CLF		
Unit values	1.23	15.40	34.00	0.00	0.00	49.40	
Totals	9.85	\$123	\$272	\$0	\$0	\$395	
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES				4.00 EA		
Unit values	2.00	137.00	55.00	0.00	0.00	192.00	
Totals	8.00	\$548	\$220	\$0	\$0	\$768	
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE				2.00 EA		
Unit values	1.00	290.00	27.50	0.00	0.50	317.50	
Totals	2.00	\$580	\$55	\$0	\$0	\$635	
1611870101	LOW VOLTAGE TRANS 115V-24V				1.00 EA		
Unit values	0.67	64.00	18.35	0.00	0.00	82.35	
Totals	0.67	\$64	\$18	\$0	\$0	\$82	
1611870102	SWITCHING RELAYS				4.00 EA		
Unit values	0.50	11.30	13.75	0.00	0.00	25.00	
Totals	2.00	\$45	\$55	\$0	\$0	\$100	
1611950101	1/2" EMT				550.00 LF		
Unit values	0.05	0.38	1.29	0.00	0.00	1.67	
Totals	25.85	\$209	\$710	\$0	\$0	\$911	
U16 ELECTRICAL	49	\$1,569	\$1,330	\$0	\$0	\$2,899	

20-Jul-94

MeansData for Lotus

Page

## Line #

## Description

	Manhours	Matl	Labor	Equipment	Sub	Total
--	----------	------	-------	-----------	-----	-------

ESTIMATE TOTAL	49	\$1,569	\$1,330	\$0	\$0	\$2,899
SALES TAX	5.00%	\$73				
MAVL MARKUP	-30.00%	(\$471)				
LABOR MARKUP	-13.40%		(\$178)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$1,177	\$1,152	\$0	\$0	\$2,321
CONTINGENCY	10.00%					\$231
BOND	2.50%					\$58
PROFIT	10.00%					\$231
JOB TOTAL						\$2,851

PAGE

20-Jul-94

## MeansData for Lotus

3

Page

Estimate: Bldg. 7243 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	49	\$1,569	\$1,330	\$0	\$0	\$2,899
TOTAL	49	\$1,569	\$1,330	\$0	\$0	\$2,899
SALES TAX	5.00%	\$76				
MATL MARKUP	-30.00%	(\$471)				
LABOR MARKUP	-13.40%		(\$178)			
EQUIPT MARKUP	0.00%			\$0		\$0
SUB MARKUP	C.00%				\$0	
TOTAL BEFORE CONTINGENC		\$1,177	\$1,152	\$0	\$0	\$2,329
CONTINGENCY	10.00%					\$233
BOND	2.50%					\$58
PROFIT	10.00%					\$233
<b>JOB TOTAL</b>						<b>\$2,892</b>

# FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS

19 AUGUST 1994

## DAYLIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: 7445  
AREA: HANGAR BAY

LIGHTING CONTROLLED: 16 KW  
(AFTER ANY PROPOSED RETROITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

ELECTRIC LOSSES:  
ENERGY CHARG: \$0.0211 PER KWH  
DEMAND CHARG: \$11.76 PER KW

### REVISED USAGE:

1 DAY	14
1 DAY/WEEK	5
1 WEEK/5W	5
DEMAND (MONTH)	8


### ECO ENERGY CONSUMPTION

50,844 KWH	30,715 KWH
\$10,974 MJ	\$6,257.4 MJ
\$2,276	\$1,517

NET DEMAND SAVINGS \$759 /NR  
NET DOLLAR SAVINGS \$325 /NR

## PHOTOCELL CONTROL LAYOUT

### Building 7245



#### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; letter inside Designates Controlling Photocell
Ⓑ A	Photocell; letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Pa

Estimate: Bldg. 7245 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total					
1611350023	LOW VOLTAGE WIRE #18-4C						
Unit values	1.23	15.40	34.00	0.00	13.00 CLF		
Totals	16.00	\$200	\$442	\$0	0.00	49.4	\$64
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES						
Unit values	2.00	137.00	55.00	0.00	5.00 EA		
Totals	10.00	\$685	\$275	\$0	0.00	192.0	\$96
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE						
Unit values	1.00	290.00	27.50	0.00	4.00 EA		
Totals	4.00	\$1,160	\$110	\$0	0.00	317.5	\$1,27
1611970101	LOW VOLTAGE TRANS 115V-24V						
Unit values	0.67	64.00	18.35	0.00	1.00 EA		
Totals	0.67	\$64	\$18	\$0	0.00	82.3	\$8
1611870102	SWITCHING RELAYS						
Unit values	0.50	11.30	13.75	0.00	3.00 EA		
Totals	4.00	\$90	\$110	\$0	0.00	25.0	\$20
1611990101	1/2" EMT						
Unit values	0.05	0.38	1.29	0.00	480.00 LF		
Totals	22.56	\$132	\$619	\$0	0.00	1.6	\$80
U16 ELECTRICAL	58	\$2,391	\$1,574	\$0	\$0	\$0	\$3,95

20-Jul-94

MeansData for Lotus

Page

Line #	Description
	Manhours Matl Labor Equipment Sub Total

ESTIMATE TOTAL	58	\$2,381	\$1,574	\$0	\$0	\$3,955
SALES TAX	5.00%	\$119				
MATL MARKUP	-30.00%	(5714)				
LABOR MARKUP	-13.40%		(5211)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENC		\$1,786	\$1,363	\$0	\$0	\$3,149
CONTINGENCY	10.00%					\$315
BOND	2.50%					\$79
PROFIT	10.00%					\$315
JOB TOTAL						\$3,857

20-Jul-94

YeanasData for Lotus

Page

Estimate: Bldg. 7243 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	58	\$2,381	\$1,574	\$0	\$0	\$3,955
<b>TOTAL</b>	<b>58</b>	<b>\$2,381</b>	<b>\$1,574</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,955</b>
SALES TAX	5.00%	\$119				
MATL MARKUP	-30.00%	(\$714)				
LABOR MARKUP	-13.40%		(\$211)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$1,786	\$1,363	\$0	\$0	\$3,149
CONTINGENCY	10.00%					\$315
BOND	2.50%					\$79
PROFIT	10.00%					\$315
<b>JOB TOTAL</b>						<b>\$3,857</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS

19 AUGUST 1994

DATA COLLECTED CONTROLS IN HIGH BAY AREAS

BUILDING #: 7219  
AREA: HANGAR BAY

ELECTRIC COSTS:  
ENERGY CHARGES .200211 PER KW/H  
DEMAND CHARGES .31176 PER KW


LIGHTING CONTROLLED: 18 KW (AFTER ANY PROPOSED RETROITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT USAGE	REvised USAGE:
MONDAY	14
DAY/WEEK	5
WEEKS/YR	52
DEMAND MONTHS	12

BASELINE ENERGY CONSUMPTION	ECO ENERGY CONSUMPTION
<u>52.60%</u> KW/H <u>219.574</u> MJ	<u>50.715</u> KW/H <u>182.074</u> MJ
<u>\$1.775</u>	<u>\$1.517</u>
ECO DEMAND	ECO DEMAND

NET ENERGY SAVINGS	NET DOLLAR SAVINGS
<u>20,460 MJ/YR</u>	<u>\$769 /YR</u>
<u>27 MJ/MTW</u>	<u>\$223 /YR</u>
NET ENERGY SAVINGS	NET DOLLAR SAVINGS

**PHOTOCELL CONTROL LAYOUT**  
**Building 7249**



**LEGEND**

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
Ⓐ A	Photocell; Letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7249 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE #18-4C					13.00 CLF	
Unit values	1.23	15.40	34.00	0.00	0.00	\$0	49.40
Totals	16.00	\$200	\$442	\$0	0.00	\$0	\$642
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES				5.00 EA		
Unit values	2.00	137.00	55.00	0.00	0.00	\$0	192.00
Totals	10.00	\$685	\$275	\$0	0.00	\$0	\$960
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE				4.00 EA		
Unit values	1.00	290.00	27.50	0.00	0.00	\$0	317.50
Totals	4.00	\$1,160	\$110	\$0	0.00	\$0	\$1,270
1611870101	LOW VOLTAGE TRANS 115V-24V				1.00 EA		
Unit values	0.67	64.00	18.35	0.00	0.00	\$0	82.35
Totals	0.67	\$64	\$18	\$0	0.00	\$0	\$82
1611870102	SWITCHING RELAYS				8.00 EA		
Unit values	0.50	11.30	13.75	0.00	0.00	\$0	25.05
Totals	4.00	\$90	\$110	\$0	0.00	\$0	\$200
1611950101	1/2" EMT				480.00 LF		
Unit values	0.05	0.38	1.29	0.00	0.30	\$0	1.67
Totals	22.56	\$182	\$619	\$0	0.30	\$0	\$801
016 ELECTRICAL	58	\$2,381	\$1,374	\$0	\$0	\$0	\$3,955

20-Jul-94

MeansData for Lotus

Page

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL		58	\$2,381	\$1,574	\$0	\$0	\$3,857
SALES TAX	5.00%		\$119				
MATL MARKUP	-30.00%		(-\$714)				
LABOR MARKUP	-13.40%			(\$211)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY		\$1,786	\$1,363	\$0	\$0	\$3,149	
CONTINGENCY	10.00%						\$315
BOND	2.50%						\$73
PROFIT	10.00%						\$315
JOB TOTAL							\$3,857

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7249 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	58	\$2,381	\$1,374	\$0	\$0	\$3,955
<b>TOTAL</b>	<b>58</b>	<b>\$2,381</b>	<b>\$1,374</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,955</b>
STATE TAX	5.00%	\$119				
SUPPL MARKUP	-30.00%	(-\$714)				
LABOR MARKUP	-13.40%		(-\$211)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$1,786</b>	<b>\$1,363</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,149</b>
CONTINGENCY	10.00%					\$315
ROND	2.50%					\$79
PROFIT	10.00%					\$315
<b>JOB TOTAL</b>						<b>\$3,857</b>

**FORT CAMPBELL LIGHTING SURVEY**

ECO 2: LIGHTING CONTROLS  
19 AUGUST 1984

DAYLIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: T332  
AREA: HIGH BAY


ELECTRIC COSTS:  
ENERGY CHARG \$0.0211 PER KWH  
DEMAND CHARG \$1178 PER KW

LIGHTING CONTROLLED: 75 KW (AFTER ANY PROPOSED RETROFITS)  
SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE!

WEEKDAY USAGE		REVISED USAGE:		ECO ENERGY CONSUMPTION	
DAY	HOURS	DAY	HOURS	WEEK	KWH
SATURDAY	10	SUNDAY	10	10	174,540
MONDAY	5	TUESDAY	5	5	612,654
TUESDAY	5	WEDNESDAY	5	5	612,654
WEDNESDAY	5	THURSDAY	5	5	612,654
THURSDAY	5	FRIDAY	5	5	612,654
FRIDAY	5	SATURDAY	5	5	612,654
SATURDAY	5	SUNDAY	5	5	612,654
SUNDAY	5	SUNDAY	5	5	612,654
TOTAL DEMAND (KWH)	12	TOTAL DEMAND (KWH)	6	TOTAL DEMAND	37,320
BASELINE ENERGY CONSUMPTION	302,678 KWH	ECO DEMAND	37,320	NET DEMAND SAVINGS	\$3,564 PYR
BASELINE ENERGY CONSUMPTION	727,634 MJ	ECO DEMAND	37,320	NET DOLLAR SAVINGS	\$4,238 PYR
BASELINE DEMAND	315,631	NET ENERGY SAVINGS	33,323 MJ PYR	NET ENERGY SAVINGS	\$3,633 MJ PYR

## PHOTOCELL CONTROL LAYOUT

### Building 7262



#### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
▀ A	Photocell; Letter Designates which Photocell

20-Jul-94

MeansData for Lotus

Page :

Estimate: Bldg. 7262 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours Matl Labor Equipment Sub Total					
1611350023	LOW VOLTAGE WIRE 613-4C						
Unit values	1.23	15.40	34.00	0.00	25.00 CLF		
Totals	30.78	\$385	\$850	\$0	0.00	49.40	
					\$0	\$1,235	
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES						
Unit values	2.00	137.00	55.00	0.00	8.00 EA		
Totals	16.00	\$1,096	\$440	\$0	0.00	192.00	
					\$0	\$1,536	
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE						
Unit values	1.00	290.00	27.50	0.00	8.00 EA		
Totals	8.00	\$2,320	\$220	\$0	0.00	317.50	
					\$0	\$2,540	
1611870101	LOW VOLTAGE TRANS 115V-24V						
Unit values	0.67	64.00	18.35	0.00	1.00 EA		
Totals	0.67	\$64	\$18	\$0	0.00	82.35	
					\$0	\$82	
1611870102	SWITCHING RELAYS						
Unit values	2.50	11.30	13.75	0.00	16.00 EA		
Totals	8.00	\$181	\$220	\$0	0.00	25.05	
					\$0	\$401	
1611950101	1/2" EMT						
Unit values	0.05	0.38	1.29	0.00	750.00 LF		
Totals	35.25	\$285	\$968	\$0	0.00	1.67	
					\$0	\$1,253	
C16 ELECTRICAL	99	\$4,331	\$2,716	\$0		\$7,047	

20-JUL-94

MeansData for Lotus

Page :

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL		99	\$4,331	\$2,716		\$0	\$0 \$7,047
SALES TAX	5.00%		\$217				
MATL MARKUP	-30.00%		(\$1,299)				
LABOR MARKUP	13.40%			(\$364)			
EQUIPT MARKUP	9.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$3,248	\$2,352		\$0	\$0 \$5,600
CONTINGENCY	10.00%						\$560
BOND	2.50%						\$140
PROFIT	10.00%						\$560
JOB TOTAL							\$6,860

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7262 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

## SUMMARY

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	99	\$4,331	\$2,716	\$0	\$0	\$7,047
TOTAL	99	\$4,331	\$2,716	\$0	\$0	\$7,047
SALES TAX	5.00%	\$217				
MATL MARKUP	-30.00%	(\$1,299)				
LABOR MARKUP	-13.40%		(\$364)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENC		\$3,248	\$2,352	\$0	\$0	\$5,600
CONTINGENCY	10.00%					\$560
BOND	2.50%					\$140
PROFIT	10.00%					\$560
JOB TOTAL						\$6,860

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS  
19 AUGUST 1994

DAYLIGHTING CONTROLS IN HIGH BAY AREAS


BUILDING #: 7264  
AREA: HANGAR BAY

ELECTRIC COSTS:  
ENERGY CHARGES \$0.0211 PER KWH  
DEMAND CHARGE \$11.76 PER KW

LIGHTING CONTROLLED: 71 KW  
(AFTER ANY PROPOSED RETROFITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT USAGE:	71 KW	REVISED USAGE:	10 KW	10 KW	\$0.0211 KWH
MONDAY	10	MONDAY	10	5	\$0.0211 KWH
TUESDAY	5	TUESDAY	5	5	\$0.0211 KWH
WEEKEND	52	WEEKEND (MON)	52	6	\$0.0211 KWH
WEEKEND (TUE)	12	WEEKEND (TUE)	12	6	\$0.0211 KWH
BASELINE ENERGY CONSUMPTION	185,220 KWH	ECO ENERGY CONSUMPTION	185,220 KWH	185,220 KWH	\$0.0211 KWH
BASELINE DEMAND	697.191 KW	ECO DEMAND	697.191 KW	697.191 KW	\$0.0211 KWH
NET ENERGY SAVINGS	\$3,813 M/YR	NET DOLLAR SAVINGS	\$3,813 M/YR	\$3,813 M/YR	\$3,813 M/YR
NET ENERGY SAVINGS	\$3,813 M/YR	NET DOLLAR SAVINGS	\$3,813 M/YR	\$3,813 M/YR	\$3,813 M/YR

**PHOTOCELL CONTROL LAYOUT**  
**Building 7264**



**LEGEND**

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
Ⓑ A	Photocell; Letter Designates which Photocell

20-Jul-94

## MeansData for Lotus

Page 1

Estimate: Bldg. 7264 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description						
		Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE #18-4C						
Unit values	1.23	15.40	34.00	0.00	12.00 CLF		
Totals	14.77	\$165	\$408	\$0	.00	49.41	
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES						
Unit values	2.00	137.00	53.00	0.00	4.00 EA		
Totals	8.00	\$548	\$220	\$0	.00	192.00	
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE						
Unit values	1.00	290.00	27.50	0.00	3.00 EA		
Totals	3.00	\$870	\$83	\$0	.00	317.50	
1611870101	LOW VOLTAGE TRANS 115V-24V						
Unit values	0.67	64.00	16.05	0.00	1.00 EA		
Totals	0.67	\$64	\$18	\$0	.00	82.30	
1611870102	SWITCHING RELAYS						
Unit values	0.50	11.30	13.75	0.00	6.00 EA		
Totals	3.00	\$68	\$83	\$0	.00	25.00	
1611950101	1/2" EMT						
Unit values	0.05	0.38	1.29	0.00	600.00 LF		
Totals	28.20	\$228	\$774	\$0	.00	1.61	
U16 ELECTRICAL		58	\$1,963	\$1,586	\$0	\$3,54	

20-Jul-94

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL		58	\$1,963	\$1,586	\$0	\$0	\$3,549
SALES TAX	5.00%		\$98				
MATL MARKUP	-30.00%		(\$589)				
LABOR MARKUP	-13.40%			(\$213)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENC			\$1,472	\$1,373	\$0	\$0	\$2,846
CONTINGENCY	10.00%						\$286
BOND	2.50%						\$71
PROFIT	10.00%						\$286
JOB TOTAL							\$3,486

20-Jul-94

MeansData for Lotus

Page

Estimate: Bldg. 7264 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
UIC ELECTRICAL	58	\$1,963	\$1,586	\$0	\$0	\$3,549
<b>TOTAL</b>	<b>58</b>	<b>\$1,963</b>	<b>\$1,586</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,549</b>
SALES TAX	5.00%	\$98				
MATL MARKUP	-30.00%	(5589)				
LABOR MARKUP	-13.40%		(5213)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>	<b>\$1,472</b>	<b>\$1,373</b>		<b>\$0</b>	<b>\$0</b>	<b>\$2,846</b>
CONTINGENCY	10.00%					\$285
BOND	2.50%					\$71
PROFIT	10.00%					\$285
<b>JOB TOTAL</b>						<b>\$3,486</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS

19 AUGUST 1984

DAYLIGHTING CONTROLS IN HANGAR BAY AREAS

BUILDING #: 7200  
AREA #: HANGAR BAY


ELECTRIC COSTS:  
ENERGY CHARGES \$0.0211 PER KWH  
DEMAND CHARGES \$11.78 PER KW

LIGHTING CONTROLLED: 30 KW (AFTER ANY PROPOSED RETROFITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTINUOUS SEQUENCE)

CURRENT USAGE	REVISED USAGE:	NET ENERGY SAVINGS	NET DOLLAR SAVINGS
HOURLY	10%	10,000 KWH	\$1,832 / yr
DAY/WEEK	5%	303,217 KWH	\$2,119 / yr
WEEK/MONTH	32%		
DEMAND (MONTH)	1.2		
BASELINE ENERGY CONSUMPTION	101,000 KWH		
BASELINE DEMAND	101,000 KWH		
NET ENERGY SAVINGS	45,387 KWH		
NET ENERGY SAVINGS	45,387 KWH		

## PHOTOCELL CONTROL LAYOUT

### Building 7268



#### LEGEND

Symbol	Description
O	Light; Controlled by Manual Switch Only
A	Light; Letter Inside Designates Controlling Photocell
— A	Photocell; Letter Designates which Photocell

20-Jul-94

XeansData for Lotus

Page

Estimate: Bldg. 7268 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE #18-4C						
Unit values	1.23	15.40	34.00	0.00	0.00	49.40	
Totals	12.31	\$154	\$340	\$0	\$0	\$494	
1611750101	LIGHTING CONTACTOR 600 V, 20 A, 3 POLES						
Unit values	2.00	137.00	35.00	0.00	0.00	192.00	
Totals	6.00	\$411	\$165	\$0	\$0	\$576	
1611850101	PHOTO SWITCH 50-500 FC ADJUSTABLE						
Unit values	1.00	290.00	27.50	0.00	0.00	317.50	
Totals	4.00	\$1,160	\$110	\$0	\$0	\$1,270	
1611870101	LOW VOLTAGE TRANS 115V-24V						
Unit values	0.67	64.00	18.35	0.00	0.00	82.35	
Totals	0.67	\$64	\$18	\$0	\$0	\$82	
1611870102	SWITCHING RELAYS						
Unit values	0.50	11.30	13.75	0.00	0.00	25.05	
Totals	4.00	\$90	\$110	\$0	\$0	\$200	
16118930101	1/2" EMT						
Unit values	0.05	0.38	1.29	0.00	375.00	0.00	
Totals	17.63	\$143	\$484	\$0	\$0	\$627	
U16 ELECTRICAL	45	\$2,022	\$1,227	\$0	\$0	\$3,249	

PAGE 4

20-Jul-94

## MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL		45	\$2,029	\$1,227	\$0	\$0	\$3,249
SALES TAX	5.00%		\$103				
MATL MARKUP	-30.00%		(-\$607)				
LABOR MARKUP	-13.40%			(-\$164)			
EQUIPT MARKUP	0.00%				\$0		
SCB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY			\$1,517	\$1,053	\$0	\$0	\$2,579
CONTINGENCY	10.00%						\$258
BOND	2.50%						\$64
PROFIT	30.00%						\$258
JOB TOTAL							\$3,159

20-Jul-94

MeansData for Lotus

Page 1

Estimate: Blng. 7268 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	45	\$2,022	\$1,227	\$0	\$0	\$3,249
<b>TOTAL</b>	<b>45</b>	<b>\$2,022</b>	<b>\$1,227</b>	<b>\$0</b>	<b>\$0</b>	<b>\$3,249</b>
SALES TAX	5.00%	\$1.01				
MATL MARKUP	-30.00%	(\$607)				
LABOR MARKUP	-15.40%		(\$164)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$1,517	\$1,063	\$0	\$0	\$2,579
CONTINGENCY	10.00%					\$258
BOND	2.50%					\$64
PROFIT	10.00%					\$258
<b>JOB TOTAL</b>						<b>\$3,159</b>

## FORT CAMPBELL LIGHTING SURVEY

ECO 2: LIGHTING CONTROLS

19 AUGUST 1984

DATA LIGHTING CONTROLS IN HIGH BAY AREAS

BUILDING #: 7272  
AREA: HANGAR BAY



ELECTRIC COSTS:  
ENERGY CHARGES \$0.0211 PER KWH  
DEMAND CHARGES \$11.73 PER KW

LIGHTING CONTROLLED: 29 KW (AFTER ANY PROPOSED RETROFITS)  
(SEE ATTACHED SKETCH FOR DESCRIPTION OF CONTROL SEQUENCE)

CURRENT USAGE:		REVISED USAGE:		ECO ENERGY CONSUMPTION		NET DEMAND SAVINGS	
FRIDAY	10	FRIDAY	10				
DAY/WEEK	5	DAY/WEEK	5				
WEEKS/YR	32	WEEKS/YR	32				
DEMAND (MONTH)	12	DEMAND (MONTH)	12				
BASELINE ENERGY CONSUMPTION	73,916 kWh	ECO ENERGY CONSUMPTION	25,619 kWh				
BASELINE DEMAND	372.93 kW	ECO DEMAND	236.986 kW				
	84.122		82.744				
NET ENERGY SAVINGS	36,742 kWh/yr			\$1,374 /yr			
NET DOLLAR SAVINGS	\$1,852 /month			\$1,588 /yr			
NET ENERGY SAVINGS							

## PHOTOCELL CONTROL LAYOUT

### Building 7272



Indicates Office Area Enclosed  
Below HID Fixtures.

#### LEGEND

Symbol	Description
○	Light; Controlled by Manual Switch Only
Ⓐ	Light; Letter Inside Designates Controlling Photocell
Ⓑ A	Photocell; Letter Designates which Photocell

20-Jul-94

## MeansData for Lotus

Page

Estimate: Bldg. 7272 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
1611350023	LOW VOLTAGE WIRE #18-4C						
Unit values	1.23	15.40	34.00	0.00	14.00 CLF	0.06	49.40
Totals	17.23	\$216	\$476	\$0		\$0	\$692
1611750101	LIGHTING CONTACTOR 600 V, 30 A, 3 POLES					3.00 EA	
Unit values	2.00	137.00	55.00	0.00		0.00	192.00
Totals	6.00	\$411	\$165	\$0		\$0	\$576
1611630101	PHOTO SWITCH 50-500 FC ADJUSTABLE					4.00 EA	
Unit values	1.00	290.00	27.50	0.00		0.00	317.50
Totals	4.00	\$1,160	\$110	\$0		\$0	\$1,270
1611870101	LOW VOLTAGE TRANS 115V-24V					1.00 EA	
Unit values	0.67	64.00	18.35	0.00		0.00	82.35
Totals	0.67	\$64	\$18	\$0		\$0	\$82
1611870102	SWITCHING RELAYS					8.00 EA	
Unit values	0.50	11.30	13.75	0.00		0.00	25.05
Totals	4.00	\$90	\$110	\$0		\$0	\$200
1611950101	1/2" EMT					500.00 LF	
Unit values	0.05	0.38	1.29	0.00		0.00	1.67
Totals	23.50	\$190	\$645	\$0		\$0	\$815
U16 ELECTRICAL		56	\$2,131	\$1,524		\$0	\$3,655

20-Jul-94

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
ESTIMATE TOTAL		56	\$2,131	\$1,524	\$0	\$0	\$3,655
SALES TAX	5.00%		\$107				
MATL MARKUP	-30.00%		(\$639)				
LABOR MARKUP	-13.40%			(\$204)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	0.00%					\$0	
TOTAL BEFORE CONTINGENCY		\$1,598		\$1,320	\$0	\$0	\$2,918
CONTINGENCY	10.00%						\$292
BOND	2.50%						\$73
PROFIT	10.00%						\$292
JOB TOTAL							\$3,575

20-Jul-94

MeansData for Lotus

?

• 3

Estimate: Bldg. 7272 Date: 20 July 1994  
 Description: Flightline Facility  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City Indx:

## SUMMARY


	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL	56	\$2,131	\$1,524	\$0	\$0	\$3,6
TOTAL	56	\$2,131	\$1,524	\$0	\$0	\$3,6
SALES TAX	5.00%	\$107				
MATL MARKUP	-10.00%	(\$639)				
LABOR MARKUP	-10.40%		(\$204)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
TOTAL BEFORE CONTINGENCY		\$1,592	\$1,320	\$0	\$0	\$2,9
CONTINGENCY	10.00%					\$3
ZON	2.50%					\$3
PROFIT	10.00%					\$3
JOB TOTAL						\$3,6



Remote Control  
Low Voltage

Switches


Components  
and Applications



GENERAL ELECTRIC

## Photo Switches

**BPHOTO-4** This unit is used to start artificial lighting in interior day spaces if it is turned outside switches through a perimeter window or sky light to provide the switching signal to the indicator, a Master Sequence or Telephone override. The switch will turn lights OFF when the exterior light level reaches the set point and a level and remains there for 15 minutes. When the light level decreases to approximately 15% less than this setting and remains there for 15 minutes, lights will be turned ON. (See the wiring diagram on page 28.)



**BPHOTO-5** This unit is designed to turn exterior lighting

Specifications	
Circuit Number	BPHOTO-4 (number 48001)
	BPHOTO-5 (number 48002)
Operating Range	32°-102°-50-53°C (89.6°-215.6°F)
	BPHOTO-5 5-70°C (41-158°F)
Power Requirements	No external source needed
Environment	-10 to 55°C (14 to 131°F) non-condensing & non-corrosive 0.05% RH non-corrosive (BPHOTO-4) 0-100% RH (BPHOTO-5)
RF Environment	Less than 12 v.c.
Immunity Requirements	
	BPHOTO-4 - Yes
	BPHOTO-5 - No
Hysteresis	15% l.v. @ 100°C 20% l.v. @ 300°C 25% l.v. @ 350°C

## 5 PROJECT III: INTERIOR LIGHTING AND CONTROLS AT BLANCHFIELD HOSPITAL

FYD4 EBAP Edition C, ENRCA Study, Ft. Campbell, KY

This section contains the Project Development Brochures and the DD 1391 Forms for Project III Interior Lighting and Controls at Blanchfield Hospital. Following the DD 1391 Forms is a project summary table, the life cycle cost analysis for the total project, and the life cycle cost analysis, calculations, and cost estimate for the interior lighting and for the controls. The interior lighting replacements include T8 fluorescent fixtures with electronic ballasts (with and without reflectors), and compact fluorescents. The controls portion of the project involves the installation of occupancy sensors in doctors' offices and exam rooms in Building C. Below is a detailed index of the information included in this section.

PDB	5-2
DD 1391 Forms	5-18
Table 5.1 Project Summary - Hospital Interior Lighting and Controls	5-26
Project LCCA	5-27
LCCA for Interior Lighting - Buildings B & C	5-28
Calculations and Cost Estimates - Interior Lighting - Buildings B & C	5-29
LC41AA for Lighting Controls - Building C - Doctor and Exam Rooms	5-40
Calculations and Cost Estimates - Lighting Controls - Building C	5-41
Catalog Cut Sheets	5-43

# **facility**

INTERIOR LIGHTING REPLACEMENT AND CONTROLS AT BLANCHFIELD HOSPITAL  
Fort Campbell, Kentucky

## **project coordinator for using service**

Arlin Wright

**functional requirements summary, PDB-1**

5-2

DA FORM 5020-1A, Feb 82

TM 5-800-3 AF

**OBJECTIVE:**

The objective of this project is to replace existing interior lighting with high efficiency fixtures and lamps and install occupancy sensors at Blanchfield Hospital. The replacement of the existing lighting and installation of occupancy sensors will reduce energy consumption and life cycle operating costs for the hospital in accordance with the Army Energy Resources Management Plan (ERMP), and Executive Order 13759.


**functional requirements summary, PDB-1**

**S-3**

DA FORM 5020-2-R, Feb 82

TM 5-800-2 A-1

**FORT CAMPBELL, KY**



**facilities requirements sketch, PDB- ½**

DA FORM 5022-R, Feb 82

TM 8-800-3 A-21

5-4

TM 5-600-5

**APPENDIX C  
DOCUMENTATION CHECKLIST**

6-1  
S-S

#### **S. SPECIAL CONSIDERATIONS**

135

- |      |  |
|------|--|
| 4-1  | Gov. will remain for 10 days, during one, lighting festival  |
| 4-2  | Preparations will start 20 days before with USAGC and authorization for execution  |
| 4-3  | Scouting mission will begin pre-ICED, determining boundaries using various methods, location confirmation and confirming resources, engineering coordination site.             |
| 4-4  | Assignment of leaders  |
| 4-5  | Economic profile of provinces  |
| 4-6  | Agendas for new states   |
| 4-7  | Verification because of potential PBOPI confrontation with U.S. Garrison command and NATO-command could be undertaken immediately (including role of on-call USG in estimates) |
| 4-8  | Initial 24 hours support JV by engineers and field technicians coordination with USG<br>Resource presentation JV for A. JV found on historic presentation                      |
| 4-9  | Establishment of basecamp C-HQs  |
| 4-10 | Coordination with various state agencies (Protest March, International borders, etc.)  |
| 4-11 | Coordination of logistic at time of: Direct USG projects can be coordinated  |
| 4-12 | Resource compilation area  |
|      | Start Strategic Considerations 1-3 days minimum needed   |

J. 388 89-2206-A 4

**REQUIRED OR NOT REQUIRED** - You can expect no resistance to compliance. Since "R" is not a factor you do not require for this project. Since "NR" is not a factor you do not require for this project.

TO BE DETERMINED - information needed but not currently available.  
This report is informational only.

**ENTIRE ATTACHED** - Reference information contained or explained  
therein.

DOCUMENTATION - Document organization is at an existing level.

“电子政务和 E-Government”

8-2918

3 - 1998

#### **Environnemental factors**

C = 89.9%

## I - Dimeric Green Fluorescent Protein and Dimerization

## **documentation checklist**

DS FORM 5323-6.8, 300 P7

5-6

## B. SITE DEVELOPMENT

### ITEM

6-1 Consultation with the Design Office to determine and evaluate design plan hazards

6-2 Preparation, submittal, and/or approval of doc.

(A) General Site Plan

(B) Annotated General Site Plan

(C) Sketch Site Plan

(D) Facilities Requirements Sketch

6-3 Preparation of

(A) Site Survey

(B) Support Information

6-4 Approval by Department or Defense Executive Sector Board (DDESB) for Safety Site Plan

Other Site Development Considerations (list any number 11001)

1. See Project Development Brochure, PDB-1/2

**REQUIRED OR NOT REQUIRED** = has provisions or no information to determine. Enter "R" if item is relevant and is required for this project. Enter "NR" if item is relevant and is not required for this project.

**TO BE DETERMINED** = information needed but not currently obtainable from other information source

**COMMENT ATTACHED** = significant information summary for an estimate and otherwise

**DOCUMENT ATTACHED** = significant information is in an existing document attached to this page

**NOT IN DOCUMENT AND MUST BE DETERMINED**

- A - Draw
- B - Using Service
- C - Construction Services
- D - Design
- E - Other (Check Comments Attached and Explain)

## documentation checklist

DA FORM 5023-B-R, Feb 82

5-7

T31 5-500-3 C-7

### C. ARCHITECTURAL & STRUCTURAL

ITEM	RECOMMENDED ACTION	DEPARTMENT OR AGENCY RESPONSIBILITY	DEPARTMENT OR AGENCY COORDINATOR	DEPARTMENT OR AGENCY COORDINATOR	DEPARTMENT OR AGENCY COORDINATOR
C-1	Reconciliation with USAF planning programs and requirements				
C-2	Evaluation of existing facilities (including degree of utilization)				
C-3	Action for removal and replacement of existing logistic facilities				
C-4	Evaluation of off-base community facilities				
C-5	Storage and maintenance facilities (including nuclear weapons)				
C-6	Coordination facilities, payload and control facilities with Surgeon General				
C-7	Coordination of aviation facilities with PAA				
C-8	Coordination air traffic controlled navigation aids with USAFCEC				
C-9	Tabulation of types and numbers of aircraft				
C-10	Evaluation of laboratories, research and development, and technical maintenance facilities				
C-11	Coordination checks with Chief of Chaplains				
C-12	Review local service facilities by USATSA				
C-13	Automated data processing system or information processing center analysis when ADP and communication centers are coordinated with related facilities				
C-14	Coordination basic facilities with U.S. Posts Service Regional Director				
C-15	Liaison and info sharing facilities - USAF action with ASD:ISA				
C-16	Tenant facilities coordination in installation where sites				
C-17	Facilities for or exposed to rad, NBC, toxic chemicals, or ammunition - review by DDOESD Item 8-41				
C-18	Analysis of deficiencies				
C-19	Consideration of alternatives				
C-20	Determination whether objectives will include physical accommodations of disabled persons				
C-21	Airfield drainage for alterations or additions				
C-22	Availability of Standard Design or site acceptable design				
Other Architectural & Structural (List and Number items)					
1. See Supplemental Data Detailed Project Justification Paragraphs D3.					
2. See Supplemental Data Detailed Project Justification Paragraph D4.					

REQUIRED OR NOT REQUIRED = Not required or no requirement to continue.  
Enter "R" if item is required and is required for this project.  
Enter "NR" if item is not required and it is not required for this project.

TO BE DETERMINED = Information needed but not currently required.  
Enter code for information source.

COMMENT ATTACHED = Significant information summarized or explained  
by source.

DOCUMENT ATTACHED = Significant information is in an existing document while a source.

\*DO NOT USE (Check one, mark appropriate effort)

- R = DPAE
- P = Using Service
- C = Construction Source
- D = Design
- E = Other (Check Comments Attached one option)

## documentation checklist

DA FORM 5023-C.R, Feb 82

5-8

TM 5-8100-3 C-9

**D. MECHANICAL, ELECTRICAL, & UTILITY SYSTEMS**

**ITEM**

D-1	Site considerations and cost comparison analysis
D-2	Energy requirements analysis (ERA)
D-3	Conformance with DOD Energy Reduction requirements
D-4	Evaluation of existing and/or proposed utility systems

Other Mechanical and Utility Systems (list and number items):

1. See Special Requirements, Paragraph 3 (SRP-3)

S	D	U	G
C	D		
P	D		
R	D		
E	C		

**REQUIRED OR NOT REQUIRED** = Not relevant or no information to comment. Enter "N/A" if item is relevant and is required for this project.  
Enter "R" if item is relevant and is not required for this project.

**TO BE DETERMINED** = Information needed but not currently available. Enter "N/A" for information source.

**DOCUMENT ATTACHED** = Significant information summarized or documented elsewhere.

**DOCUMENT ATTACHED** = Significant information is in an existing document which is operating.

\*BY WHICH IS USED AND WHAT INFORMATION IS USED

- A = DRAE
- B = Using Services
- C = PC Construction Services
- D = L = L
- E = O = Other Comments Attached and original

**documentation checklist**

DA FORM 5023-D-R, Feb 82

5-9

TM 5-8110-3 C-11

## E. ENVIRONMENTAL CONSIDERATIONS

TCN

E-1	Environmental Impact Statement
E-2	EIA conclusion requires Environmental Impact Statement
E-3	Determination of health, environmental or related hazards. Assistance to determine existence of any health, environmental or related hazard that may be associated with Aberdeen Proving Ground, MD 21010. The Office of the Surgeon General, AFM: DASC-MCH (Army Environmental Hazards Agency).
E-4	Air/water pollution permit, coordinated with operator and compliance with standards of both state and federal laws.
E-5	Corrective measures associated with Environmental Impact Statement(s) or assessment(s) for corrective and preventive

Other environmental considerations (list, and number, name):

1. See Supp. (etc.) Data  
Data in Project Justification  
Paragraph D9.

Environmental Impact Statement	Health Assessment	Corrective Measures	Other Environmental Considerations
F	Y		
NE			
NR			
NR			

ACQUIRED OR NOT REQUIRED - Not relevant or no information to communicate. Enter "NR" if item is relevant and is required for this project. Enter "NA" if item is irrelevant and is not required for this project.

TO BE DETERMINED - Information needed but not currently available  
SOURCES FOR INFORMATION SOURCE

COMMENT ATTACHED - Significant information summarized or contained  
one source

DOCUMENT ATTACHED - Significant information is in or contains docu-  
ment other than this

\* BY WHO (Check one or more applicable items)

- A - DPAE
- B - Wings Service
- C - Construction Service
- D - Designer
- E - Other (Check Comments Attached and  
explain)

## documentation checklist

DA FORM 5023-E.R, Feb 82

5-10

TM 3-80G-3 C-13

TM 5-800-3

**APPENDIX D  
TECHNICAL DATA CHECKLIST**

8-1  
5-11

## A SPECIAL CONSIDERATIONS

### ITEM

- A1 Fraction of the population of ground circumference protected in interior roads and non-major state highways
- A2 Construction of existing infrastructure
- A3 Functional urban development (including structure, site security, traffic control, etc.)
- A4 Equipment in stores and distribution
- A5 Other equipment and furniture (C&M, C&P, and costs)
- A6 Social studies and social integration (compatibility testing, new technology testing, etc.)
- A7 Types of construction (earthworks, timberwork, semi-detachable)
- A8 Construction standards (minimum, maximum performance time, quality basis, and cost) handling and storage requirements, times used for protection

Other special considerations (any one may be none)

TYPE OF CONSTRUCTION	STRUCTURE	LANDSCAPE	SOILS	WATER
AS				
BS				
CS				
DS				
ES				
FS				
GS				
HS				
KS				
LS				
MS				
NS				
OS				
PS				
RS				
SS				
TS				
VS				

REQUIRED OR NOT REQUIRED = Basis of report or information to be determined. If "N" is used, a relevant note is required for the "D" or "S" if applicable regarding what is not required for this project.

DOES DETERMINES = Information needed but not currently available through the information sources

CONFIDENTIALITY = Classification information contained in this document

DOCUMENT ATTACHED = A portion of document is attached to this form and is identified

NOTES = Notes and important comments about

- 1 = DRAFT
- 2 = DRAFT SOURCE
- 3 = Construction basis
- 4 = Design
- 5 = Other (check common attached info)

## technical data checklist

DA FORM 5626-A-R 300-82

S-12

TII A-506-3 8

## B SITE DEVELOPMENT

ITEM

B-1 Construction restrictions or guidelines pertaining to site access and preferred construction routes

B-2 Standard clearance, set off the storage berths, berthing areas, etc.  
Facilities and/or functions of adjoining berths/structures  
Materials impact

B-3 Real estate actions (acquisition, disposal, lease, right-of-way)

B-4 Demolition/abatement requirements

B-5 Specific considerations due to explosives and asbestos  
Chemical contamination asbestos emissions toxic gases

B-6 Restrictions on disposal of surplus and reusable materials  
including hazardous waste

B-7 Pavement types and requirements (including traffic surveys  
and ATMC coordination)

B-8 Landscaping considerations

B-9 Protection of existing vegetation

B-10 Stockpile locations

C. Other Site Developments (List and number items)

F. There is a possibility, that the existing  
'gating' may contain PCB's in the ballasts.

REQUIRE DA FORM 5024-B-R, EDITION 1, 1 SEP 82  
FOR INFORMATION CONCERNING THE USE OF THIS FORM  
OR FOR INFORMATION CONCERNING THE REQUIREMENT FOR ITS USE.

TC BE DETERMINED = Information needed but not currently available  
INFO SOON FOR INFORMATION SOURCE

COMMENT ATTACHED = Information available on comment page or add a note  
INFO SOON

DOCUMENT ATTACHED = Document information is on packing sheet  
INFO SOON

TC = To be determined - check and mark appropriate section

- A - BPAF
- B - Using Services
- C - Construction Services
- D - Design
- E - Disposal/Trade Government Agencies (see  
original)

## technical data checklist

DA FORM 5024-B-R, EDITION 1, 1 SEP 82

5-13

TIN 3-8400-3

## C ARCHITECTURAL & STRUCTURAL

115

- |     |  |
|-----|--|
| C-1 | Vibration & Seismic Qualification Requirements   |
| C-2 | Same zone and other design use criteria developed by respective authority based upon local seismic activity                        |
| C-3 | Protective shield, insulation and radiation safety criteria developed by manufacturer and one-time test performed by manufacturer  |
| C-4 | Universal foundation requirements (per, per, center, side) foundation, incl, exterior treatment requirements & site, esp. lighting |
| C-5 | Configuration and strength of grates to be determined  |
| C-6 | Requirements and basis for initial design process  |
| C-7 | Universal floor and roof loads limitations   |
| C-8 | Security features (interior rooms - vaults, interior exterior pass   |

Other Archaeological & Ethnographic Items from Pommern 1900

Reporting Date Received	Date Received	Comments Arrived	Comments Accepted
#	C		
NK			
NR			
NR			
NI			
NP			
NE			
NP			

PRAGATIKA BODHAKA KARMAKALA = THIS IS A DOCUMENT OF THE ASSOCIATION IN WHICH  
MEMBERSHIP FEES "₹ 10/-" IS ASKED TO BE PAID BY THE MEMBERS FOR THE ASSOCIATION.  
FEE "₹ 10/-" IS USED TO SUPPORT AND HELP POOR PEOPLE FOR THE BENEFIT  
TO BE ORGANIZED IN A COMMUNAL WAY AND FOR COMMUNAL WORKS  
FEE "₹ 10/-" IS USED FOR COMMUNAL WORKS.

MEMBERSHIP FEE "₹ 10/-" IS USED FOR COMMUNAL WORKS AND COMMUNAL  
AND TRADITION

BODHAKA KARMAKALA = 24TH JULY, 1947, PRAGATIKA KARMAKALA  
BODHAKA KARMAKALA

१ = भूमि  
 २ = विद्युत ऊर्जा  
 ३ = बांधनी-विद्युत ऊर्जा  
 ४ = देश-ग्राम  
 ५ = देश-विद्युत ऊर्जा विद्युत विद्युत ऊर्जा

## **technical data checklist**

DA FORM 5024 C.R., FEB 53

23

## D. MECHANICAL, ELECTRICAL & UTILITY SYSTEMS

TEA

- D-1 Socio-mechanical requirements of construction project. From DA Form 816
- D-2 Socio-bean under per DA Form 800, level of team goal
- D-3 Maintenance equipment required for the project. Estimated in terms of its requirement
- D-4 Plumbing-and-drainage system type and characteristics including pipe sizes and piping materials or standards
- D-5 Heat transfer system type and characteristics of cooling and heating
- D-6 Ventilation air condition refrigeration and cooling system type and characteristics (total round trip fan pressure)
- D-7 Electrical distribution system type and characteristics are direct current, communication, etc. (including power existing)
- D-8 Water supply-drain treatment-piping system. General system type and characteristics (including piping systems)
- D-9 Energy requirements fuel conversion facilities and fuel in basic stocks (per DA Form 816)
- D-10 Green energy production

Other Mechanical & Util. Systems (use one number items)

TEA	+	T	C	I	P	U
AR						
NR						
Z	D					
NZ	D					
Z						
R	C					
AR						
NR						
S						
LR						

DATA WHICH IS NOT REQUIRED OR NOT RELATED OR NOT APPROPRIATE TO THE  
MANUFACTURER'S INFORMATION REQUESTED OR REQUIRED FOR THIS PROJE  
CT. DA FORM 816 IS NOT A REQUIREMENT AND NOT USED FOR THIS PROJECT.

TC OR REFERENCE = Information needed but not currently available  
DATA SOURCE = Information source

COMMENT ATTACHED = Significant information summarized or explained  
and discussed

SECURITY ATTACHED = Security information or classification information  
pertaining to reference

DATA WHICH IS RELATED AND APPROPRIATE TO THE  
MANUFACTURER'S INFORMATION REQUESTED OR REQUIRED FOR THIS PROJE  
CT. DA FORM 816 IS NOT A REQUIREMENT AND NOT USED FOR THIS PROJECT.

A = DATA  
P = Power Source  
C = Construction Bureau  
S = Budget  
I = Other (Cross Comments attached and  
used as)

## technical data checklist

5-15

DA FORM 5C24 D-R, Feb 62

TM 5-510A-3 D-11

## E. ENVIRONMENTAL CONSIDERATIONS

### ITEM

E-1 Waste water treatment, air quality, and noise control disposal criteria  
Other Environmental Considerations (list one number item)

NR	NR	NR	NR	NR

REQUIRED OR NOT REQUIRED = Does not mean no information is not available. Enter "R" if there is sufficient and is not required for this project.  
Enter "NR" if there is insufficient and is not required for this project.

TO BE DETERMINED = Information needed but not currently available  
Enter code for information source

COMMITTEE ATTACHED = Significant information on summarized by document  
indicated

DOCUMENT ATTACHED = Significant information is in existing docu-  
ment indicated

\*S & T SOURCE ITEMS AND THEIR APPROPRIATE LISTED

- A = SFA&S
- B = Using Services
- C = Construction Services
- D = Design
- E = Other (Name Company & Address and  
Telephone)

## technical data checklist

DA FORM 5024-E.R, PAB 82

5-16

TAB 5-800-2 B-12

## F. FIRE PROTECTION

ITEM

8.1 Special fire protection systems or features protection and suppression equipment required etc.

Other Fire Protection Considerations List and number item

NR	1	2	3	4	5

REQUIRED OR NOT REQUIRED o Not relevant or no information to evaluate methods. Enter "NR" if item is relevant and is required for the project  
Enter "NOT" if item is relevant and is not required for the project

TO BE DETERMINED o Information needed but not currently available  
Enter code for information source

COMMENT ATTACHED o Significant information summarized or detailed  
and attached

DOCUMENT ATTACHED o Significant information is in an attached document  
and attached

o BY whom (check one) and reason(s) attached

- A - DPAQ
- B - Using Source
- C - Construction Office
- D - Designee
- E - Other (Check Comments Attached and explain)

## technical data checklist

DA FORM 8024-F.R. Feb 82

5-17

TM 8-800-3 9-11

1 COMPONENT ARMY	2 DATE 23 September		
3 INSTALLATION AND LOCATION Fort Campbell, Kentucky		4 PROJECT TITLE Interior Lighting Replacements and Controls at Barracks Buildings	
5 PROGRAM ELEMENT	6 CATEGORY CODE	7 PROJECT NUMBER ECIP #3	8 PROJECT COST ISOC \$424.00
9 COST ESTIMATES			
ITEM	U.M.	QUANTITY	UNIT COST ISOC
Primary Facility			
Interior Light Fixtures	Lb.	1	366.36
Subtotal			366.36
Contingency (10%)			36.64
Total Contract Cost			402.99
Supervision, Inspection and Overhead (5.5%)			22.16
Total Request			424.15

#### 10. DESCRIPTION OF PROPOSED CONSTRUCTION

The existing interior lighting is a combination of standard efficiency fluorescent fixtures and incandescent. The proposed project will replace the interior lighting fixtures with T8 fluorescents with high efficiency electronic ballasts and compact fluorescents. The implementation of this project will save 5,545,042 kWh's of electric energy. The first year dollar savings is \$70,518 and the Savings to Investment Ratio (SIR) is 2.27.

#### 11. REQUIREMENT

**Project:** The proposed interior lighting project replaces lighting at the following Korean War Barracks w/ energy efficient lighting: 3211, 3212, 3213, 3214, 3215, 3218, 3219, 6709, 6710, 6711, 6712, 6713, 6723, 6726, 6727, 6728, 6730, 6732, 6733, 6909, 6910, 6912, 6917, 6918, 6919, 6920, 6923, 6928, 6929, 6931, 6936, 6937, 6938, 6939, 6940, 6943, 6944, 6945.

**Requirement:** The project is required to reduce the energy consumption of lighting systems and to comply w/ the Army Energy Resources Management Plan (ERMP) and Executive Order 12739. The proposed project will reduce annual energy consumption by 9,572,124 kWh's and annual energy cost by \$148,800.

**Current Situation:** The existing lighting at Blanchfield Hospital in buildings B and C is inefficient fluorescent & incandescent fixtures. The lighting in the doctors' offices and exam rooms in building C are controlled manual switches and are left on unnecessarily many hours of the day.

1. COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA	2. DATE 23 September 94
3. INSTALLATION AND LOCATION Fort Campbell, Kentucky		
4. PROJECT TITLE INTERIOR LIGHTING REPLACEMENT AND CONTROLS AT BRANCHFIELD HOSPITAL	5. PROJECT NUMBER ECIP #3	

**Impact:** If not provided, if the proposed project is not funded, a reduction of 5,545,042 MWhr cannot be achieved, and excessive amounts of energy will continue to be used. There will be no contribution to energy reduction goals established for United States Army facilities by Army Headquarters.

Colonel USA  
Commanding

ESTIMATED CONSTRUCTION START:	September 1995	INDE
ESTIMATED MIDPOINT OF CONSTRUCTION:	April 1996	INDE
ESTIMATED CONSTRUCTION COMPLETION:	November 1996	INDE

#### DETALLED JUSTIFICATIONS

##### D1. GENERAL

The proposed project encompasses the replacement of lighting at Branchfield Hospital, buildings B and C exclusive of patients rooms and surgical suites. The project will decrease the energy consumption of the lighting system without reducing light levels except where necessary. The project also installs occupancy sensors in the doctors' offices and exam rooms in building C. Lights will be automatically switched off when not required.

##### D2. ACCOMMODATIONS NOW IN USE:

The existing lighting systems are composed of standard efficiency fluorescent and incandescent fixtures. The lighting systems in the doctors' offices and exam rooms in building C have manual controls.

##### D3. ANALYSIS OF DEFICIENCY

Currently, Branchfield Hospital buildings B and C are using standard or low efficiency fixtures for lighting. The purpose of this project is to replace the existing lighting with new light fixtures which are much more efficient along with installing automatic controls in areas where lights are left on unnecessarily. The current deficiency results in large amounts of energy usage to maintain adequate lighting.

PC-FORM 101  
10-82

REVISED FORM 101-82-101  
10-82

FOR OFFICIAL USE ONLY  
(WHEN DATA IS ENTERED)

COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA	DATE 23 September 94
1. INSTALLATION AND LOCATION Fort Campbell, Kentucky		
2. PROJECT TITLE INTERIOR LIGHTING REPLACEMENT AND CONTROLS AT BANCHFIELD HOSPITAL	3. PROJECT NUMBER ECIP #3	
<b>D4. CONSIDERATION OF ALTERNATIVES:</b>  The only alternatives to the proposed project are to install lower efficiency light fixtures or more sophisticated controls. The disadvantage of using lower efficiency light fixtures is that less energy savings can be realized without significantly reducing the construction cost. If a less efficient light fixture is selected, the project would have a lower SIR. Installing more sophisticated controls would significantly increase the construction cost without increasing the savings. The project would have a lower SIR.		
<b>D5. CRITERIA FOR PROPOSED PROJECT:</b>  The proposed project will conform with all applicable federal and United States Army Regulations.		
<b>D6. PROGRAM FOR RELATED EQUIPMENT:</b>  No equipment funded from appropriations other than MCA are required.		
<b>D7. DISPOSAL OF PRESENT ASSETS:</b>  Light fixtures at Banchfield Hospital in buildings B and C will be disposed.		
<b>D8. SURVIVAL FACILITIES:</b>  The proposed project is not suitable for inclusion of protective shelters.		
<b>D9. SUMMARY OF ENVIRONMENTAL CONSEQUENCES:</b>  The proposed project has been analyzed and will not adversely impact the environment. Energy savings resulting from this project will conserve natural resources.		
<b>D10. EVALUATION OF FLOOD HAZARDS AND ENCROACHMENT ON WETLANDS:</b>  It has been determined that these facilities are not located in a flood plain and they do not encroach wetlands.		
<b>D11. ECONOMIC JUSTIFICATION:</b>  The proposed project qualifies under SCIP Guidelines in AR-415-15. SIR for the project is 2.27 with a site payback of 5.33 years. See Economic Analysis, SAP-1		

1 COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA	2 DATE 23 September 9
---------------------	---	--------------------------

3. INSTALLATION AND LOCATION  
Fort Campbell, Kentucky

4 PROJECT TITLE INTERIOR LIGHTING REPLACEMENTS AND CONTROLS AT BLANCHFIELD HOSPITAL	5 PROJECT NUMBER ECIP #3
--	-----------------------------

D12. UTILITY AND COMMUNICATION SUPPORT:

- A. No related utility support projects are programmed. Adequate utilities are available to support the project.
- B. No telecommunication support is required.

D13. PROTECTION OF HISTORIC PLACES AND ARCHEOLOGICAL SITES:

The project involves the replacement of light fixtures and installation of controls in existing buildings. Review procedures have been implemented for this project in accordance with 36 CFR 800. The review has established that there will be no effect.

D14. PROJECT DEVELOPMENT BROCHURE (PART 1):

A Project Development Brochure was prepared on 23 September 94 and is attached as a part of the programming documentation.

D15 ENERGY REQUIREMENTS:

The proposed project will reduce present energy consumption by 6,545,042 MJ/yr at the cost savings \$79,518 per year. See Energy Requirements Appraisal (EPA) in Special Requirements, Paragraph 3 (SRP).

D16. PROVISION FOR THE HANDICAPPED:

No provisions for the handicapped will be made since the scope of the project is in no way applicable designing for the handicapped.

D17. REAL PROPERTY MAINTENANCE ACTIVITY (RPMA) ANALYSIS:

- A. Physical Impact: There will be light fixture removed and replaced by the same number of light fixture. Occupancy sensors will be installed in place of wall mounted switches. No new structures will be added.

1 COMPONENT <b>ARMY</b>	FY 19 <u>94</u> MILITARY CONSTRUCTION PROJECT DATA	2 DATE 23 September 94
3 INSTALLATION AND LOCATION <b>Fort Campbell, Kentucky</b>		
4 PROJECT TITLE <b>INTERIOR LIGHTING REPLACEMENT AND CONTROLS AT BLANCHFIELD HOSPITAL</b>	5 PROJECT NUMBER <b>ECIP #3</b>	

**B. Operations and Maintenance (O&M) Impact:**

<b>O&amp;M</b>	
<b>YEAR</b>	<b>NET CHANGE (\$000)</b>
1994	-6.1
1995	-6.1
1996	-6.1

**C. Backlog of Maintenance and Repair (BMAR) Impact:**

There will be no net change in the number of fixtures or in fixture life expectancy. There will be no effect on BMAR.

**D18. COMMERCIAL ACTIVITIES:**

The proposed project is not a "New Start Expansion" as defined by DA Circular 235-1. The project has been reviewed in light of the requirements of commercial and industrial facilities. It has been determined that whereas the project does not affect commercial facilities, the requirements of DA Circular 235-1 does not apply.

1 COMPONENT ARMY	FY 19 94 MILITARY CONSTRUCTION PROJECT DATA	2 DATE 23 September 94
---------------------	---	---------------------------

3 INSTALLATION AND LOCATION Fort Campbell, Kentucky	4 PROJECT TITLE INTERIOR LIGHTING REPLACEMENT AND CONTROLS AT BLAND-FIELD HOSPITAL	5 PROJECT NUMBER ECIP #3
--	---	-----------------------------

Life Cycle Cost Analysis  
 Project Title: Interior Lighting Replacements and Controls  
 Fiscal Year: 1994  
 Analysis Date: 09/23/94  
 Economic Life: Fifteen (15) Years

1 INVESTMENT

A CONSTRUCTION COST	385 457
B. SICH	19 273
C DESIGN COST	19 273
D ENERGY CREDIT CALC	-0-
E SALVAGE VALUE	-0-
F. TOTAL INVESTMENT	424 003

2. ENERGY SAVINGS

ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTED SAVINGS

FUEL	COST \$/Btu (1)	SAVINGS MWh/YR(2)	ANNUAL S AVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A ELECT	6.18	5258	32 482	12.43	403.752
B DIST					
C RESID					
D NG					
E DEMAND			40 974	11.85	469.542
F TOTAL		5258	73 456		689.294

3 NON-ENERGY SAVINGS

A. ANNUAL RECURRING (1) DISCOUNT FACTOR (2) DISCOUNTED SAVINGS	11.85	\$8062
B. NON-RECURRING SAVINGS		571.025

ITEM	SAVINGS (1)	YEAR OF OCCURRENCE (2)	DISCOUNT FACTOR (3)	DISCOUNTED SAVINGS (4)	COST (5)
a. Replace Interior					
b. Replace Exterior					
c.					
d. Total					
C. TOTAL NON ENERGY DISCOUNTED SAVINGS (1)(2)(3)				71.83	

DD FORM 1301  
1 DEC 76

PREVIOUS EDITIONS MAY BE USED INTERNALLY

UNTIL EXHAUSTED

FOR OFFICIAL USE ONLY  
(WHEN DATA IS ENTERED)

5 - 2

1. COMPONENT ARMY	FY 18 <del>94</del> MILITARY CONSTRUCTION PROJECT DATA	2. DATE 23 September 94
3. INSTALLATION AND LOCATION Fort Campbell, Kentucky		
4. PROJECT TITLE INTERIOR LIGHTING REPLACEMENT AND CONTROLS AT BLANCHFIELD HOSPITAL	5. PROJECT NUMBER ECIP #3	

SPECIAL REQUIREMENTS PARAGRAPH 1 (SRP-1) (continued)

4. FIRST YEAR DOLLAR SAVINGS	\$ 79.51
5. SIMPLE PAYBACK PERIOD	3.33 Year
6. TOTAL NET DISCOUNTED SAVINGS	\$ 61.12
7. DISCOUNTED SAVINGS RATIO	2.2

COMPONENT ARMY	FY 13 94 MILITARY CONSTRUCTION PROJECT DATA	DATE 23 September 6
-------------------	---	------------------------

3 INSTALLATION AND LOCATION

Fort Campbell, Kentucky

4 PROJECT TITLE

INTERIOR LIGHTING REPLACEMENT AND CONTROLS AT BLANCHFIELD HOSPITAL

5 PROJECT NUMBER

ECIP 23

SPECIAL REQUIREMENTS PARAGRAPH 3 (SRP-3).

Energy Requirements Appraisal (ERA)

1. Project Description: Replace existing lighting systems with more efficient lighting system without reducing the light levels. Install occupancy sensors in doctor's offices and exam room.
2. Estimated Energy Consumption: The buildings are currently lit by standard efficiency lighting. The existing lighting system consumes 7,738,341 MJ/yr of energy. Replacing the existing lighting with high efficiency lighting and installing occupancy sensors will result in 5,545,042 MJ/yr of electrical energy savings, a seventy-two percent (72%) reduction in current energy consumption.
3. Energy Sources: No new energy sources are required for the proposed project. The use solar energy for this project is impractical.
4. Energy Use Impacts: The proposed project will substantially reduce the consumption electricity for lighting. The burden on the existing base distribution system will be lessened.
5. Energy Conservation: The proposed project will reduce annual energy consumption to 5,545,042 MJ/yr with annual energy cost savings of \$79,518. This project complies with Air Resources Management Plan (ERMP) and Executive Order 12739.
6. Energy Alternatives: The proposed project represents the greatest possible reduction in energy consumption seventy-two percent (72%), without reducing the current lighting levels. The current levels do not exceed the levels recommended by ASHRAE.
7. Energy Effects: The proposed project provides positive environmental effects. Reduces current energy consumption by seventy-two percent (72%), effectively reducing the consumption of non-renewable fuel sources. The degrading of environmental standards would not make more efficient energy sources available.
8. Goals of Approval: Total energy requirements and alternative fuel sources have been considered and included in this appraisal or discarded as applicable.

09 FEB 2011  
FRC 73

PREVIOUS EDITIONS MAY BE USED INTERNALLY  
WITH EXCUSITON

FOR OFFICIAL USE ONLY  
WHEN DATA IS ENTERED:

3-1

TABLE S.1  
PROJECT SUMMARY: HOSPITAL INTERIOR LIGHTING AND CONTROLS

SIC Category	Building Number	Eco System	Energy System	Equipment Costs		Gross Area	Site Cost	Material Costs	Labor Costs	Additional Costs	Total Cost Estimate
				Incandescent	Fluorescent						
1	610	610	4,000,000	2,000,000	2,000,000	50,000	\$12,500	\$120,000	\$14,700	\$1,200	\$12,700
2	611	611	3,000,000	1,500,000	1,500,000	50,000	\$12,500	\$120,000	\$14,700	\$1,200	\$11,700
<b>Total</b>			<b>8,000,000</b>	<b>3,500,000</b>	<b>3,500,000</b>	<b>100,000</b>	<b>\$25,000</b>	<b>\$240,000</b>	<b>\$30,400</b>	<b>\$2,400</b>	<b>\$30,400</b>

LIFE CYCLE COST ANALYSIS SUMMARY  
 ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) STUDY: HOSP101  
 INSTALLATION & LOCATION: FORT CAMPBELL REGION NOS. 4 LCCID: 1.080  
 PROJECT NO. & TITLE: HOSPITAL INTERIOR LIGHTING & CONTROLS @ HOSPIT  
 FISCAL YEAR 94 DISCRETE PORTION NAME: LIGHTING  
 ANALYSIS DATE: 09-14-94 ECONOMIC LIFE 15 YEARS PREPARED BY: J. HOLL

SSE

1. INVESTMENT  
 A. CONSTRUCTION COST \$ 385457.  
 B. SITE \$ 19273.  
 C. DESIGN COST \$ 19273.  
 D. TOTAL COST (IA+IB+IC) \$ 424003.  
 E. SALVAGE VALUE OF EXISTING EQUIPMENT \$ 0.  
 F. PUBLIC UTILITY COMPANY RERATE \$ 0.  
 G. TOTAL INVESTMENT (ID + IE + IF) \$ 424003.

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS CCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNT SAVINGS
A. ELECT	\$ 6.18	5256.	\$ 32482.	.12.43	\$ 403
B. DIST	\$ .00	0.	\$ 0.	.13.56	\$ 0.
C. RESID	\$ .00	0.	\$ 0.	.15.09	\$ 0.
D. NAT G	\$ .00	0.	\$ 0.	.15.86	\$ 0.
E. COAL	\$ .39	0.	\$ 0.	.13.61	\$ 0.
F. LPG	\$ .00	0.	\$ 0.	.12.64	\$ 0.
M. DEMAND SAVINGS			\$ 48974.	.11.85	\$ 405
N. TOTAL		5256.	\$ 73656.		\$ 889

3. NON ENERGY SAVINGS (+) / CCOST (-)

A. ANNUAL RECURRING (+/-)

(1) DISCOUNT FACTOR (TABLE A)  
 (2) DISCOUNTED SAVINGS/COST (3A X 3A1)

\$ 6  
 \$ 71

2.  
 5.

B. NON RECURRING SAVINGS(-) / CCOSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR CC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+)/ COST(-)(4)
------	------------------------------	-----------------	------------------------	---

C. TOTAL \$ 0. 0.

5.

G. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 71

4. FIRST YEAR DOLLAR SAVINGS 2N3+3A+ (3Bd1/(YRS ECONOMIC LIFE)) \$ 79

5.

5. SIMPLE PAYBACK PERIOD (1G/4) \$ 3.33

EAS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 961

9.

7. SAVINGS TO INVESTMENT RATIO (SIR) = (6 / 1G) = 3.27  
 (IF < 1 PROJECT DOES NOT QUALIFY)

8. ACCURSED INTERNAL RATE OF RETURN (AIRR) : 6.68

LIFE CYCLE COST ANALYSIS SUMMARY  
 ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) STUDY: ECO1HOSP  
 INSTALLATION & LOCATION: FORT CAMPBELL REGION NOS. 4 CENSUS: 3 LCCID 1.080  
 PROJECT NO. & TITLE: ECO1HOSP INTERIOR LIGHTING & HOSPITAL  
 FISCAL YEAR 94 DISCRETE PORTION NAME: LIGHTING  
 ANALYSIS DATE: 09-14-94 ECONOMIC LIFE 15 YEARS PREPARED BY: J. HOLLE

BE

SSE

1. INVESTMENT

A. CONSTRUCTION COST	\$ 374668.
B. SILOH	\$ 18734.
C. DESIGN COST	\$ 18734.
D. TOTAL COST (1A+1B+1C)	\$ 412135.
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$ 0.
F. PUBLIC UTILITY COMPANY REBATE	\$ 0.
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$ 412135.

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS \$/MBTU(2)	ANNUAL S AVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNT SAVINGS(5)
A. ELECT	\$ 6.18	4672.	\$ 28873.	12.43	\$ 3588
B. DIST	\$ .00	0.	\$ 0.	13.56	\$ 0
C. RESID	\$ .00	0.	\$ 0.	15.09	\$ 0
D. NAT G	\$ .00	0.	\$ 0.	15.86	\$ 0
E. COAL	\$ .00	0.	\$ 0.	13.61	\$ 0
F. LPG	\$ .00	0.	\$ 0.	12.64	\$ 0
M. DEMAND SAVINGS			\$ 40974.	11.85	\$ 4855
N. TOTAL		4672.	\$ 69947.		\$ 8444

3. NON ENERGY SAVINGS (+) / CCOST(-)

A. ANNUAL RECURRING (+/-)

(1) DISCOUNT FACTOR (TABLE A)	11.85	\$ 60
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 718

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+)/ COST (-) (4)
D. TOTAL	\$ 0.			0.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+)/COST (-) (3A2+3Bd4)\$				718
4. FIRST YEAR DOLLAR SAVINGS 2N3+3A+3Bd1/(YRS ECONOMIC LIFE))\$				759
5. SIMPLE PAYBACK PERIOD (1G/4)				5.43
6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C)				\$ 936:
7. SAVINGS TO INVESTMENT RATIO (SIR)=(6 / 10) = (IF < 1 PROJECT DOES NOT QUALIFY)				2.22
8. ADJUSTED INTERNAL RATE OF RETURN (AIRR):				8.74

## FORT CAMPBELL LIGHTING SURVEY

ECO 4: INTERIOR / EXTERIOR LUMINANCE

REPLACEMENT OF EXISTING FIXTURES RELOCATE ME AT  
19 AUGUST 1994

卷之三

PAGE

## FORT CAMPBELL LIGHTING SURVEY

ECD 4: METEROR / OZONE

WILLIAM WOODWARD: A BRIEF HISTORY OF THE PRACTICE IN

PAGE 5.

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

INTERIOR LIGHTING: FLUORESCENT FIXTURE REPLACEMENT

BUILDING #: 605 - HOSPITAL

AREA:

AREAL USE:

HOURS/DAY

DAYSPANNER

240V VOL. 1AFC 217

ELECTRIC COSTS  
ENERGY CHARGE:  
D-Y-MAND CHARGE:

\$0.0211 PER KWH  
\$11.16 PER KW

EXISTING FIXTURE DATA

2 FOOT  
... 20 2 LAMP @ 92 WATT = 1,840 WATTS  
4 FOOT  
1 LAMP @ 45 WATT = 0 WATTS  
... 700 2 LAMP @ 92 WATT = 71,490 WATTS  
... 60 3 LAMP @ 137 WATT = 8,316 WATTS  
... 32 4 LAMP @ 164 WATT = 50,728 WATTS

6 FOOT  
1 LAMP @ 92 WATT = 0 WATTS  
... 700 2 LAMP @ 125 WATT = 87,500 WATTS  
... 60 3 LAMP @ 164 WATT = 9,720 WATTS  
... 32 4 LAMP @ 191 WATT = 76,384 WATTS

8 FOOT  
1 LAMP @ 92 WATT = 0 WATTS  
... 700 2 LAMP @ 125 WATT = 87,500 WATTS

BASELINE ENERGY CONSUMPTION

BASELINE DEMAND

ECO ENERGY CONSUMPTION  
ECO DEMAND

NET ENERGY SAVINGS  
NET ENERGY SAVINGS

NET DEMAND SAVINGS  
NET DOLLAR SAVINGS

\$07,474 PER  
\$29,763 PER

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: EXTERIOR / EXTERIOR LIGHTING

19 AUGUST 1986

EXTERIOR SURVEY: FLUORESCENT FURNITURE REPLACEMENT

Surveys done at:  
AMERICAN  
AREA USE: 24  
HOURS/DAY  
DAYS/WEEK 7  
BUILDING VOLTAGE 277

## EXISTING FURNITURE DATA

ELECTRIC COSTS  
ENERGY CHARGE  
DEMAND CHARGE  
\$0.0711 PER kWh  
\$11.78 PER KW

## REPLACEMENT FURNITURE DATA

	2 FOOT	3 FOOT	4 FOOT	5 FOOT	6 FOOT	8 FOOT
2 LAMP U-2	32 WATTS	48 WATTS	64 WATTS	80 WATTS	96 WATTS	128 WATTS
4 LAMP U-2	64 WATTS	96 WATTS	128 WATTS	160 WATTS	192 WATTS	256 WATTS
6 LAMP U-2	96 WATTS	144 WATTS	192 WATTS	240 WATTS	300 WATTS	432 WATTS
8 LAMP U-2	128 WATTS	192 WATTS	256 WATTS	320 WATTS	400 WATTS	512 WATTS
10 LAMP U-2	160 WATTS	240 WATTS	320 WATTS	400 WATTS	500 WATTS	640 WATTS
12 LAMP U-2	192 WATTS	288 WATTS	384 WATTS	480 WATTS	600 WATTS	768 WATTS
14 LAMP U-2	224 WATTS	336 WATTS	448 WATTS	560 WATTS	700 WATTS	896 WATTS
16 LAMP U-2	256 WATTS	384 WATTS	512 WATTS	640 WATTS	800 WATTS	1024 WATTS

	2 FOOT	3 FOOT	4 FOOT	5 FOOT	6 FOOT	8 FOOT
2 LAMP U-2	32 WATTS	48 WATTS	64 WATTS	80 WATTS	96 WATTS	128 WATTS
4 LAMP U-2	64 WATTS	96 WATTS	128 WATTS	160 WATTS	192 WATTS	256 WATTS
6 LAMP U-2	96 WATTS	144 WATTS	192 WATTS	240 WATTS	300 WATTS	432 WATTS
8 LAMP U-2	128 WATTS	192 WATTS	256 WATTS	320 WATTS	400 WATTS	512 WATTS
10 LAMP U-2	160 WATTS	240 WATTS	320 WATTS	400 WATTS	500 WATTS	640 WATTS
12 LAMP U-2	192 WATTS	288 WATTS	384 WATTS	480 WATTS	600 WATTS	768 WATTS
14 LAMP U-2	224 WATTS	336 WATTS	448 WATTS	560 WATTS	700 WATTS	896 WATTS
16 LAMP U-2	256 WATTS	384 WATTS	512 WATTS	640 WATTS	800 WATTS	1024 WATTS

	NET ENERGY SAVINGS	NET DOLLAR SAVINGS	NET ENERGY SOURCES	NET DOLLAR SOURCES
BASELINE ENERGY CONSUMPTION	\$0.0711/kWh	\$0.0711/kWh	\$0.0711/kWh	\$0.0711/kWh
BASELINE DEMAND	61.36 kW	61.36 kW	61.36 kW	61.36 kW

NET ENERGY SAVINGS

NET DOLLAR SAVINGS

NET ENERGY SOURCES

NET DOLLAR SOURCES

# FORT CAMPBELL LIGHTING SURVEY

ECO 1: INTERIOR / EXTERIOR LIGHTING

19 AUGUST 1994

## INTERIOR LIGHTING: INCANDESCENT LAMP REPLACEMENT

BUILDING #: ESS - HOSPITAL  
AREA: DRESSING ROOMS  
LAMP USE: 18  
HOURS/DAY: 5  
DAYSPER/WK: 1 (1-YES, 2-NO)  
PEAK USE:  
BUILDING VOLTAGE: 277

ELECTRIC COSTS  
ENERGY CHARGE \$0.0211 PER KWH  
OF METER CHARGE \$11.76 PER KW

## EXISTING INCANDESCENTS

LAMPS @	52 WATTS @	0 WATTS @	13 WATTS @	9 WATTS @
LAMPS @	60 WATTS @	0 WATTS @	0 WATTS @	0 WATTS @
LAMPS @	75 WATTS @	0 WATTS @	10 WATTS @	0 WATTS @
LAMPS @	80 WATTS @	0 WATTS @	16 WATTS @	1245 WATTS @
LAMPS @	85 WATTS @	0 WATTS @	26 WATTS @	
26 LAMPS @	135 WATTS @	6665 WATTS @		

## BASELINE ENERGY CONSUMPTION

30,336 KWH  
199,175 SJ  
6.49 KW

## BASELINE DEMAND

ECO DEMAND

NET DEMAND SAVINGS \$740 NR

NET DOLLAR SAVINGS \$1,354 NR

## COMPACT FLUORESCENT REPLACEMENT

10 LAMPS @	13 LAMPS @	16 LAMPS @	26 LAMPS @	4,248 KWH
0 WATTS @	0 WATTS @	0 WATTS @	0 WATTS @	4,493 MJ
0 WATTS @	0 WATTS @	1245 WATTS @		1.25 KW

## ECO ENERGY CONSUMPTION

199,175 SJ  
6.49 KW

## ECO DEMAND

NET ENERGY SAVINGS \$9,152 NR

NET ENERGY SAVINGS \$9,152 NR

# SYSTEMS Corp

SYSTEMS ENGINEERING AND MANAGEMENT CORPORATION

## BLDG 850 - HOSPITAL

ELECTRICAL COSTS - ENERGY CHARGE  $\$0.02119/\text{kWh}$   
DEMAND CHARGE  $\$1178/\text{kW}$

ASSUMPTIONS - CHILLER COP = 3

$$1. \text{ DEMAND SAVINGS} = \left[ \frac{(\text{BASE LINE DEMAND}) - (\text{COP COOLING} \times \text{COP LIGHTING})}{\text{COP COOLING} + \text{COP LIGHTING}} \right]$$

$$\div \text{COP OF CHILLERS} \times 12 \frac{\text{MONTHS}}{\text{YR}} \times \$1178 \frac{\text{kW}}{\text{kW}}$$

$$= (532.41 \text{ kW} - 119.02 \text{ kW})/3 \times 12 \times \$11.78/\text{kW}$$

$$= \underline{\underline{\$10,243/\text{yr}}} \quad (72.4 \text{ kW})$$

$$2. \text{ ENERGY SAVINGS} = \frac{\text{KW OF COOLING} \times .5 \times 8700 \frac{\text{HR}}{\text{YR}} \times .02119 \frac{\text{KWH}}{\text{kW}}}{\text{SAVED}}$$

$$= 72.4 \text{ kW} \times .5 \times 8700 \frac{\text{HR}}{\text{YR}} \times .02119 \frac{\text{KWH}}{\text{kW}}$$

$$= \underline{\underline{\$6,709/\text{yr}}} \quad (317,574.8 \text{ KWH OR } 1,060 \text{ MWH})$$

$$3. \text{ TOTAL SAVINGS} = \$10,243 + \$6,709 = \underline{\underline{\$16,952/\text{yr}}}$$

PROJ. COOLING SAVINGS DUE TO ILLUMINATION 11% LIGHTING LOAD	CHARTED BY	RECD PAUL B. G.
PROJ. FOR 1 COMPARE II LIGHTING SYSTEM (COP-1 Interior/Lighting Load)	PREPARED BY	SHED NO. PAGE 3-1 1 CP-1
	REC'D BY	

28-JUL-94

MeansData for Lotus

Page

Estimate: Lighting-opt.4 Date: 12 July 1994  
 Description: Hospital  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
0207082119	DEMO. 2X2', 1X4' FLUOR FIXTURES					1023.00 EA	
Unit values	0.36	0.00	10.00	0.00	0.00	0.00	10.00
Totals	372.37	\$0	\$10,230	\$0	\$0	\$0	\$10,230
0207082121	DEMO. 2X4' FLUOR FIXTURES					1297.00 EA	
Unit values	0.49	0.00	13.35	0.00	0.00	0.00	13.35
Totals	629.05	\$0	\$17,315	\$0	\$0	\$0	\$17,315
0207082122	DEMO. STRIP/INDUST FLUOR FIXTURES					295.00 EA	
Unit values	0.32	0.00	8.80	0.00	0.00	0.00	8.80
Totals	94.40	\$0	\$2,596	\$0	\$0	\$0	\$2,596
0207082123	DEMO. INCAND FIXTURES/EXIT LIGHTS					48.00 EA	
Unit values	0.26	0.00	7.10	0.00	0.00	0.00	7.10
Totals	12.38	\$0	\$341	\$0	\$0	\$0	\$341
U02 SITWORK		1109	\$0	\$30,482	\$0	\$0	\$30,482

28-Jul-94

## MeansData for Lotus

Page

Line #	Description	Manhours Matl Labor Equipment Sub Total					
		Manhours	Matl	Labor	Equipment	Sub	Total
1661307777	L.E.D. EXIT SIGN SINGLE FACE				0.00 EA		
Unit values	1.00 185.00	27.50	0.00	0.00	0.00	212.50	
Totals	0.00 \$0	\$0	.30	\$0	\$0	\$0	
1661308803	COMP FLUOR, 9" ROUND REC, 2 26W QT OPEN REFLECTOR				48.00 EA		
Unit values	2.29 0.00	63.00	0.00	0.00	0.00	63.00	
Totals	109.92 \$0	\$3,024	\$0	\$0	\$0	\$3,024	
1661309901	REC FLUOR TROFFER PARABOLIC 2X2' W 2 32W T8-U 3" DEEP, 9-CELL				23.00 EA		
Unit values	1.40 114.00	38.50	0.00	0.00	0.00	152.50	
Totals	32.29 \$2,622	\$886	\$0	\$0	\$0	\$3,508	
1661309902	REC FLUOR TROFFER PARABOLIC 2X4' W 2 32W T8 3" DEEP, 12-CELL				0.00 EA		
Unit values	1.51 110.00	41.50	0.00	0.00	0.00	151.50	
Totals	0.00 \$0	.30	\$0	\$0	\$0	\$0	
1661309903	REC FLUOR TROFFER PARABOLIC 2X4' W 3 32W T8 3" DEEP, 19-CELL				0.00 EA		
Unit values	1.60 142.00	44.00	0.00	0.00	0.00	186.00	
Totals	0.00 \$0	\$0	\$0	\$0	\$0	\$0	
1661309904	REC FLUOR TROFFER PARABOLIC 2X4' W 4 32W T8 3" DEEP, 32-CELL				0.00 EA		
Unit values	1.70 159.00	47.00	0.00	0.00	0.00	206.00	
Totals	0.00 \$0	\$0	\$0	\$0	\$0	\$0	
1661309905	REC FLUOR TROFFER PARABOLIC 1X4' W 2 32W T8 3" DEEP, 9-CELL				0.00 EA		
Unit values	1.40 92.00	38.50	0.00	0.00	0.00	130.50	
Totals	0.00 \$0	\$0	\$0	\$0	\$0	\$0	
1661309906	REC FLUOR TROFFER PARABOLIC 1X4' W 1 32W T8 3" DEEP, 9-CELL				3.00 EA		
Unit values	1.40 86.00	38.50	0.00	0.00	0.00	126.50	
Totals	4.21 \$264	\$116	\$0	\$0	\$0	\$380	
1661309907	REC FLUOR TROFFER PARABOLIC 2X4' W 2 32W T8 3" DEEP, 12-CELL, REFLECTOR				990.00 EA		
Unit values	1.51 133.50	41.50	0.00	0.00	0.00	175.00	
Totals	1494.80 \$132,165	\$41,085	\$0	\$0	\$0	\$173,250	
1661309908	REC FLUOR TROFFER PARABOLIC 2X4' W 3 32W T8 3" DEEP, 18-CELL, REFLECTOR				0.00 EA		
Unit values	1.60 164.30	44.00	0.00	0.00	0.00	208.50	

28-Jul-94

## MeansData for Lotus

Page

<b>Totals</b>	0.00	\$0	\$0	\$0	\$0	\$0	\$0
1661309909	SUR/WALL FLUOR 1X4' W 2 32W T8						
Unit values	1.14	86.00	31.50	0.00	0.00	EA	
Totals	0.00	\$0	\$0	\$0	\$0		117.50
1661309910	INDUSTRIAL FLUOR 1X4' W 2 32W T8						
Unit values	1.14	90.00	31.50	0.00	249.00	EA	
Totals	283.86	\$22,410	\$7,844	\$0	0.00		121.50
1661309921	STRIP FLUOR. 1X4' W 2' 32W T8						
Unit values	1.14	55.00	31.50	0.00	46.00	EA	
Totals	52.44	\$2,530	\$1,449	\$0	0.00		86.50
1661309933	SUR/WALL VANITY FLUOR 1X2' W 2 17W T6				34.00	EA	
Unit values	1.14	78.00	31.50	0.00	0.00		
Totals	38.76	\$2,652	\$1,071	\$0	\$0		109.50
1661309998	SUR FLUOR TROFFER PARABOLIC 1X4' W 1 32W T8 3" DEEP, 9-CELL, REFLECTOR				8.00	EA	
Unit values	1.40	135.75	38.50	0.00	0.00		
Totals	11.23	\$1,086	\$308	\$0	\$0		174.25
1661309999	REC FLUOR TROFFER PARABOLIC 1X4' W 1 32W T8 3" DEEP, 9-CELL, REFLECTOR				1262.00	EA	
Unit values	1.40	100.75	38.50	0.00	0.00		
Totals	1771.85	\$127,147	\$48,587	\$0	\$0		139.25

28-Jul-84

MeansData for Lotus

Page

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
U16 ELECTRICAL		3800	\$290,876	\$104,370		\$0	\$395,246
ESTIMATE TOTAL		4909	\$290,876	\$134,852		\$0	\$425,728
SALES TAX	5.00%		\$14,544				
MATL MARKUP	-40.00%		(\$116,350)				
LABOR MARKUP	-13.40%			(\$18,070)			
EQUIPT MARKUP	0.00%				\$0		
SUB MARKUP	3.00%					\$0	
TOTAL BEFORE CONTINGENCY		\$189,069	\$116,782			\$0	\$305,851
CONTINGENCY	10.00%						\$30,585
BOND	2.50%						\$7,646
PROFIT	10.00%						\$30,585
JOB TOTAL							\$374,668

28-Jul-94

MeansData for Locus

Page

Estimate: Lighting-opt.4 Date: 12 July 1994  
 Description: Hospital  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City indx:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
U02 SITWORK	1109	\$0	\$20,482	\$0	\$0	\$30,482
U16 ELECTRICAL	3800	\$290,876	\$104,370	\$0	\$0	\$395,246
<b>TOTAL</b>	<b>4909</b>	<b>\$290,876</b>	<b>\$134,832</b>	<b>\$0</b>	<b>\$0</b>	<b>\$425,728</b>
SALES TAX	5.00%	\$14,544				
MATL MARKUP	-40.00%	(\$116,360)				
LABOR MARKUP	-13.40%		(\$18,070)			
EQUIPT MARKUP	0.00%			\$0		
SLB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENC</b>	<b>\$169,369</b>	<b>\$116,782</b>		<b>\$0</b>	<b>\$0</b>	<b>\$305,851</b>
CONTINGENCY	10.00%					\$30,585
BOND	2.50%					\$7,646
PROFIT	10.00%					\$30,585
<b>JOB TOTAL</b>						<b>\$374,666</b>

LIFE CYCLE COST ANALYSIS SUMMARY  
 ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) STUDY: ECO2HOS  
 INSTALLATION & LOCATION: FORT CANFIELD REGION NCS. LCCID 1.080  
 PROJECT NO. & TITLE: ECO2HOSF LIGHTING CONTROLS & HOSPITAL  
 FISCAL YEAR 94 DISCRETE PORTION NAME: LIGHTING  
 ANALYSIS DATE: 09-14-94 ECONOMIC LIFE 18 YEARS PREPARED BY: J. HOLL

SB:

1. INVESTMENT  
 A. CONSTRUCTION COST \$ 10729.  
 B. STCK \$ 540.  
 C. DESIGN COST \$ 540.  
 D. TOTAL COST (A+B+C) \$ 11869.  
 E. SALVAGE VALUE OF EXISTING EQUIPMENT \$ 0.  
 F. PUBLIC UTILITY COMPANY REBATE \$ 0.  
 G. TOTAL INVESTMENT (D - E - F) \$ 11869.

2. ENERGY SAVINGS (+) / COST (-)

DATE OF WESTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR (2)	ANNUAL S AVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNT SAVINGS
A. ELECT	\$ .18	584.	\$ 3609.	12.43	\$ 44
B. DIST	\$ .00	0.	\$ 0.	13.56	\$ 0.
C. RESID	\$ .00	0.	\$ 0.	15.09	\$ 0.
D. NAT G	\$ .00	0.	\$ 0.	15.86	\$ 0.
E. COAL	\$ .00	0.	\$ 0.	13.61	\$ 0.
F. LPG	\$ .00	0.	\$ 0.	12.64	\$ 0.
G. DEMAND SAVINGS			\$ 0.	11.85	\$ 0.
H. TOTAL		584.	\$ 3609.		\$ 44

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)

- (1) DISCOUNT FACTOR (TABLE A)
- (2) DISCOUNTED SAVING/COST (3A X 3A1)

\$ 11.85  
\$

C.  
C.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS(+) COST(-) (1)	YR SC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+)/ COST(-)(4)
A. TOTAL	\$ 0.			C.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-): 3A2+3Ad4(5)				0.
4. FIRST YEAR DOLLAR SAVINGS 2N5+3A+(3Ad1/(YRS ECONOMIC LIFE))S			S	3.
5. SIMPLE PAYBACK PERIOD (1G/4)				3.29
6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C)			\$ 44	1.
7. SAVINGS TO INVESTMENT RATIO (S:IR)=(S / 1G)= (IF < 1 PROJECT DOES NOT QUALIFY)			3.78	
8. ADJUSTED INTERNAL RATE OF RETURN (AIRR):			12.66	

## FORT CAMPBELL LIGHTING SURVEY

### ECO #2: LIGHTING CONTROLS

16 AUGUST 1994

#### OCCUPANCY SENSOR SAVINGS AFTER LIGHTING RETROFIT

BUILDING #: 690 - HOSPITAL  
AREA: 1 FLA WORKS & CPTIC'S  
WATTAGE CONTROLLED: 23,638 W  
ON/OFF PEAK: 0% (1.10-0%)

CURRENT USAGE (AFTER PROPOSED RETROFIT)  
WEEKDAY 24 HOURS  
WEEKEND 7 HOURS

	CURRENT ENERGY CONSUMPTION	PROPOSED ENERGY CONSUMPTION	NET ENERGY SAVINGS	NET DOLLAR SAVINGS
BASELINE ENERGY CONSUMPTION	200,240 kWh	76,960 kWh	-	\$15,921 MVR
BASELINE DEMAND	23,828 kW	-	-	384 MVR
				\$3,616 MVR

ELECTRIC COSTS  
ENR. H.P. CHARGE \$0.0211 PER KWH  
DEMAND CHARGE \$11.78 PER KW

REVISED USAGE:  
WEEKDAY 8 HOURS  
WEEKEND 6 HOURS

37,187 kWh  
133,874 MJ  
23.84 kW

\$0 MVR  
\$3,616 MVR

27-Jul-94

MeansData for Lotus

Pa

Estimate: Hospital-Control Date: 12 July 1994  
Description: Hospital  
Project: Lighting Study Bid Date:  
Location: Ft. Campbell Job #:  
Sq. footage: City index:

Line #	Description	Manhours	Matl	Labor	Equipment	Sub	Total
166230L000	OCCUPANCY SENSORS					140.00 EA	
Unit values	PASSIVE INFRARED, MANUAL OFF SW.	0.50	\$0.00	13.75	0.00	0.00	73.7
Totals		70.00	\$8,400	\$1,925	\$0	\$0	\$10,32
C16 ELECTRICAL		70	\$8,400	\$1,925	\$0	\$0	\$10,32

27-JUL-94

Meanslate for Lotus

Pa

Line #	Description						
	Markups	Matl	Laser	Equipment	Sub	Total	
ESTIMATE TOTAL	70	\$6,400	\$1,920	\$0	\$0	\$10,32	
SALES TAX	5.00%	\$400					
MATL MARKUP	-20.00%	\$1,280					
LABOR MARKUP	-13.40%		\$255				
EQUIPT MARKUP	3.00%			\$0			
SUB MARKUP	0.00%				\$0		
TOTAL BEFORE CONTINGENCY	\$7,140	\$1,667	\$0	\$0	\$0	\$8,80	
CONTINGENCY	10.00%						\$88
BOND	2.50%						\$22
PROFIT	10.00%						\$88
JOB TOTAL							\$10,78

27-Jul-94


MeansData for Lotus

Page

Estimate: Hospital-Control Date: 12 July 1994  
 Description: Hospital  
 Project: Lighting Study Bid Date:  
 Location: Ft. Campbell Job #:  
 Sq. footage: City index:

**SUMMARY**

	Manhours	Matl	Labor	Equipment	Sub	Total
C16-ELECTRICAL	70	\$8,400	\$1,925	\$0	\$0	\$10,325
<b>TOTAL</b>	<b>70</b>	<b>\$8,400</b>	<b>\$1,925</b>	<b>\$0</b>	<b>\$0</b>	<b>\$10,325</b>
SALES TAX	5.00%	\$420				
MATL MARKUP	-20.00%	(\$1,680)				
LABOR MARKUP	-13.40%		(\$258)			
EQUIPT MARKUP	0.00%			\$0		
SUB MARKUP	0.00%				\$0	
<b>TOTAL BEFORE CONTINGENCY</b>		<b>\$7,140</b>	<b>\$1,667</b>	<b>\$0</b>	<b>\$0</b>	<b>\$8,807</b>
CONTINGENCY	10.00%					\$88
BOND	2.50%					\$221
PROFIT	10.00%					\$88
<b>JOB TOTAL</b>						<b>\$10,786</b>





Total Customer Satisfaction

## CUSTOMER SUPPORT 1-800-MLI-0089

### HIGH PERFORMANCE FEATURES

Power Factor	Greater than 90
Total Harmonic Distortion	Less than 10%
Third Harmonic Distortion	Less than 5%
Lamp Current Crest Factor	Less than 1.5
Lamp Current Frequency	Greater than 25 KHz
Lamp Configuration	Series
Lamp Rating	Less than 2%, Not Visible
Ground Rating	Class A
Transformer Life	20 years plus
Connector	Push-n-wire trap for 18 gauge 16AWG wire
Line GND	1.2 'BS
EMI	Meets FCC Part 15, Subpart C

### CODES


UL Listed: Class P  
Transient Protection: Meets ANSI C62.41, Cat. A  
(Formerly IEEE 367)

### PART NUMBER DESCRIPTION



### WIRETRAP CONNECTOR

Our Unique Pole-in  
Connectors Simplify Installation  
and Save Time



### QUALITY

Motorola's goal of acceptable quality is at Six Sigma or no more than 3.4 defects per million opportunities. Motorola Lighting Inc. designed its electronic ballast to meet the most rigorous performance standards at world class levels. This translates into a highly robust product that goes through extensive environmental stress testing to assure our customers of very low initial defect levels (less than 0.3%) and high reliability (greater than 500,000 hours Mean Time to Failure—MTTF).

The economic ballast life is 20 years when operated at 45°C ambient temperature. Operation at MLI's ballast at 50°C may reduce life expectancy by 25%.

Six Sigma Quality means "world class" in all that we do at Motorola Lighting Inc., which is part of our commitment to TOTAL CUSTOMER SATISFACTION.




# RAPID START BALLASTS

LAMP Type	Rated Lamp Voltage (V)	Lamp Length (ft.)	Model No.	Line Voltage (V)	Max Line Current (A)	Typical Line Current (A)	Typical Input Power (W)	Min Starting Temp (F)
Open Enclosed								
<b>1 LAMP T8</b>								
F32T8	32	4	M1 RMT8-LLL-120	120	.31	.24	29	56
F32T8	32	4	M1 RMT8-LLL-277	277	.13	.11	29	56
F32T8	32	3	M1 RMT8-LLL-120	120	.30	.19	23	56
F32T8	32	3	M1 RMT8-LLL-277	277	.10	.08	23	56
F32T8	25	2	M1 RMT8-LLL-277	277	.10	.08	23	56
F32T8	17	2	M1 RMT8-LLL-120	120	.17	.13	18	56
F32T8	17	2	M1 RMT8-LLL-277	277	.07	.06	16	56
<b>2 LAMP T8</b>								
F32T8	32	4	M2 RMT8-LLL-120	120	.35	.31	51	56
F32T8	32	4	M2 RMT8-LLL-277	277	.16	.11	50	56
F32T8	32	3	M2 RMT8-LLL-120	120	.42	.40	48	56
F32T8	32	3	M2 RMT8-LLL-277	277	.16	.17	46	56
F32T8	25	2	M2 RMT8-LLL-120	120	.27	.24	38	56
F32T8	17	2	M2 RMT8-LLL-277	277	.12	.10	34	56
<b>2 LAMP T12</b>								
F40T12	40	6	M2 RMT12-LLL-120	120	.84	.59	71	66
F40T12	40	6	M2 RMT12-LLL-277	277	.37	.35	66	67
F40T12	34	6	M2 RMT12-LLL-120	120	.54	.39	66	66
F40T12	34	6	M2 RMT12-LLL-277	277	.23	.21	66	66
F40T12	30	6	M2 RMT12-LLL-120	120	.64	.60	72	71
F40T12	30	6	M2 RMT12-LLL-277	277	.27	.25	70	66
F30T12	30	3	M2 RMT12-LLL-120	120	.46	.44	63	62
F30T12	30	3	M2 RMT12-LLL-277	277	.21	.18	62	60
F30T12	25	3	M2 RMT12-LLL-120	120	.40	.37	64	63
F30T12	25	3	M2 RMT12-LLL-277	277	.17	.16	63	60
<b>3 LAMP T8</b>								
F32T8	32	4	M3 RMT8-LLL-120	120	.78	.78	66	67
F32T8	32	4	M3 RMT8-LLL-277	277	.33	.32	66	66
F32T8	32	3	M3 RMT8-LLL-120	120	.81	.82	70	67
F32T8	25	3	M3 RMT8-LLL-277	277	.29	.29	66	66
F32T8	17	2	M3 RMT8-LLL-120	120	.38	.35	67	64
F32T8	17	2	M3 RMT8-LLL-277	277	.18	.16	64	61
<b>3 LAMP T12</b>								
F60T12	60	6	M3 RMT12-LLL-120	120	.92	.88	107	103
F60T12	60	6	M3 RMT12-LLL-277	277	.48	.46	106	103
F60T12	52	6	M3 RMT12-LLL-120	120	.64	.77	91	66
F60T12	52	6	M3 RMT12-LLL-277	277	.61	.53	90	66
F60T12	50	6	M3 RMT12-LLL-120	120	.79	.79	106	103
F60T12	50	6	M3 RMT12-LLL-277	277	.45	.39	107	103
F50T12	50	3	M3 RMT12-LLL-120	120	.78	.67	107	101
F50T12	50	3	M3 RMT12-LLL-277	277	.38	.37	106	101
F50T12	40	3	M3 RMT12-LLL-120	120	.78	.67	106	101
F50T12	40	3	M3 RMT12-LLL-277	277	.38	.37	105	101
F40T12	40	3	M3 RMT12-LLL-120	120	.78	.67	107	101
F40T12	40	3	M3 RMT12-LLL-277	277	.38	.37	106	101
F30T12	30	3	M3 RMT12-LLL-120	120	.78	.67	106	101
F30T12	30	3	M3 RMT12-LLL-277	277	.37	.36	105	101
F25T12	25	3	M3 RMT12-LLL-120	120	.71	.67	107	66
F25T12	25	3	M3 RMT12-LLL-277	277	.36	.34	106	66
<b>4 LAMP T8</b>								
F32T8	32	4	M4 RMT8-LLL-120	120	1.04	1.32	121	110
F32T8	32	4	M4 RMT8-LLL-277	277	.64	.63	118	110
F32T8	32	3	M4 RMT8-LLL-120	120	.81	.80	58	61
F32T8	25	3	M4 RMT8-LLL-277	277	.36	.34	63	60
F32T8	25	3	M4 RMT8-LLL-120	120	.66	.66	67	60
F32T8	17	2	M4 RMT8-LLL-277	277	.23	.19	51	60
F32T8	17	2	M4 RMT8-LLL-120	120	.66	.66	51	60


NOTICE: THIS CATALOGUE IS FOR STANDARD EQUIPMENT AT THE ABOVE TEMPS. TEST DATA FROM MANUFACTURER IS NOT FOR ARCHIVING OR REQUEST FROM FACTORY.

# WIRING DIAGRAMS AND BALLAST DIMENSIONS


## WIRING DIAGRAMS




1 LAMP



3 LAMP





2 LAMP



4 LAMP

## BALLAST DIMENSIONS\*



Our most extensive manufacturing facilities in North America for U.S.A.




**MOTOROLA**  
Lighting Inc.

617 Commerce Parkway  
Bellaire, Ohio 44413  
1-800-MU-3030

\* See Material Safety Data Sheet  
for Material Safety  
Information  
United States Environmental Protection Agency  
Docket No. E-1000-A-000000


© 1987 MOTOROLA



**SILVERLUX<sup>TM</sup>**  
**REFLECTORS**  
**CUT YOUR**  
**LIGHTING ENERGY**  
**COSTS IN HALF.**



PAGE 5-4



# SILVERLUX FLUORESCENT REFLECTORS

- Cut energy costs in half or enhance lighting levels
- Pay for themselves in two years or less
- Install and maintain easily
- Warrantied for 5 years
- Attractive low-rate financing available
- Available from retrofitter dealer network

For more information just call.

3M is a part of the Green Lights Program--a voluntary, non-regulatory program organized by the Environmental Protection Agency (EPA). This program encourages corporations to take advantage of new lighting technologies and design principles that benefit the environment. 3M is a unique member of the program because it participates as both a consumer of electric lighting energy and as a developer of electrical lighting products. Silverlux reflectors demonstrate 3M's commitment to energy-efficient lighting technologies that reduce energy consumption and pollution while delivering the same or better lighting.

Cost Control. Not Lighting.

3M Construction Markets  
3M Center, Bldg. 225-4S-08  
St. Paul, MN 55143-1000  
612-736-2386

Innovation working for you



PAGE 5

# Evenlite LED Exit Lights

EV-SERIE

*The LED of the 21st Century*



*No Ifs, Ands or Buts.*

This is exactly how the EVENLITE 2000 appears! Perfectly even illumination is produced by indirect lighting, so that the LED's are invisible, with no hot spots. All this is provided in the slimmest sign on the market with integral charger and battery.

No competitor comes close to these combined specifications:

- Less than 3 watts total power per face
- Perfect light distribution across face
- Single face only 1 1/8" thick
- Double face only 2 1/8" thick
- Remote unit only 3/8" thick
- Multiple LED lamps with 20 year unconditional guarantee
- NICAD batteries with 5 year guarantees
- Aluminum housing for light weight and strength
- Universal mount
- Baked enamel, vinyl clad or satin anodized finishes
- Polycarbonate faceplate

Patent Pending



SHIELD SOURCE INCORPORATED  
320 VFW Avenue, Grasonville, Maryland 21638  
Tel.: (410) 627-6923 Fax: (410) 627-6387

PAGE 5-5:

## PIONEER

1011 Series  
*Economy!*



UL Listed

### STANDARD FEATURES

- White translucent acrylic lens.
- White enamel finished steel pan.
- 120 volt class "P" ballast.
- Lamp(s) included.

### OPTIONS

- High power factor ballast.
- 277 volt ballast.
- Theft proof screws.

MODEL	WATTAGE	L	D
P-1011	115-230-2X13	11"	3"
P-1014	115-230-2X14	14"	3"

## ECLIPSE

5012 Series  
*New!*



UL Listed

### STANDARD FEATURES

- White translucent acrylic lens.
- White enamel finished steel pan.
- 120 volt class "P" ballast.
- Lamp(s) included.


### OPTIONS

- High power factor ballast.
- 277 volt ballast.
- Theft proof screws.

MODEL	WATTAGE	L	D
EC-5012	115-230-2X13	12"	4.5"
EC-5013	2X13-2X13-3W	13"	4.5"

## DISCOVERY

3011 Series  
*Traditional  
Square!*



UL Listed

### STANDARD FEATURES

- White translucent acrylic lens.
- White enamel finished steel pan.
- 120 volt class "P" ballast.
- Lamp(s) included.

### OPTIONS

- High power factor ballast.
- 277 volt ballast.
- Theft proof screws.

MODEL	WATTAGE	L	D
DI-3011	115-230-2X13	13"	3.25"
DI-3014	115-230-2X13-3W	14"	3.25"

## EXPLORER

1010 Series  
*Low  
Profile!*



UL Listed

### STANDARD FEATURES

- White vandal resistant lexan lens.
- Black lexan housing.
- 120 volt class "P" ballast.
- White powder coated reflector.
- Lamp(s) included.

### OPTIONS

- High power factor ballast.
- 277 volt ballast.
- White lexan housing.

MODEL	WATTAGE	L	D
EP-1010	115-230-2X13	11"	3.5"

## PLUTO

1303 Series  
*Vandal!*



UL Listed

### STANDARD FEATURES

- White heavy gauged lexan lens.
- Corrosion-proof lexan base.
- White powder coated reflector.
- Lamp(s) included.
- 120 volt class "P" ballast.


### OPTIONS

- High power factor ballast.
- 277 volt ballast.

MODEL	WATTAGE	L	D
PL-1303	115-230-2X13	10"	4.5"

## COSMO

400 Series  
*Low  
Profile!*



UL Listed

### STANDARD FEATURES

- White lexan lens.
- White vandal proof lexan lens.
- 120 volt class "P" ballast.
- Lamp(s) included.

### OPTIONS

- High power factor ballast.
- 277 volt ballast.

MODEL	WATTAGE	L	D
CO-1400	115-230-2X13	13"	4.5"



112-L series

**ARMSTRONG**

100 Series  
Fluorescent

**STANDARD FEATURES**

- 10" wide heavy gauge lexan lens.
- Corrosion proof lexan base.
- 120 volt class "T" ballast.
- Lamp(s) not included.

**OPTIONS**

- High power factor ballast
- 277 volt ballast

WATTAGE	L	D
40W	13 1/2" x 5 1/2" x 10 1/2"	4 1/2"



112-L series

**STRATUS**

2011 Series  
Low Profile Square!

**STANDARD FEATURES**

- White translucent acrylic lens.
- White enamel finished steel pan.
- 120 volt class "T" ballast.
- Lamp(s) included.

**OPTIONS**

- High power factor ballast
- 277 volt ballast
- Theft proof screws

MODEL	WATTAGE	L
STR2011-130X9.25-SK13	13"	
STR2011-130X9.25-SK14	14"	



112-L series

**CENTURY**

1010 Series  
Fluorescent


**STANDARD FEATURES**

- White extra strong lexan lens.
- White enamel finished steel pan.
- 120 volt class "T" ballast.
- Lamp(s) included.

**OPTIONS**

- High power factor ballast
- 277 volt ballast.
- Theft proof screws

WATTAGE	L	D
40W	13 1/2" x 5 1/2" x 11 3/4"	4 1/2"



112-L series

**NOVA**

200 Series  
Euro-Lite

**STANDARD FEATURES**

- Opal polycarbonate diff.
- White corrosion-proof base.
- White powder coated reflector.
- 120 volt class "T" ballast.
- Lamp(s) included.

**OPTIONS**

- Black reflector cage.
- Black lexan housing.
- Theft proof screws.

MODEL	WATTAGE	L
NV200-1-0-13-CAP	10"	



112-L series

**HALO**

213 Series  
Economy!

**STANDARD FEATURES**

- Durable polycarbonate blue
- Available in white or black.
- White C° acrylic globe
- 120 volt class "T" ballast
- Lamp included

- Options
- Clear polycarbonate jar
- White armable jar
- 110V globe

WATTAGE	L	D
18W	9 1/2" x 6 1/2" x 10 1/2"	6"
25W	10 1/2" x 7 1/2" x 10 1/2"	6"
35W	11 1/2" x 8 1/2" x 10 1/2"	6"



112-L series

**KENNEDY**

100 Series  
Fluorescent

**STANDARD FEATURES**

- Brushed aluminum housing
- Durable white lexan jar.
- 120 volt class "T" ballast
- Lamp included

**OPTIONS**

- Clear polycarbonate jar
- C° round globe
- High power factor ballast
- Full chain

100-130-1-0-4P100F	L
100-130-1-0-4P11	85"
100-130-1-0-4P12	94"

## **Switchomat™**

**The world's best investment in  
automatic light switching  
....with a 6-year proven track record!**

\$50.00 invested now will earn a \$500 to \$1,400 return by 1999.



**Turns the lights on  
automatically when you  
enter...and off after  
you leave.**



**Model SOM-500**

Automatic wall switch replacement  
for private offices, conference rooms,  
restrooms, etc. Takes only minutes  
to install utilizing the existing wires.

**Model SOM-1000**

Automatic wall switch replacement  
for large rooms and classrooms. Only  
minutes to install utilizing the  
existing wires.

### **Special Features**

- Manual lights off switch • Built-in safety neon night light
- Shortened recycle time delay during installation
- Convenient visible logic key bypass provision in the unlikely event of sensor failure • Vandal resistant design

### **Ultrasafe**

The *Switchomat*™ is equipped with a metal safety shield in compliance with the highest fire rating standards. Unit is automatically grounded for safety when mounted on an existing metal switch box.



- Universal Energy Control, Inc. is able to offer smaller sized, aesthetic, moderately priced devices because of our exclusive patent #4,875,962.
- Universal Energy Control, Inc. does not use ungrounded, potentially dangerous, bulky heat sinks. Instead, it uses easily trouble-prone components.
- Universal Energy Control, Inc. devices provide superior operating capabilities and switching even with electronic ballast; a 10 day money back guarantee and 3 to 5 years warranty.

PAC

## Energy conservation is a terrific investment

Normally all lights are turned on at 8 A.M. and not turned off until 6 P.M. by the custodians. The lights are on a total of 12 hours a day. Based on actual tests and evaluations, most people only occupy their private offices for 4 hours a day and the remaining 8 hours are spent attending meetings, appointments, lunch, etc. Consequently, daily wasted energy consumption is 8 hours.

In an office or meeting room equipped with 8 fluorescent lamps at 40 watts each the total electrical load is 320 watts including ballasts. Then using "Switchomat" the lights are turned off automatically when the last person leaves the room and will save the following:

$$\begin{aligned} \text{Daily cost savings: } & 8 \text{ Hours} \times 320 \text{ watts} = 3 \text{ KWH} \times 8c = 24c \\ \text{Weekly cost savings: } & 5 \times 24 = \$1.20 \quad \text{Yearly cost savings: } 52 \times \$1.20 = \$62.40 \end{aligned}$$

Yearly savings are conservatively calculated since no holidays or vacations are considered. During these periods even energy is wasted. In addition, cooling costs are reduced when the lights are off.

**THEORY OF OPERATION** A "Switchomat" passive infrared detector device reacts to the infrared heat rays transmitted from the human body and is a passive non-irradiating device.

**AESTHETIC FEATURES** Facility managers and engineers recognize the real value of installing money-saving features in buildings. The "Switchomat" adds prestige and convenience in addition to its contemporary appearance.

**DEPENDABILITY** You can depend on Unenco's electrical manufacturing and design methods. The "Switchomat" proven electrical circuitry. No heat is generated as in other electronic switching devices and therefore complaints or queas from occupants are eliminated. Patent # 4,874,862.

**UNIVERSAL ENERGY INC.** is a leader in infrared and ultrasonic occupancy sensors to control light and HVAC in all large rooms. Unsec Inc., the parent company has been manufacturing over 1,000,000 occupancy sensing detectors since 1971 for the security industry.




Fig. 1




Fig. 2

### SCM 300-A

- Operates on standard fluorescent fixtures
- 120VAC Below 120 VAC 600W incandescent
- 120VAC Below or 277 VAC 600W 16 HP
- Maintain light output 10% above rated output
- Cover Range 8ft x 3' x 12' Weight 102
- Power consumption 2watts/ft<sup>2</sup> inc. WIR
- See Fig. 1 for exterior pattern

### SCM 1000-A-2

- 2 settings with manual on light switch
- Operates incandescent, fluorescent fixtures
- 100W below 120VAC 600W incandescent each eye
- 180W below or 277 VAC 600W 16 HP each eye
- 2 manual light-off switches
- Cover Range 8ft x 3' x 12' Weight 7.25
- Power consumption 2watts/ft<sup>2</sup> inc. WIR
- See Fig. 2 for exterior pattern

### SCM 1000-A

- Operates incandescent, fluorescent fixtures
- 120VAC Below 120 VAC 600W incandescent
- 120VAC Below or 277 VAC 600W 16 HP
- Light output 10% above
- Cover Range 8ft x 3' x 12' Weight 102
- Power consumption 2watts/ft<sup>2</sup> inc. WIR
- See Fig. 2 for exterior pattern

### SCM 1000-B

- Operates incandescent, fluorescent fixtures
- Minimum 60 watt to Maximum 600 watt at 120V
- Minimum 100 watt to Maximum 600 watt at 277V below 1
- Maximum 100 watt
- Cover Range 8ft x 3' x 12' Weight 14.00 PAGE
- Power consumption 2watts/ft<sup>2</sup> inc. WIR
- See Fig. 3 for exterior pattern

## **REPRODUCTION QUALITY NOTICE**

We use state-of-the-art high speed document scanning and reproduction equipment. In addition, we employ stringent quality control techniques at each stage of the scanning and reproduction process to ensure that our document reproduction is as true to the original as current scanning and reproduction technology allows. However, the following original document conditions may adversely affect Computer Output Microfiche (COM) and/or print reproduction:

- Pages smaller or larger than 8.5 inches x 11 inches.
- Pages with background color or light colored printing.
- Pages with smaller than 8 point type or poor printing.
- Pages with continuous tone material or color photographs.
- Very old material printed on poor quality or deteriorating paper.

If you are dissatisfied with the reproduction quality of any document that we provide, particularly those not exhibiting any of the above conditions, please feel free to contact our Directorate of User Services at (703) 767-9066/9068 or DSN 427-9066/9068 for refund or replacement.

**END SCANNED DOCUMENT**